



**LOAD TABLE  
LIGHTING CONTROLLER "A"**

CIRCUIT	RED PHASE		BLACK PHASE		
	AMPS	WATTS	AMPS	WATTS	
A	23.8	5,712	B	23.8	5,712
C	41.3	9,912	D	39.1	9,384
E	23.8	5,712	F	23.8	5,712
G	35.4	8,496	H	33.0	7,920
I	13.8	3,312	J	13.8	3,312
K			L		
M	16.3	3,912	N	15.4	3,696
O			P		
<b>TOTAL</b>	<b>154.4</b>	<b>37,056</b>	<b>TOTAL</b>	<b>148.9</b>	<b>35,736</b>

**SINGLE LINE DIAGRAM  
LIGHTING CONTROLLER "A"**

NOTES:  
1. SEE DRAWING ME-12 FOR WIRING DIAGRAM DETAILS

**LEGEND**

- HIGH MAST LIGHT TOWER.
- 400 W. HPS LUMINAIRE (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- HIGH MAST TOWER DESIGNATION.
- LIGHTED SIGN STRUCTURE WITH 170 W. FLUORESCENT LUMINAIRE, QUANTITY OF LUMINAIRE AS REQUIRED. (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- 3 POLE SAFETY SWITCH
- UNDERPASS LIGHTING UNIT, 70W HPS LUMINAIRE. (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- LIGHTING CONTROLLER
- GROUND FIELD
- ELECTRIC UTILITY SERVICE
- ELECTRIC CABLE ASSEMBLY
- CONVENTIONAL LIGHTING UNIT, 310 WATT HPS LUMINAIRE. (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)

**SINGH** 300 W. ADAMS ST.  
CHICAGO, IL 60606  
SINGH & ASSOCIATES, INC.  
CONSULTING ENGINEERS TEL: (312) 629-0240  
FAX: (312) 629-8449

**REVISIONS**

NAME	DATE

SLO7-01

ILLINOIS DEPARTMENT OF TRANSPORTATION  
F.A.I. 90/94 (DAN RYAN EXPRESSWAY)  
31st STREET TO I-57

**SINGLE LINE DIAGRAM  
LIGHTING CONTROLLER "A"  
PROPOSED IMPROVEMENTS 2007**

SCALE: NOT TO SCALE      DRAWN BY: YJ  
DATE: OCTOBER 29, 2004      CHECKED BY: TM

JNT55091027-53b-807-01-5H 11/23/2004 2:37:35 PM