



LOAD TABLE LIGHTING CONTROLLER "O"					
CIRCUIT	RED PHASE		BLACK PHASE		
	AMPS	WATTS	AMPS	WATTS	
A	13.7	3,288	B	11.7	2,808
C	18.9	4,536	D	18.0	4,320
E	15.5	3,720	F	15.5	3,720
G	19.6	4,704	H	17.6	4,224
I	31.5	7,560	J	31.5	7,560
K	27.6	6,624	L	27.2	6,528
M	27.1	6,504	N	27.1	6,504
O	29.0	6,950	P	29.4	7,056
TOTAL	182.5	43,800	TOTAL	178.0	42,720

LEGEND

- HIGH MAST LIGHT TOWER.
- 400 W. HPS LUMINAIRE (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- HIGH MAST TOWER DESIGNATION.
- LIGHTED SIGN STRUCTURE WITH 170 W. FLUORESCENT LUMINAIRE, QUANTITY OF LUMINAIRE AS REQUIRED. (BLACK PHASE-SOLID SYMBOL, RED PHASE, OPEN SYMBOL)
- 3 POLE SAFETY SWITCH
- ELECTRIC UTILITY SERVICE
- GROUND ROD
- LIGHTING CONTROLLER
- UNDERPASS LIGHTING UNIT, 70W HPS LUMINAIRE. (BLACK PHASE- SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- ECA
- UNDERPASS LIGHTING UNIT, 150W HPS LUMINAIRE (BLACK PHASE SOLID SYMBOL, RED PHASE OPEN SYMBOL)

**SINGLE LINE DIAGRAM
LIGHTING CONTROLLER "O"**

NOTES:
1. SEE DRAWING ME-12 FOR WIRING DIAGRAM DETAILS.

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION
F.A.I. 90/94 (DAN RYAN EXPRESSWAY)
31st STREET TO I-57

**SINGLE LINE DIAGRAM
LIGHTING CONTROLLER "O"
PROPOSED IMPROVEMENTS 2007**

SCALE: NOT TO SCALE
DATE: OCTOBER 29, 2004

DRAWN BY: YJ
CHECKED BY: TM

SINGH 300 W. ADAMS ST.
SINGH & ASSOCIATES, INC. CHICAGO, IL 60606
CONSULTING ENGINEERS TEL: (312) 629-0240
FAX: (312) 629-8449

11/23/2004 1:32:18 PM