

68428

F.A.S. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
1375		STARK	6	2

\* D4 CULVERT REPLACE 2005

### COMMITMENTS

NO COMMITMENTS HAVE BEEN MADE FOR THIS PROJECT.

### GENERAL NOTES

#### ORDERING LENGTH CONFIRMATION - DRAINAGE ITEMS

THE CONTRACTOR SHALL CONSULT WITH THE ENGINEER IN REGARD TO THE EXACT LENGTH OF THE BOX/PIPE CULVERTS, STORM SEWERS, AND/OR PIPE DRAINS REQUIRED PRIOR TO ORDERING THESE ITEMS.

### JOB SPECIFIC GENERAL NOTES

#### PLAN ELEVATIONS

ALL ELEVATIONS SHOWN ON THE PLANS ARE ESTABLISHED ACCORDING TO A TEMPORARY BENCHMARK. AT THE TOP OF A FIRE HYDRANT LOCATED NORTHEAST OF THE CULVERT, THE ELEVATION IS ASSUMED TO BE 100.00 FEET. THE APPROXIMATE LOCATION OF THE HYDRANT IS SHOWN ON THE PLAN SHEET.

#### EMBANKMENT

EMBANKMENT SHALL BE CONSTRUCTED TO THE PROPOSED GRADE LINE SHOWN ON THE CROSS-SECTIONS AT BOTH ENDS OF THE PIPE CULVERT MEETING THE TERMS OF ARTICLE 205. THIS WORK WILL NOT BE PAID FOR SEPARATELY, BUT WILL BE CONSIDERED INCLUDED IN THE COST OF THE PIPE CULVERT.

#### BITUMINOUS CONCRETE MIXTURE REQUIREMENTS

THE FOLLOWING MIXTURE REQUIREMENTS ARE APPLICABLE TO THIS PROJECT:

MIXTURE USES	CLASS D PATCH (BOTTOM LIFTS)	CLASS D PATCH (SURFACE LIFT)
AC/PG:	PG 64-22	PG 64-22
RAP% (MAX):*	25%	15%
DESIGN AIR VOIDS:	4.2% @ N=50	4.2% @ N=50
MIXTURE COMPOSITION: (GRADATION MIXTURE)	IL 19.0	IL 9.5 OR 12.5
FRICITION AGGREGATE:	N.A.	MIX D

COMMITMENTS  
AND  
GENERAL NOTES