F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
704	(1)N & TS-1	McLEAN	497	497
STA. 0+200.000		TO STA. 0+350.000		
FED. ROAD DIST. NO. _		ILLINOIS	FED. AID PROJECT	

CONTRACT NO. 70514

FINAL SURVEY NOTE BOOK	BY	DATE
	SURVEYED	
	PLOTTED	
	TEMPLATE	
	AREAS	
NO.	AREAS CHECKED	

ORIGINAL SURVEY NOTE BOOK	BY	DATE
	SURVEYED	
	PLOTTED	
	TEMPLATE	
	AREAS	
NO.	AREAS CHECKED	

PERMITTED TAP SIZES

TAP SIZE	MINIMUM SIZE OF WATERMAIN TO BE TAPPED
19mm (3/4 ")	100mm (4" DIA.) + (6" DIA)
38 mm (1½")	200mm (8")

* 50mm (2") AND OVER MUST BE MADE BY SIDE TAP SLEEVES AND VALVES OR BY A REGULAR TEE. ALL SIDE TAPS 50mm (2") DIA. AND OVER SHALL BE MADE BY CITY FORCES @ THE SCHEDULED PRICES ESTABLISHED BY THE WATER DEPARTMENT.

+ TAPS ON WATER MAINS CONSTRUCTED BEFORE 1980 SUBJECT TO REVIEW AND APPROVAL OF THE CITY OF BLOOMINGTON WATER DEPARTMENT.



PIPE COVER DETAILS



TYPICAL WATER SERVICE

SERVICE SIZE	* CORP. STOP	* CURB STOP	* CURB BOX
19mm (3/4 ") & 25mm (1")	MUELLER H-15000	MUELLER H-15200 or A.Y. McDONALD 4T13	MUELLER H-10314 or A.Y. MCDONALD 5601
30mm (1 ¼")	MUELLER H-15000	MUELLER H-15204 or A.Y. McDONALD 6100	A.Y. MCDONALD 5603
38mm (1-1/2") & 50mm (2")	BALL VALVES FORD, MUELLER OR A.Y. MCDONALD	BALL VALVES FORD, MUELLER OR A.Y. MCDONALD	A.Y. MCDONALD 5603

* OR APPROVED EQUAL



TYPICAL CURB BOX INSTALLATION IN SIDEWALK OR DRIVEWAY



SAMPLING & CHLORINATION SERVICE PIPING TAP



TYPICAL HYDRANT INSTALLATION PLAN

PIPE MATERIALS

WATER MAINS SHALL BE POLY WRAPPED DUCTILE IRON PIPE SPECIAL CLASS 52 WITH SINGLE GASKET JOINTS.

CEMENT LINING AND TAR (SEAL) COATING SHALL BE PROVIDED FOR ALL PIPE. ALL PIPE SHALL HAVE PUSH-ON TYPE JOINT UNLESS OTHERWISE CALLED FOR.

WHERE RESTRAINED JOINTS ARE SPECIFIED, THEY SHALL MEET ONE OF THE FOLLOWING:
A. U.S. PIPE: TR FLEX JOINT
B. AMERICAN DUCTILE IRON PIPE: LOK-RING JOINT
C. McWANE INC. (CLOW): TITON OR FASTITE JOINT
D. GRIFFIN PIPE: SNAP-LOK OR BOLT-LOK JOINT
E. 350mm (14") OR LARGER PIPE: EBBA IRON SALES MEG-A-LUG RETAINER GLANDS
F. 300mm (12") OR SMALLER PIPE STANDARD RETAINER GLANDS FROM APPROVED MANUFACTURERS.
G. OR APPROVED EQUAL.

WATER MAIN FITTINGS INCORPORATED INTO THIS WORK SHALL CONFORM TO A.N.S.I./A.W.W.A. C110/A21.10 AND A.N.S.I./A.W.W.A. C111/A21.11, 1725 Kpa (250 psi) RATED PRESSURE. ALL FITTINGS SHALL HAVE THE SAME LININGS AND COATINGS AS THE PIPE SUPPLIED. ALL FITTINGS (INCLUDING BUT NOT LIMITED TO BENDS, TEES, REDUCERS, AND PLUGS) SHALL BE RESTRAINED WITH RETAINER GLANDS OR A MANUFACTURED JOINT RESTRAINING SYSTEM APPROVED BY THE DIRECTOR OF WATER.

TAPPING VALVES SHALL BE CLOW F6114 OR APPROVED EQUAL. RETAINER GLANDS SHALL BE: McWANE (CLOW) F-1058 OR APPROVED EQUAL, AND SHALL BE INSTALLED AT THE JOINT BETWEEN THE VALVE AND THE PROPOSED WATER MAIN.

TAPPING SLEEVES SHALL BE STAINLESS STEEL WITH STAINLESS STEEL BOLTS AS FOLLOWS:

TAPS ONTO EXISTING 100mm (4"), 150mm (6"), AND 200mm (8") MAINS:
CASCADE CST-SL, FORD FAST OR APPROVED EQUAL

TAPS ONTO EXISTING 250mm (10") OR LARGER MAINS:
CASCADE CST-EX OR APPROVED EQUAL

VALVE BOXES SHALL BE PROVIDED AND INSTALLED. ALL VALVE BOXES SHALL HAVE NOT LESS THAN A 130mm (5¼") SHAFT. THE EXTENSIONS OF THE VALVE BOX AND SHAFT NECESSARY TO REACH THE GROUND ELEVATION SHALL BE INCLUDED. VALVE BOXES SHALL BE TYLER PIPE TWO PIECE, SCREW TYPE, #6850 SERIES WITH THE WORD "WATER" CAST ON LID OR AN APPROVED EQUAL.

NOTES

1. THE "STANDARD SPECIFICATIONS FOR WATER AND SEWER MAIN CONSTRUCTION IN ILLINOIS", FIFTH EDITION, DATED MAY 1996 SHALL APPLY TO THIS WORK, EXCEPT AS MODIFIED HEREIN.
2. ALL WATERMAIN MATERIALS SHALL BE MANUFACTURED IN COUNTRIES SIGNATORY TO THE NORTH AMERICAN FREE TRADE AGREEMENT AND SHALL MEET OR EXCEED AWWA SPECIFICATIONS.
3. FOR APPROVED MANUFACTURERS NOT LISTED ON THIS SHEET, INQUIRE OF THE DIRECTOR OF THE CITY OF BLOOMINGTON WATER DEPARTMENT AT (309) 434-2426.
4. ALL FIRE HYDRANTS, VALVES, AND FITTINGS SHALL BE RESTRAINED.
5. A #12 THHN SINGLE STRAND ELECTRIC CABLE SUITABLE FOR DIRECT BURIAL SHALL BE INSTALLED ON ALL WATERMAINS. THE CABLE SHALL BE TAPED OR ATTACHED TO THE PIPE IN AN APPROVED MANNER DURING INSTALLATION AND PRIOR TO BACKFILLING. TWO FEET OF SLACK SHALL BE PROVIDED AT ALL VALVE BOXES AND FIRE HYDRANTS. THE SLACK SHALL BE WRAPPED AROUND THE YAVLE BOX OR FIRE HYDRNAT AT FINISHED GRADE.
6. ALL VERTICAL AND HORIZONTAL BENDS SHALL BE CONSTRUCTED WITH RESTRAINED JOINT PIPE. RESTRAINED JOINT LENGTHS SHALL BE DETERMINED IN ACCORDANCE WITH THE DUCTILE IRON PIPE RESEARCH ASSOCIATION (DIPRA) GUIDELINES & FURNISHED FOR REVIEW.



TYPICAL HYDRANT LOCATION PLAN



WATER MAIN CROSSING

VALVE REQUIRED ON EACH SIDE OF SEWER, CREEK OR OTHER CROSSING WHERE WATER MAIN IS MORE THAN 2.4 m (8'-0") DEEP.

NO SERVICE TAPS OR HYDRANT CONNECTIONS BETWEEN VALVES.

FIRE HYDRANTS SHALL BE: WATEROUS PACER, CLOW F-2500, CLOW MEDALLION, MUELLER MODERN CENTURION. ALL HYDRANTS SHALL BE STEAMER TYPE. A STEAMER HYDRANT SHALL HAVE A MINIMUM 133.4mm (5-1/4") INTERNAL VALVE, TWO 63.5mm (2-1/2") HOSE NOZZLES WITH NATIONAL STANDARD THREADS, AND ONE 114.3mm (4-1/2") PUMPER NOZZLE WITH BLOOMINGTON STANDARD THREADS: 7 THREADS PER 25.4mm (1"), 6.27mm (0.247") DEEP. THE STEAMER NOZZLE SHALL BE EQUIPPED WITH A STORZ FITTING. FOR ALL HYDRANTS, ALL BOLTS BELOW GROUND LEVEL SHALL BE STAINLESS STEEL. FIRE HYDRANTS SHALL BE PAINTED SAFETY YELLOW WITH A PAINT APPROVED BY THE DIRECTOR OF THE WATER DEPARTMENT. PRIVATE HYDRANTS SHALL BE PAINTED SAFETY RED.



TYPICAL HYDRANT INSTALLATION SECTION

FOR REFERENCE ONLY

CITY OF BLOOMINGTON
PUBLIC WORKS DEPARTMENT

SCALE NONE

DESIGN BY: CBB PUBLIC WORKS REVISED - 12/28/2009 TJM
APPROVED BY: _ DATE: _

WATER MAIN STANDARDS

GREENWOOD AVENUE WATER MAIN REPLACEMENT

SHEET C5.1

NOTES & DETAILS