


NOTES:

1. SEE DRAWING E-01 FOR IDOT ELECTRICAL SYMBOLS.
2. PROVIDE 3-1/2 NO. 2 WITH 1/2 NO. 4 GROUND XLP TYPE USE CABLES IN 1 1/2" UNIT DUCT.
3. PROVIDE A TEMPORARY AERIAL CABLE FEED, 3-1/2 NO. 2 WITH MESSENGER FROM JUNCTION BOX MOUNTED ON THE BRIDGE TO THE EXISTING MEDIAN WALL MOUNTED LIGHTING UNIT AS SHOWN. CONNECT THE ROADWAY LIGHTING UNITS TO THE UNDERPASS LIGHTING SYSTEM.
4. SEE DRAWING NO. E-05 FOR THE PEORIA STREET UNDERPASS LIGHTING PLAN.
5. THIS DRAWING SHOWS THE FINAL CONDITIONS FOR THE TEMPORARY ROADWAY LIGHTING CONNECTIONS.



E-04

FILE PATH = p:\388035\pmt\aescom\line\local\p\AECD\00\Documents\01_Americas\Transportation\60269938_Circle\Phase 1\1000_CAD\016_Electrical\Sheets\60W29_sht-Light-04



D160W29-sht-Light-04
 USER NAME = BAW:tor.t
 PLOT SCALE = 100.0000' / 1" = 100.0000'
 PLOT DATE = 10/28/2013

DESIGNED - WDS	REVISED -
DRAWN - CAM	REVISED -
CHECKED - JPC	REVISED -
DATE - 10/30/2013	REVISED -

**STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION**

I-290 PROPOSED LIGHTING PLAN

SCALE: 1"=50' SHEET 4 OF 19 SHEETS STA. TO STA.

F.A.I. RTE. 90/94/290	SECTION 2013-011R	COUNTY COOK	TOTAL SHEETS 356	SHEET NO. 114
CONTRACT NO. 60W29			ILLINOIS FED. AID PROJECT	