



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

February 23, 2010

SUBJECT: FAI Route 55 (I-55)
Section 99 (1&2) RS-11
Will County
Contract No. 60I53
Item No. 243, March 5, 2010 Letting
Addendum A

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

1. Replaced the Schedule of Prices.
2. Revised page ii of the Table of Contents to the Special Provisions.
3. Added pages 105 - 121 to the Special Provisions.
4. Revised sheets 1, 2, 3 & 28 of the Plans.
5. Added sheets 9A - 9D and 34A - 34H to the Plans.

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

Scott E. Stitt, P.E.
Acting Engineer of Design and Environment

A handwritten signature in cursive script, reading "Ted B. Walschleger P.E." with a small "P.E." to the right.

By: Ted B. Walschleger, P. E.
Engineer of Project Management

cc: Diane O'Keefe, Region 1, District 1; Mike Renner; Estimates

TBW:MS:jc

ILLINOIS DEPARTMENT OF TRANSPORTATION
 SCHEDULE OF PRICES
 CONTRACT
 NUMBER - 60153

State Job # - C-91-060-10
 PPS NBR - 1-77325-0000
 County Name - WILL - -
 Code - 197 - -
 District - 1 - -
 Section Number - 99 (1 & 2) RS-11

Project Number

Route
 FAI 55

* REVISED : FEBRUARY 23, 2010

Item Number	Pay Item Description	Unit of Measure	Quantity	x	Unit Price	=	Total Price
X0322729	MATL TRANSFER DEVICE	TON	50,988.000				
X0324685	TEST STRIP SMA	EACH	2.000				
X0325305	STR REP CON DP = < 5	SQ FT	15.800				
X0325702	NIGHT WORK ZONE LIGHT	L SUM	1.000				
X0325775	WET RF TEM TAPE T3 4	FOOT	319,200.000				
X0325841	WET RF TEM TAPE T3 24	FOOT	270.000				
X0325876	WET RF TEM TAPE T3 8	FOOT	15,600.000				
X0326107	WET RF TEM TAPE T3 5	FOOT	38,300.000				
* X0326872	CON T 2 HD POLY COILB	FOOT	200.000				
X4066685	POL HMA BC SMA N80	TON	23,120.000				
X7011015	TR C-PROT EXPRESSWAYS	L SUM	1.000				
X7013820	TR CONT SURVEIL EXPWY	CAL DA	50.000				
* X8850102	INDUCTION LOOP	FOOT	540.000				
* Z0030250	IMP ATTN TEMP NRD TL3	EACH	2.000				
* DELETED							

ILLINOIS DEPARTMENT OF TRANSPORTATION
 SCHEDULE OF PRICES
 CONTRACT
 NUMBER - 60153

State Job # - C-91-060-10
 PPS NBR - 1-77325-0000
 County Name - WILL - -
 Code - 197 - -
 District - 1 - -
 Section Number - 99 (1 & 2) RS-11

Project Number

Route
 FAI 55

* REVISED : FEBRUARY 23, 2010

Item Number	Pay Item Description	Unit of Measure	Quantity	x	Unit Price	=	Total Price
* DELETED							
20201006	GRADING & SHAP SHLDS	UNIT	1,550.000				
40600200	BIT MATLS PR CT	TON	238.000				
40600300	AGG PR CT	TON	1,190.000				
40600400	MIX CR JTS FLANGEWYS	TON	446.000				
40600826	P LB MM IL-4.75 N50	TON	872.000				
40600895	CONSTRUC TEST STRIP	EACH	2.000				
40600982	HMA SURF REM BUTT JT	SQ YD	787.000				
40601005	HMA REPL OVER PATCH	TON	225.000				
40603085	HMA BC IL-19.0 N70	TON	9,820.000				
40603153	P HMA SC SMA N80	TON	27,868.000				
40603340	HMA SC "D" N70	TON	7,667.000				
44000158	HMA SURF REM 2 1/4	SQ YD	21,128.000				
44000165	HMA SURF REM 4	SQ YD	278,731.000				
44002220	HMA RM OV PATCH 5	SQ YD	803.000				

ILLINOIS DEPARTMENT OF TRANSPORTATION
 SCHEDULE OF PRICES
 CONTRACT
 NUMBER - 60153

State Job # - C-91-060-10
 PPS NBR - 1-77325-0000
 County Name - WILL - -
 Code - 197 - -
 District - 1 - -
 Section Number - 99 (1 & 2) RS-11

Project Number

Route
FAI 55

* REVISED : FEBRUARY 23, 2010

Item Number	Pay Item Description	Unit of Measure	Quantity	x	Unit Price	=	Total Price
44201765	CL D PATCH T2 10	SQ YD	523.000				
44201769	CL D PATCH T3 10	SQ YD	112.000				
44201771	CL D PATCH T4 10	SQ YD	27.000				
48102100	AGG WEDGE SHLD TYPE B	TON	11,089.000				
50102400	CONC REM	CU YD	5.200				
50200100	STRUCTURE EXCAVATION	CU YD	9.000				
50800105	REINFORCEMENT BARS	POUND	2,000.000				
54003000	CONC BOX CUL	CU YD	5.200				
63301215	REM RE-E SPBGR TY B	FOOT	82.000				
64200105	SHOULDER RUMBLE STRIP	FOOT	140,293.000				
67000400	ENGR FIELD OFFICE A	CAL MO	6.000				
67100100	MOBILIZATION	L SUM	1.000				
70106800	CHANGEABLE MESSAGE SN	CAL MO	20.000				
* 70300240	TEMP PVT MK LINE 6	FOOT	225.000				
70301000	WORK ZONE PAVT MK REM	SQ FT	68,754.000				

ILLINOIS DEPARTMENT OF TRANSPORTATION
 SCHEDULE OF PRICES
 CONTRACT
 NUMBER - 60153

State Job # - C-91-060-10
 PPS NBR - 1-77325-0000
 County Name - WILL - -
 Code - 197 - -
 District - 1 - -
 Section Number - 99 (1 & 2) RS-11

Project Number

Route
 FAI 55

* REVISED : FEBRUARY 23, 2010

Item Number	Pay Item Description	Unit of Measure	Quantity	x	Unit Price	=	Total Price
* 70400100	TEMP CONC BARRIER	FOOT	400.000				
* DELETED							
78000200	THPL PVT MK LINE 4	FOOT	146,693.000				
78000400	THPL PVT MK LINE 6	FOOT	763.000				
78000500	THPL PVT MK LINE 8	FOOT	7,800.000				
78000600	THPL PVT MK LINE 12	FOOT	3,478.000				
78000650	THPL PVT MK LINE 24	FOOT	135.000				
78004220	PREF PL PM TB INL L5	FOOT	17,536.000				
78100100	RAISED REFL PAVT MKR	EACH	1,758.000				
* 78200530	BAR WALL MKR TYPE C	EACH	32.000				
78300200	RAISED REF PVT MK REM	EACH	1,406.000				
* 81018500	CON P 2 GALVS	FOOT	625.000				
* 81400200	HD HANDHOLE	EACH	8.000				
* 81900200	TR & BKFIL F ELECT WK	FOOT	200.000				

HOT-MIX ASPHALT - DENSITY TESTING OF LONGITUDINAL JOINTS (BDE)	64
HOT-MIX ASPHALT – DROP-OFFS (BDE)	65
HOT-MIX ASPHALT – PLANT TEST FREQUENCY (BDE)	66
HOT-MIX ASPHALT – QC/QA ACCEPTANCE CRITERIA (BDE)	67
HOT-MIX ASPHALT – TRANSPORTATION (BDE)	67
IMPACT ATTENUATORS, TEMPORARY (BDE)	68
LIQUIDATED DAMAGES (BDE).....	69
METAL HARDWARE CAST INTO CONCRETE (BDE).....	70
MONTHLY EMPLOYMENT REPORT (BDE)	70
MULTILANE PAVEMENT PATCHING (BDE).....	71
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM / EROSION AND SEDIMENT CONTROL DEFICIENCY DEDUCTION (BDE)	72
NIGHTTIME WORK ZONE LIGHTING (BDE)	73
PARTIAL EXIT RAMP CLOSURE FOR FREEWAY/EXPRESSWAY (BDE)	74
PAVEMENT PATCHING (BDE).....	75
PAYMENTS TO SUBCONTRACTORS (BDE)	75
PERSONAL PROTECTIVE EQUIPMENT (BDE)	76
POLYUREA PAVEMENT MARKING (BDE).....	76
PORTLAND CEMENT CONCRETE PLANTS (BDE)	83
RAISED REFLECTIVE PAVEMENT MARKERS (BDE).....	84
RAMP CLOSURE FOR FREEWAY/EXPRESSWAY (BDE).....	84
REFLECTIVE SHEETING ON CHANNELIZING DEVICES (BDE)	85
REINFORCEMENT BARS - STORAGE AND PROTECTION (BDE).....	86
SUBCONTRACTOR MOBILIZATION PAYMENTS (BDE)	86
SURFACE TESTING OF PAVEMENTS (BDE)	86
THERMOPLASTIC PAVEMENT MARKINGS (BDE)	92
TRUCK MOUNTED/TRAILER MOUNTED ATTENUATORS (BDE)	94
BITUMINOUS MATERIALS COST ADJUSTMENTS (BDE) (RETURN FORM WITH BID)	94
FUEL COST ADJUSTMENT (BDE) (RETURN FORM WITH BID)	97
STEEL COST ADJUSTMENT (BDE) (RETURN FORM WITH BID)	101
INDUCTION LOOP	105
GALVANIZED STEEL CONDUIT	109
POLYETHYLENE DUCT.....	115
HANDHOLE	117
TRENCH AND BACKFILL.....	118
CONTROL OF TRAFFIC SURVEILLANCE MATERIALS	120

Revised 02/23/2010

TSC T418#1

INDUCTION LOOP

Effective: June 1, 1994

Revised: Oct. 2, 2009

1. DESCRIPTION

This item shall consist of furnishing, installing and testing an induction loop, of the dimensions shown on the plans or of the dimension from Table 1, at the locations shown. The induction loop shall be installed in accordance with all details shown on the plans and applicable portions of Section.886 Standard Specifications for Road and Bridge Construction. All sawcutting, cable installation, joint sealing, lead-ins and testing necessary to complete the installation shall conform with the following requirements.

2. MATERIALS

The cable used for induction loop shall be #14-7 strand XHHW XLP-600V, encased in orange Detecta-duct tubing as manufactured by Kris-Tech Wire Company, Inc., or comparable. All loop wire shall be UL listed. Lead-ins shall be Conoga 30003 or equal cable. The jacket, constructed of high density polyethylene, shall be rated to 600 volts in accordance with UL 83 Section 36.

Joint sealer shall have sufficient strength and resiliency to withstand stresses set up by vibrations and differences in expansion and contraction due to temperature changes. The joint sealer shall have a minimum tensile strength of 100 P.I.E. when tested by ASTM Method D638-58T. Adhesion to clean dry, oil-free Portland Cement concrete shall be at least equal to the tensile strength of the concrete. The joint sealer, with qualities described above, shall be capable of curing in a maximum time of 30 minutes at all temperatures above 50 degrees F (10 degrees C). Curing shall be defined as the capability of withstanding normal traffic loads without degradation. A hard asphalt-based filling and insulating compound having a high softening point and a high pouring temperature shall be used if the outside installation temperature is below 50 degrees F (10 degrees C). The filling compound shall have a softening point of not less than 235 degrees F (110 degrees C) and a summer pouring temperature of 375 degrees F (190 degrees C); winter pouring temperature of 425 degrees F (220 degrees C). Sealant for Detector Loop(s): The sealer shall meet or exceed the characteristics provided by OZ GEDNEY DOZSeal 230 filling compound.

3. INSTALLATION DETAILS

Slots in the pavement shall be cut with a concrete sawing machine in accordance with the applicable portions of Art. 420.05 of the Standard Specifications for Road and Bridge Construction. The slot must be clean, dry, and oil-free. Wire shall be inserted in the pavement slot with a blunt tool which will not damage the insulation. Loops shall not be dry cut. Loops should not be installed at an outside temperature below 50 degrees F (10 degrees C) unless directed by Engineer.

Plastic sleeving shall be used to insulate the wire where loop wire crosses cracks and joints in the pavement. The sleeving shall be properly sealed with electrical tape to prevent joint sealer from entering sleeves. Sleeving shall extend a minimum of 8 inch (20 cm) each side of joint.

Added 02/23/2010

Induction loops on exit and entrance ramps shall be square or rectangular with edges perpendicular or parallel to traffic flow. All mainline loops shall be round loops, 6 feet (1.8 m.) in diameter. Induction loops shall be centered on all ramps and in traffic lanes unless designated otherwise on the plans or by the Engineer. Traffic lanes shall be referred to by number and loop wire shall be color-coded and labeled accordingly. Lane one shall be the lane adjacent to the median, or that lane on the extreme left in the direction of the traffic flow; subsequent lanes are to be coded sequentially towards the outside shoulder. A chart which shows the coding for each installation shall be included in each cabinet. Core holes shall not be allowed at corner of loop. Sawcuts for all induction loops and lead-ins shall not be greater than 2.75 inches (7 cm) in depth.

All excess joint sealer shall be removed so that the level of the sealer in the sawcut is at the same level as the adjoining pavement.

All induction loops shall contain three (3) turns of No. 14 wire min. Each induction loop shall have its own Canoga 30003 or equal home run or lead-in to the cabinet when said induction loops is over 150 feet (45 m) from cabinet. Induction loops shall not be connected in series with other loops. This wire shall be free from kinks or any insulation abrasions. The loop lead-in shall be a Canoga 30003 cable. The loop lead-in shall be barrel sleeved, crimped, soldered and protected by heat shrinkable tubing to the loop #14 wire. Lead-ins shall be twisted in such a manner so as to prevent mechanical movement between the individual cables. Lead-ins shall be brought into a cabinet or handhole at the time the induction loop is placed in the pavement. Loops located over 1000 feet (300m) from cabinet require four (4) turns of No. 14 wire.

Where lead in runs are less than 150 feet (45 meters) the loop wire will be utilized as lead in to the point of termination w/o splices, being twisted 16 turns per meter (5 turns per foot). The loop wire will be paid for as "lead in" from last point of sawcut in pavement at dive hole to point of termination.

Where duct is collapsed or damaged, making it impossible to pull loop lead-in, the affected area will need to be replaced. This will be paid for by the pay items CONDUIT IN TRENCH, HIGH DENSITY POLYETHYLENE COILABLE 1-1/4" and TRENCH AND BACKFILL FOR ELECTRICAL WORK.

Loop lead-ins placed in handholes shall be coiled, taped and hung from the side of the handhole to protect against water damage. Any other method of installation will require prior written approval of the Engineer. Each loop lead-in shall be color coded and tagged in each handhole thru which it passes. The loop lead-in shall be color coded and tagged at the core hole, in each junction box it passes thru, and at the termination point in the cabinet.

Contractor shall core drill all mainline round loops 6 feet (183 meters) in diameter x .25 inch (6 mm) in width x 2.75 inches (7 cm) in depth.

Loop lead-ins shall not be allowed in saw cuts in shoulders. The Engineer shall be contacted regarding proposed changes in loop locations necessitated by badly deteriorated pavement. The Engineer may relocate such loops. Loop Wire and lead-ins shall not be installed in the curb and gutter section or through the edge of pavement. A hole shall be drilled at least 12 inches (30 cm) in from the edge of pavement through which the P-duct, loop wire and lead-in shall be installed. Saw cuts through shoulders to core hole shall not be allowed.

Added 02/23/2010

W (M)	S (M)
13 ft (4.0 m)	9 ft (2.8 m)
14 ft (4.3 m)	10 ft (3.1 m)
15 ft (4.6 m)	11 ft (3.4 m)
16 ft (4.9 m)	12 ft (3.7 m)
17 ft (5.2 m)	13ft (4.0 m)
18 ft (5.5 m)	14ft (4.3 m)
19 ft (5.8 m)	15 ft (4.6 m)
20 ft (6.1 m)	16 ft (4.9 m)
21 ft (6.4 m)	17 ft(5.2 m)
22 ft (6.7 m)	18 ft (5.5 m)
23 ft (7.0 m)	19 ft (5.8 m)
24 ft (7.3 m)	20 ft (6.1 m)
25 ft (7.6 m)	21 ft (6.4 m)

Should the induction loop and/or core hole for the induction loop and loop lead-in cable be paved over by other construction operations, it shall be the contractor's responsibility for locating and finding the induction loop and/or the core hole for the repair of a bad loop or lead-in or for the installation of a new loop or loop lead-in. The locating of the core hole and the induction loop shall be incidental to the cost of the induction loop lead-in installation.

No extra compensation shall be allowed for finding and locating induction loops and/or core hole.

The loop shall be spliced to the lead-in wire with a barrel sleeve crimped and soldered. Epoxy filled heat shrink tubing shall be used to protect the splice. The soldered connection shall be made with a soldering iron or soldering gun. No other method will be acceptable, i.e. the use of a torch to solder will not be acceptable. The heat shrink tube shall be shrunk with a heat gun. Any other method will not be acceptable, i.e. the use of a torch will not be acceptable. No burrs shall be left on the wire when done soldering. Cold solder joints will not be acceptable. Refer to T.S.C. typical(s) TY-1TSC-418 #2 & #3 for proper loop to loop lead-in splice detail.

Where there are continuous count stations or multiple lane exits or entrance ramps the loop in the left most lane shall be wrapped clockwise, the adjacent lane loop wrapped counter-clockwise, etc, alternating wrapping the loops every other lane.

4. TRAFFIC SYSTEMS CENTER LOOP SPLICING REQUIREMENT COLOR CODE

<u>MAINLINE LOOPS</u>				<u>METERING LOOPS</u>	
Lane 1	Blue	Lane 4	Violet	Loop 1	Green
Lane 2	Brown	Exit	Black	Loop 2	Yellow
Lane 3	Orange	Entrance	White	Loop 3	Red

When 2 or 3 loops are installed on an exit or entrance ramp the loop color code shall conform to the mainline loop color code and shall be marked as entrance or exit ramp loops.

Added 02/23/2010

In addition to color codes each loop shall be identified with a written label attached to the loop wire, or lead-in wire. The tags shall be Panduit #MP250W175-C or equivalent. All wires and cables shall be identified in each handhole or cabinet that the cable passes through, or terminates in. The labels shall be attached to the cable by use of two cable ties.

5. PROSECUTION OF SURVEILLANCE WORK

The work shall consist of replacement and/or repairs caused by the pavement repair, removal and resurfacing to all induction loops, loop lead-in, poly-duct, steel conduits, all interconnecting cables and all Surveillance appurtenances. The Contractor shall make modifications to existing installations to render the location functional. The Contractor shall also furnish and install new induction loops, loop lead-ins, poly-duct, steel conduits, all interconnecting cables, and all Surveillance appurtenances.

Should damage occur to any Traffic Systems Center cabinets, housing telemetry equipment and/or vehicle detection equipment, the Contractor shall install and replace all damaged equipment at his own expense. The Traffic Systems Center staff shall determine what equipment shall be reusable and what shall be replaced. Replaced equipment shall be of equal or better quality and type.

6. CONNECTIONS TO EXISTING INSTALLATIONS

Where new work connects to existing installations, the Contractor shall do all necessary cutting, fitting and foundation drilling to the existing installation. The Contractor shall remove all existing equipment, as required to make satisfactory connections, so as to leave the entire work in a finished and workmanlike manner, as approved by the Engineer. No raceways shall be allowed to enter cabinet through the sides or backwalls.

7. PROTECTION OF WORK

Electrical work, equipment and appurtenances shall be protected from damage during construction until final acceptance. Electrical raceway or duct openings, shall be capped or sealed from the entrance of water and dirt. Wiring shall be protected from mechanical injury.

8. STANDARDS OF INSTALLATION

Electrical work shall be installed in a neat and workmanlike manner in accordance with the best practices of the trade. Unless otherwise indicated, materials and equipment shall be new and installed in accordance with the manufacturer's recommendations.

Except as specified elsewhere herein, materials and equipment shall be in conformance with the requirements of Section 106 of the Standard Specifications.

9. TESTING

Before final acceptance, the induction loops shall be tested. Tests will not be made progressively, as parts of the work are completed. They shall be all made at one time. Items which fail to test satisfactorily shall be repaired or replaced.

An electronic test instrument capable of measuring large values of electrical resistance, such as major megger, shall be used to measure the resistance of the induction loop and its lead-in.

Added 02/23/2010

The resistance of the loop and its lead-in shall be a minimum of 100 meg ohms above ground under any conditions of weather or moisture. The resistance tests and all electronic tests shall be performed in the presence of the Engineer any number of times specified by the Engineer. The loop and loop lead-in shall have an inductance between 100 micro henries and 700 micro henries. The continuity test of the loop and loop lead-in shall not have a resistance greater than two (2) ohms. The Contractor shall do all testing in the presence of the Engineer and all readings will be recorded by the Engineer. Testing shall be done with an approved loop tester.

10. FINAL ACCEPTANCE INSPECTION

When the work is complete, tested and fully operational, the Contractor shall schedule a Final Acceptance Inspection with the Engineer. Final acceptance will be made as a total system, not as parts.

The Contractor shall furnish the necessary manpower and equipment to make the Final Acceptance Inspection. The Engineer will designate the type of equipment required for the inspection tests.

11. METHOD OF MEASUREMENT

The induction loop measurement shall be the length of sawcut in the pavement which contain loop wire. The actual length of wire used in the sawcut shall not be considered in any measurement.

12. BASIS OF PAYMENT

This item will be paid at the contract unit price per lineal foot (meter) as **INDUCTION LOOP** for furnishing and installing all materials listed complete and operating in place. If loop is less than 150 ft. from cabinet, loop wire shall be used as lead-in and paid for at the contract unit price per lineal foot (meter) as **ELECTRIC CABLE IN CONDUIT NO. 14, 1 PR.** If loop is greater than 150 ft. from cabinet, loop wire shall be spliced in handhole to a **4C #18 TWISTED SHIELDED CABLE.**

TSC T420#1

GALVANIZED STEEL CONDUIT

Effective: June 1, 1994

Revised: November 12, 2008

1. DESCRIPTION:

This item shall consist of furnishing and installing galvanized steel conduit, fittings and accessories as specified herein and as shown on the contract drawings, either attached to structure, laid in trench, or pushed in place. The galvanized steel conduit shall conform to the requirements of applicable portions of Art. 810, 811 & 1088.01 of the Standard Specifications, and Section 1E-663#11 of the Recurring Special Provisions for Roadway Lighting (12/1992), except where more stringent requirements are specified herein.

2. MATERIALS:

2.1 GENERAL

Added 02/23/2010

- 2.1.1 Rigid steel conduit shall be manufactured in accordance with U.L. Standard 6 and shall be UL listed and labeled.
- 2.1.2 Rigid steel conduit shall meet Federal Specification WWC-581, ANSI Standard C80.1, and the requirements of NEC Article 344.
- 2.1.3 The conduit, after fabrication, shall be thoroughly cleaned and the inside and outside surfaces shall be galvanized.
- 2.1.4 Couplings and fittings shall meet ANSI Standard C80.4 and shall be hot-dip galvanized. Elbows and nipples shall conform to the specifications for conduit. The cost of fittings, couplings, elbows, nipples and other such conduit appurtenances shall be included in the bid unit price for conduit. All fittings and couplings for rigid conduit shall be of the threaded type.

2.2 PVC Coated Conduit

- 2.2.1 PVC coated conduit shall be manufactured in conformance to NEMA Standard No. RN1-1986.

- 2.2.2 The PVC coating shall have the following characteristics:

Hardness: 85+ Shore A Durometer

Dielectric Strength: 400V/mil @ 60 Hz

Aging: 1000 Hours Atlas Weatherometer

Temperature: The PVC compound shall conform at -18 ° C (0 degrees F) to Federal Specifications PL-406b, Method 2051. Amendment 1 of 25 September 1952 (ASTMD-746)

Elongation: 200%

- 2.2.3 The exterior galvanized surfaces shall be coated with a primer before PVC coating to ensure a bond between the zinc substrate and the PVC coating. The bond strength created shall be greater than the tensile strength of the plastic coating. The nominal thickness of the PVC coating shall be 40 mils. The PVC shall pass the following bonding test:

Two parallel cuts ½ inch (12mm) apart and 1-1/2 inches (38mm) in length shall be made with a sharp knife along the longitudinal axis. A third cut shall be made perpendicular to and crossing the longitudinal cuts at one end. The knife shall then be worked under the PVC coating for ½ inch (1/2") to free the coating from the metal. Using pliers, the freed PVC tab shall be pulled with a force applied vertically and away from the conduit. The PVC tab shall tear rather than any additional PVC coating separating from the substrate.

- 2.2.4 A two part urethane coating shall be applied to the interior of the conduit. The internal coating shall have a nominal thickness of 2 mils. The interior coating shall be applied in a manner so that there are no runs, drips, or pinholes at any point. The coating shall not peel, flake or chip off after a cut is made in the conduit or a scratch is made in the coating. The urethane interior coating applied shall afford sufficient flexibility to permit field bending without cracking or flaking of the interior coating.

Added 02/23/2010

- 2.2.5 All conduit fitting covers shall be furnished with stainless steel screws which have been encapsulated with a polyester material on the head to ensure maximum corrosion protection.

2.3 Liquid-Tight Metal Flexible Conduit

- 2.3.1 Liquid-tight flexible metal conduit shall be manufactured to the requirements of UL 360 and be UL Listed.
- 2.3.2 The conduit shall have a temperature range of. -4 degrees F to plus 140 degrees F (-20 degrees C to + 60 degrees C)
- 2.3.3 The thermoplastic covering shall be oil resistant.
- 2.3.4 Conduit from 3/8" (9.5mm) diameter to 1-1/4" (30mm) diameter shall have an integral copper ground wire.

3. INSTALLATION

3.1 General

- 3.1.1 Galvanized steel conduit shall be installed in conformance with the requirements of NEC Article 344 except where more stringent requirements are specified herein.
- 3.1.2 The ends of the conduit shall be cut square and thoroughly reamed before installation. All burrs and rough edges shall be removed.
- 3.1.3 Bends shall be made with a standard pipe bender. Bends shall be so made that the conduit will not be injured and that the internal diameter of the conduit will not be effectively reduced. The radius of the curve shall not be less than that shown on Table 344.24 of the National Electric Code and where larger radii are specified or shown on the Plans, the larger radii shall be used.
- 3.1.4 Conduit joints shall be threaded. All joints before assembly and exposed threads after assembly shall be coated with low resistance, conductive, joint compound. Running threads in conduits runs will not be permitted. Care shall be used to assure that conduits are not over-threaded. Threading shall be in accordance with the requirements of NEC Article 344.28. The protective coatings on all threads must be sufficient to prevent corrosion before installation is made. If threads become corroded before installation, the material shall be replaced with new material or the corroded parts must be thoroughly cleaned and recoated as directed by the Engineer.
- 3.1.5 Whenever possible, conduits shall be installed so as to drain to the nearest opening, box or fitting.

Added 02/23/2010

- 3.1.6 Ends of conduits shall be equipped with insulating bushings. Rigid steel conduits terminating in the base of lighting controllers, pedestal bases, transformer bases and other open enclosures shall be equipped with insulating bushings with ground lugs which shall be used to bond the conduits to the enclosure via a copper ground conductor.
- 3.1.7 Unless otherwise indicated, conduits terminating at cast or malleable iron boxes, or in sheet steel boxes below grade shall be terminated in conduit hubs. Hubs may be integral to the box or may be installed separately. Non-integral hubs or integral hubs which do not provide a flared, smooth entry shall be used where conductors are No. 4 or larger, in compliance with NEC Article 312.6(c), and in these cases two locknuts and an insulating bushing shall be used.
- 3.1.8 Threaded conduits terminating at sheet metal boxes or enclosures above grade, or where bushings cannot be brought into firm contact with the box or enclosure or where insulating bushings are required by the NEC, shall terminate with two locknuts and an insulating bushing. Conduit bushings constructed wholly of an insulating material shall not be used to secure a raceway.
- 3.1.9 Conduit connections shall be made tight to assure good ground continuity.
- 3.1.10 Expansion fittings, as specified herein, shall be installed in all raceway runs crossing structural expansion joints. Unless otherwise indicated or approved by the Engineer, expansion fittings shall include a 8 inch (20cm) expansion fitting with a bonding jumper plus a deflection fitting allowing not less than a $\frac{3}{4}$ inch (2cm) deflection in any direction. Bonding jumpers for conduit attached to structure shall be external type. The drawings shall be examined to determine complete extent of expansion joints.
- 3.1.11 Fasteners used to mount conduit supports, and other associated items attached to the structure shall be suitable for the weight supported and shall be compatible with the structure material, i.e. wood screws shall be used for wood, toggle bolts shall be used for hollow masonry, expansion bolts or power-set studs shall be used for solid masonry or concrete and clamps shall be used for structural steel. Expansion anchors shall not be less than $\frac{1}{4}$ inch (6mm) trade size and shall extend at least 2 inches (50mm) into the masonry or concrete. Power-set anchors shall not be less than $\frac{1}{4}$ inch (6mm) trade size and they shall extend at least 1-1/4 inches (30.0mm) into masonry or concrete.
- 3.1.12 Raceways shall be protected from mechanical and corrosion damage during construction. Open ends shall be capped or fitted with plugs. Before cables are installed, raceways shall be cleared of all obstruction, moisture and burrs or rough edges. Conduits which have had mud, dirt or water inside shall be cleaned with a dry swab.

Added 02/23/2010

3.2 Conduit Pushed

- 3.2.1 Conduit which is pushed in place shall be installed in a manner so that it will not be less than 2.5 feet (75cm) below finished grade.
- 3.2.2 Unless otherwise required, pushed conduit shall extend 2 feet (60cm) beyond the shoulder, curb and/or guardrail, as applicable. If auguring is required to facilitate the push installation, the auguring shall be done at no additional cost to the State.
- 3.2.3 Immediately following the conduit push, the conduit shall be rodded and swabbed to remove all dirt and other foreign materials and it shall be capped until conductors are installed.

3.3 Conduit Attached to Structure

- 3.3.1 Unless otherwise indicated or specified, surface-mounted conduits shall be held in place by one-hole clamps and clamp backs. Conduits which are mounted to steel beams or columns shall be held in place by suitable beam clamps. Clamps, clamp backs and beam clamps shall be stainless steel.
- 3.3.2 Unless otherwise indicated, raceways suspended from the structure shall be supported by trapeze or other hangers approved by the Engineer. Trapeze hangers shall be hot-dip galvanized steel channels or angle irons with conduits held in place by heavy-duty stainless steel U-bolts, nuts and lock washers. Trapeze hangers shall be hung using threaded stainless steel rods not less than 3/8 inch (9 mm) diameter and appropriate anchors or by other means approved by the Engineer.

Table 3.1
 MAXIMUM DISTANCE

CONDUIT DIAMETER BETWEEN RIGID METAL
CONDUIT SUPPORTS

(inch)	mm	(feet)	M
1/2-3/4	12.7-19	1.5	1.52
1	25	6	1.8
1-1/4 - 1-1/2	30-38	7	2.1
2-2 1/2	50-62	8	2.4
	75 and larger	10	3

Conduit Support

- 3.3.3 Raceway supports shall be as specified in Article 344.30 of the NEC, with a support within 3 feet (1 meter) of each cabinet, box or fitting except the maximum distance between supports shall be as indicated in table 3.1. The listed exceptions in NEC Article 341-12 shall not apply.

Added 02/23/2010

3.4 PVC Coated Conduit Attached to Structure

In addition to the methods described in section 3.3, the following methods shall be observed when installing PVC coated conduit.

- 3.4.1 PVC coated conduit pipe vise jaw adapters shall be used when the conduit is being clamped to avoid damaging the PVC coating.
- 3.4.2 PVC coated conduit should be cut with a roller cutter or by other means as approved by the conduit manufacturer.
- 3.4.3 After any cutting or threading operations are completed, the bare steel shall be touched up with the conduit manufacturer's touch up compound.

3.5 Liquid-Tight Flexible Conduit

In addition to the methods described in section 3.3 the following methods shall be observed when installing liquid-tight flexible conduit.

- 3.5.1 Conduit shall be installed in accordance with NEC Article 350.
- 3.5.2 Liquid-tight conduit shall not exceed 36 inches (1 meter) in length.
- 3.5.3 Fittings designed for use with liquid-tight flexible conduit shall be used at all connections.
- 3.5.4 Flexible conduit shall not be used as a substitute for the bending of rigid conduit. Flexible conduit should only be used where movement of the conduit is anticipated or as indicated on the plans.

4. METHOD OF MEASUREMENT:

Conduit shall be measured for payment in linear feet (meters) in place. Measurement shall be made in straight lines along the centerline of the conduit between ends and changes in direction. Vertical conduit shall be measured for payment. Liquid-tight flexible metal conduit shall not be measured for payment, but shall be included in the bid price for conduit attached to structure regardless of size or type.

5. BASIS OF PAYMENT:

This item shall be paid for at the contract unit price per linear meter (foot) for CONDUIT IN TRENCH, GALVANIZED STEEL, CONDUIT PUSHED, GALVANIZED STEEL, or, CONDUIT ATTACHED TO STRUCTURE, GALVANIZED STEEL, or, CONDUIT ATTACHED TO STRUCTURE, GALVANIZED STEEL, PVC COATED, of the diameter indicated which shall be payment in full for the work as described herein.

Added 02/23/2010

TSC T420#2
POLYETHYLENE DUCT
 Effective: June 1, 1994

Revised: May 12, 2008

DESCRIPTION

This item shall consist of furnishing and installing polyethylene duct of the type and size specified including all couplings, junctions, adapters, reducers, condulets and all incidental items necessary to complete the work at the locations indicated on the plans or directed by the Engineer in accordance with the following requirements.

MATERIALS

The flexible electrical plastic duct shall be manufactured to comply with the American Society for Testing and Materials Standards (latest edition) cited by ASTM Designation D 3485, and to the standards of NEMA Publication No. TC-7.

The duct shall be manufactured from black polyethylene complying with ASTM Designation D1248, Type III, Grade 3, Class C with the following exceptions and additions:

1. The Elongation when tested by the procedure in ASTM Designation D-638 shall be a minimum of 300%.
2. The Brittle Temperature when tested by Procedure A in ASTM Designation D-746 shall be -94 degrees F. (-70 degrees C.) or below.
3. The environmental Stress Crack Resistance when tested in accordance with ASTM Designation D-1693 shall produce not more than 2 failures per 10 specimens after 48 hours.

Construction: The duct shall be manufactured as polyethylene plastic pipe complying with ASTM Designation D-2104 with the following exceptions and additions:

1. The Outside Diameter, minimum wall thickness, and bending radius shall be as follows:

Nominal Size Inches/(mm)	Outside Diameter Inches/(mm)	Minimum Wall Thickness Inches/(mm)	Minimum Bending Radius Inches/(mm)
1-1/4"/(30)	1.660 ± 0.012" (42.16 ± 0.305)	0.106 ± 0.020 2.692 ± 0.508	18 inches (450)
2"/(50)	2.375 ± 0.012" 60.33 ± 0.305	0.158 ± 0.020 4.013 ± 0.508	26 in. (650)
3"/(75))	3.500 ± 0.012" (88.90 ± 0.305)	0.226 ± 0.020 5.740 ± 0.508	40in. (1000)

The duct may be manufactured to the dimensions in the above table, for Schedule 40. The duct must be capable of being bent in the minimum bending radius listed above.

Added 02/23/2010

2. When tested in accordance with the procedures and test methods referred to in ASTM Designation D-2104 the test pressures used shall be 75% of the values listed in Tables III, V, VI, VII.

3. The duct shall pass the following tests:

a) Freeze-up test:

A 10 ft (3.0m) length of the duct bent into an upright "U" shape shall be filled with water and then placed in a low temperature cabinet and maintained at -20 degrees C. for twenty-four hours. The duct shall not crack or burst during the test.

b) Compression Test:

The test shall be conducted on three, 6 inch (150.0mm) samples of the duct, using equipment set at 2 in.(50mm)per minute. Samples are placed between 6 in. (150.0 mm) plates and compressed at the rate of 1/2 in. (12.0mm) per minute until the distance between the plates is reduced by 50%, recording the load required to compress the duct. The samples are then removed and allowed to stand for exactly 5 minutes. The load required to compress the sample shall be equal to or greater than that listed below and the duct shall have returned to not less than 85% of its original diameter at the end of the 5 minutes.

Nominal Size In. (mm)	Load lbs (N)
1-1/4"(30.0)	188 lbs (836.26)
2 in. (50.0)	300 lbs (1334.50)
3 in (75.0)	350 lbs (1556.87)

The duct shall be permanently marked at regular intervals on the outside with the manufacturer's name or trademark.

The manufacturer shall certify that these tests were made and the results conform to specifications, using the apparatus and test methods listed above and shall be submitted to the Engineer for approval, prior to installation of duct.

Couplings shall be high density polyethylene or acetyl butyl styrene drive on pipe fittings.

INSTALLATION DETAILS

Polyethylene duct will be installed in a prepared trench at a minimum depth in the ground of 750mm (30 inches). The Contractor shall exercise care in installing the duct to insure that the completed duct raceway is smooth, free of sharp bends and located in such a manner as will preclude damage from subsequent construction operations. Crushed or deformed polyethylene duct shall not be used or accepted. All joints, including those with galvanized steel conduit, shall be watertight.

Duct which passes through cabinet foundations shall have an upper termination approximately 2 inches (50mm) above the top of the foundation.

Added 02/23/2010

Duct terminations shall be temporarily capped to prevent water and other contaminants from entering during construction operations. The duct shall be swabbed and blown clean of any debris before installation of cable. If, in the opinion of the Engineer, water or any other debris is in the duct after the cable is installed the Contractor shall blow the duct clean and make any repair necessary to stop water leaking or debris entering.

Should damage occur to existing or newly installed polyethylene duct, the Contractor shall locate the damaged area and repair damaged area with new polyethylene duct. All repairs will be inspected by the T.S.C. Engineer. The cost of locating the damaged polyethylene duct shall be incidental to the cost of the new polyethylene duct.

Where new P-duct connects to existing installations or foundations the Contractor shall do all necessary cutting, fitting and foundation drilling to the existing installation as required, to make satisfactory connections, with the work to be performed under these Provisions, so as to leave the entire work in a finished and workmanlike manner, as approved by the Engineer. No raceways shall be allowed to enter cabinet through the sides or back walls. All cutting, fitting and foundation drilling shall be incidental to the cost of the polyethylene duct.

METHOD OF MEASUREMENT

The length of measurement shall be the distance along a straight line measured between changes in direction of the polyethylene duct and its connection to terminal structures, galvanized steel conduit or condulets.

BASIS OF PAYMENT

This item will be paid at the contract unit price per lineal foot (meter) of CONDUIT IN TRENCH, HIGH DENSITY POLYETHYLENE, COILABLE, for furnishing the specified size duct in place and connected at its terminal. Trench and backfill will be paid for separately.

TSC T428#1

HANDHOLE

Effective: June 1, 1994

Revised: May 19, 2009

DESCRIPTION

This item shall consist of constructing a handhole, a heavy-duty handhole, or a double handhole, cast in place, complete with frame and cover and in accordance with the following requirements and conforming in all respects to the lines, grades, and dimensions shown on the plans or as directed by the Engineer. All handholes shall be installed in accordance with the Standard Specifications Sec. 814.

MATERIALS

All handholes shall be constructed of Class SI concrete meeting the requirements of the Standard Specifications for Road and Bridge Construction Section 1020.

Added 02/23/2010

CONSTRUCTION DETAILS

Handholes of the type specified shall be constructed in accordance with the details shown on the plans and conform to the following requirements:

1. Concrete: Concrete construction shall be done in accordance with the provisions of Concrete for Structures and Incidental Construction contained in the Standard Specifications for Road and Bridge Construction Sec. 503.
2. Placing Castings: Castings shall be set accurately to the finished elevation so that no subsequent adjustment will be necessary. Castings shall be set flush with a sidewalk or pavement surface. When installed in an earth shoulder away from the pavement edge, the top surface of the casting shall be 1 in. (25.4mm) above the finished surface of the ground.
3. Backfilling: Any backfilling necessary under a pavement, shoulder, sidewalk or within 2 ft. (60 cm) of the pavement edge shall be made with sand or stone screenings.
4. Forming: Forms will be required for the inside face of the handhole wall, and across all trenches leading into the handholes excavation. The ends of conduits leading into the handhole shall fit into a conduit bell which shall fit tightly against the inside form and the concrete shall be carefully placed around it so as to prevent leakage.
5. French Drain: A french drain conforming to the dimensions shown on the plans shall be constructed in the bottom of the handhole excavation.
6. Steel Hooks: Each handhole shall be provided with four galvanized steel hooks of appropriate size, one on each wall of the handhole.
7. Frame and Cover: The outside of the cover shall contain a recessed ring Type "G" for lifting and a legend "IDOT TSC" cast-in.
8. Cleaning: The handhole shall be thoroughly cleaned of any accumulation of silt, debris, or foreign matter of any kind, and shall be free from such accumulations at the time of final inspection.

BASIS OF PAYMENT

This work will be paid for at the contract unit price each for HANDHOLE or HEAVY DUTY HANDHOLE, or CONCRETE HEAVY DUTY HANDHOLE (SPECIAL), as the case may be, for all necessary excavating, backfilling, disposal of surplus material and form work, frame and cover, and furnishing all materials.

TSC T430#1

TRENCH AND BACKFILL

Effective: June 1, 1994

Revised: May 19, 2009

DESCRIPTION

This item shall consist of constructing a trench for the accommodation of the poly-duct or conduit and backfilling it at the locations indicated by the Engineer.

Added 02/23/2010

Included is the furnishing of the backfill material and disposing of surplus materials. All work shall be done in accordance with these specifications and Section 819 of the Standard Specifications.

CONSTRUCTION METHODS

The trench shall be excavated in a manner to prevent cave-ins and to a depth of not less than 30 inch (750mm) below final grade. Excavated material cannot fall back onto the trench. The width of the trench shall be at least 3 inches (75.0mm). Where the duct enters the foundation or rigid steel conduit, the bottom of the trench shall be built up to provide a smooth bed for the duct.

The duct shall be placed in the bottom of the trench after all loose stones have been removed and all protruding stones have been removed or covered with backfill material as directed by the Engineer.

If the trench is for an electrical power line, a cable marker shall be installed 12 inch (30 cm) below finished grade. The marker shall be a 6 inches (15 cm) wide (match trench width for smaller trenches) reinforced metallic detection tape consisting of a reinforced polyethylene tape with a metallic core. The tape shall be red with black lettering to read "CAUTION-ELECTRICAL LINE BURIED BELOW". The tape shall have a thickness of not less than 8 mils. The tensile strength of a 3 inch (75.0mm) wide specimen shall be a minimum of 600 lbs.(2669 N). Splicing of the tape shall be accomplished with metal clips to maintain electrical continuity along the entire length of the tape. In addition to metal clips, all splices must be wrapped with a waterproof adhesive tape to prevent corrosion of the metal core.

The trench shall be backfilled by placing backfill material in uniform layers not exceeding 6 inch (15 cm) in depth (loose measure). The material in each layer shall be thoroughly compacted to a density equal to the existing ground or as approved by the Engineer in such a manner as not to injure the duct.

No stone or rock greater than 1 inch (25mm.) in maximum dimension shall be allowed in any layer or backfill.

No sod, frozen material, or any material which, by decay or otherwise, might cause settlement shall be used as backfill. Deleterious substances, such as coal, lignite, shells, clay lumps, and conglomerate and cemented particles shall not exceed 5 percent by weight in any one sample of backfill material.

Any material excavated from the trench may be used as backfill provided it does not conflict with the above and that the material meets with the approval of the Engineer.

The Engineer will inspect:

1. The trench before the duct or conduit is placed in the trench.
2. The duct in the trench before the first layer of backfill.
3. The trench at any other time during excavation or backfilling.

Trenches under and within 2 ft. (60 cm.) of pavement, curb, gutter, or curb and gutter and other locations indicated by the Engineer shall be filled with sand or stone screenings complying with Articles 1003.01 and 1003.04 of the Standard Specifications.

Added 02/23/2010

Extra compensation shall not be allowed for such sand or stone screenings.

The method and type of equipment to be used in compacting the backfill material shall be approved by the Engineer before any work is started.

All areas and plant material damaged by the installation shall be replaced as follows:

1. Grass Areas: Replace top soil to a depth of 3 inch (8 cm) , re-grade shoulders, ditch slopes, and open areas back to former existing grades. Fertilize, seed and mulch all damaged areas.
2. Sodded Areas: Fertilize and re-sod all damaged areas.
3. Plant Materials: Remove and replace damaged trees, shrubs, and vines with the same varieties that existed prior to the damage.
4. Shoulders Other than Stabilized Shoulders and back slopes: Replace shoulders to original condition and restore edge of back slope to original lines and grades.

All damaged landscape shall be replaced in accordance with Sections 250 through 254 of the Standard Specifications for Road and Bridge Construction.

METHOD OF MEASUREMENT

The length of measurement shall be the distance along a straight line measured between changes in direction of the trench.

BASIS OF PAYMENT

This work will be paid for at the contract unit price per lineal foot (meter) for TRENCH AND BACKFILL FOR ELECTRICAL WORK, for all excavation, cable marker, furnishing and placing all backfill material, and the disposal of surplus excavations. Any boring made for the purpose of placing conduit or cable under sidewalks or driveways shall be paid for at the same contract unit price per lineal foot (meter) and designated as TRENCH AND BACKFILL FOR ELECTRICAL WORK for seeding or sodding the surface of the trench, when and as directed by the Engineer.

TSC T620#1

CONTROL OF TRAFFIC SURVEILLANCE MATERIALS

Effective: June 1, 1994

Revised: May 12, 2008

Control of materials shall meet the requirements of Section 801 of the Standard Specifications, except for the following:

DOCUMENTATION

The Contractor shall submit the following traffic surveillance material documentation for the Engineer's approval.

Added 02/23/2010

The material shall be submitted prior to the delivery of equipment to the job site, or within 30 consecutive calendar days after the contract is awarded, or within 15 consecutive calendar days after the contract is awarded, or within 15 consecutive calendar days after the preconstruction meeting.

(A) One (1) complete set of manufacturer's descriptive literature, drawings, and specifications of the traffic surveillance equipment, handholes, junction box, cable, conduit and all associated items that will be installed on the contract.

(B) Eight (8) complete shop drawings of the cabinets, showing in detail the fabrication, anchor bolts, and reinforcing materials.

(C) Eight (8) copies of a letter listing the manufacturer's name and model numbers of the proposed equipment to be supplied, as noted in Paragraphs (A) and (B) of this Special Provision. The letter will be reviewed by the Traffic Surveillance Engineer to determine whether the equipment to be used is approved. The letters will be stamped as approved or not approved accordingly and returned to the Contractor.

(D) (A), (B), and (C) above shall be stamped with the Contract Number, Permit Number, or Intersection for FAUS projects.

Unless otherwise approved by the Engineer, all of the above items shall be submitted to the Engineer at the same time. Each item shall be properly identified by route, section and contract number. Failure to submit the required information above may result in any request for 120-day delay under Article 801.08 being denied.

ACCEPTANCE

Acceptance of the traffic surveillance equipment by the Department shall be based upon inspection results at the Traffic Surveillance "turn on". If approved, traffic surveillance acceptance shall be verbal at the "turn on" inspection followed by written correspondence from the Engineer. The Contractor shall be responsible for all traffic surveillance equipment and associated maintenance thereof until Departmental acceptance is granted.

At or prior to the "Turn On" inspection of the traffic surveillance installation, the Contractor shall provide the Traffic Surveillance Inspector with one(1) copy of the letter described in Paragraph (C) above. In addition, the Contractor shall provide the Engineer with one (1) copy of the operation and service manuals of the associated equipment and five (5) copies of the cabinet wiring diagrams and cable log and location diagram. If these items are not delivered, the traffic surveillance installation(s) will not be placed in operation.

All cost of work and materials required to comply with the above requirements shall be included in the pay item bid prices, under which the subject materials and surveillance equipment are paid, and no additional compensation will be allowed. Materials and equipment not complying with the above requirements will be subject to removal and disposal at the Contractor's expense.

Added 02/23/2010