

## GENERAL NOTES

All structural steel shall conform to AASHTO Classification M-270 Gr. 36, unless otherwise noted.

Fasteners shall be high strength bolts. Bolts  $^{7}_{8}$  "\$\phi\$, open holes  $^{15}_{16}$  "\$\phi\$, unless otherwise noted.

The Contractor shall provide support and/or shoring systems for the slab and beam in the area of existing beam removal. See Special Provisions "Temporary Shoring and Cribbing" and "Temporary Slab Support System."

After the new beam is in its final position and/or beam straightening operations have been completed, the Engineer in the field shall check to see that the top flange is tight against the slab. If not, the Contractor shall inject epoxy between the existing concrete deck and the top flange of the beam. See Special Provision "Epoxy Injection".

Plan dimensions and details relative to existing plans are subject to nominal construction variations. The Contractor shall field verify existing dimensions and details affecting new construction and make necessary approved adjustments prior to construction or ordering of materials. Such variations shall not be cause for additional compensation for a change in scope of the work, however, the Contractor will be paid for the quantity actually furnished at the unit price bid for the work.

Cost of removal and re-installation of all members necessary to complete the work as detailed on the plans and as specified in the Special Provisions shall be included with Furnishing and Erecting Structural Steel.

The existing structural steel coating contains lead. The Contractor shall take appropriate precautions to deal with the presence of lead on this project.

Existing structural steel that will be in contact with new structural steel shall be cleaned and painted prior to erection as required by the Special Provision "Cleaning and Painting Contact Surface Areas of Existing Steel Structures", and "Cleaning and Painting New Metal Structures". The color of the final finish coat shall be Interstate Green, Munsell No. 7.5G 4/8. Cost included with Furnishing and Erecting Structural Steel.

Diaphragm connection holes shall be  $^{15}_{16}$  " $\phi$  for  $^{3}_{4}$ " $\phi$  bolts. Two hardened washers shall be required at diaphragm connections.

Load carrying components designated "NTR" shall conform to the Supplemental Requirements for Notch Toughness, Zone 2.

The Inorganic Zinc Rich Primer / Acrylic / Acrylic Paint System shall be used for shop and field painting of new structural steel except where otherwise noted. The color of the final finish coat shall be Interstate Green, Munsell No. 7.5G 4/8. See Special Provision "Cleaning and Painting New Metal Structures".

The Contractor is responsible for the method of supporting the portion of existing girder to be removed prior to, during cutting and removal operations, and shall ensure that cuts made are smooth and straight.

## TOTAL BILL OF MATERIAL

ITEM	UNIT	QUANTITY	
Furnishing and Erecting Structural Steel	Pound	11,920	
Structural Steel Removal	Pound	11,920	
Temporary Slab Support System	L.S.	1	
Beam Straightening	L.S.	1	
Temporary Shoring and Cribbing	L.S.	1	
Overhead Sign Structure -Bridge Mounted	Foot	16.5	

## PLAN AND ELEVATION SN 060-0046

SHEET NO. 1	F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
8 SHEETS	270	60 B-I-3, 60-1B-I-3, 60-(1,2,3)RS-1, 60-(2HBY,	Madison	12	5
	2VHBY,3HBY-1,3VHBY,3VBY)	CONTRACT	NO. 7	'6D30	
	FED. ROAD DIST. NO.   ILLINOIS   FED. AID PROJECT				

CHECKED AUGUSTUME

DRAWN

DRAWN

CHECKED AT H

GUE

EXAMINED

ENGINEER OF STRUCTURES

ENGINEER OF BRIDGES AND ST

January 21, 2010



Expires: November 30, 2010

SLT-98-001-09