

LEGEND PLATE SCHEDULE	
DEVICE	LABEL
SERVICE DISCONNECT FOR VAULT (LOCATED INSIDE VAULT)	SERVICE DISCONNECT FOR VAULT AND HANGARS 120/240VAC, 1PH, 3W
VAULT PANELBOARD/LOAD CENTER	VAULT PANEL 120/240 VAC, 1 PH, 3W FED FROM SERVICE DISCONNECT
RUNWAY 18-36 CCR	RUNWAY 18-36
RUNWAY 13-31 CCR	RUNWAY 13-31 AND TAXIWAY
CUTOUT ENCLOSURE FOR RUNWAY 18-36	RUNWAY 18-36 CUTOUT
EACH CUTOUT ENCLOSURE (2 LEGEND PLATES)	CAUTION OPERATE CUTOUTS WITH CCR SHUT OFF
CUTOUT ENCLOSURE FOR RUNWAY 13-31 AND TAXIWAY	RUNWAY 13-31 AND TAXIWAY CUTOUT
EACH CUTOUT INPUT SIDE CONNECTION (2 LEGEND PLATES)	INPUT
EACH CUTOUT OUTPUT SIDE CONNECTION (2 LEGEND PLATES)	OUTPUT
CONTROL PANEL FOR AIRFIELD LIGHTING AND NAVAIDS	CONTACTOR PANEL FOR AIRFIELD LIGHTING AND NAVAIDS
CONTROL PANEL FOR AIRFIELD LIGHTING AND NAVAIDS	NOTICE CONTACTORS HAVE REMOTE LOCATED CONTROLS AND MAY ACTIVATE AT ANY TIME
LOW VOLTAGE WIREWAY (PROVIDE 2 LEGEND PLATES 1/2" HIGH BLACK LETTERS WHITE BACKGROUND)	LOW VOLTAGE
HIGH VOLTAGE WIREWAY (PROVIDE 2 LEGEND PLATES 1/2" HIGH BLACK LETTERS WHITE BACKGROUND)	HIGH VOLTAGE
VAULT GROUND BUS (PROVIDE 1 LEGEND PLATE 1/2" HIGH WHITE LETTERS GREEN BACKGROUND; INSTALL ABOVE OR BELOW GROUND BUS)	VAULT GROUND BUS
GROUNDING ELECTRODE CONDUCTORS TERMINATED ON VAULT GROUND BUS. (PROVIDE 2 LEGEND PLATES & SECURE TO CONDUCTORS WITH NYLON STRING OR CABLE TIES)	DO NOT DISCONNECT

NOTE: LEGEND PLATES SHALL BE WEATHERPROOF ENGRAVED PLASTIC OR PHENOLIC MATERIAL, 1/4" HIGH BLACK LETTERS ON A WHITE BACKGROUND UNLESS NOTED OTHERWISE. SECURE WITH WEATHERPROOF ADHESIVE AND MACHINE SCREWS. FURNISH ADDITIONAL LEGEND PLATES WHERE REQUIRED BY CODE, FOR ADDITIONAL EQUIPMENT, AS DETAILED HEREIN ON THE PLANS, AND AS NOTED IN THE SPECIAL PROVISION SPECIFICATIONS.

FURNISH & INSTALL A WEATHERPROOF WARNING LABEL FOR EACH SAFETY SWITCH, PANELBOARD, LOAD CENTER, CUTOUT, & CONTROL PANEL TO WARN PERSONS OF POTENTIAL ELECTRIC ARC FLASH HAZARDS, PER THE REQUIREMENTS OF NEC 110.16 "FLASH PROTECTION". LABELS SHALL BE HAZARD COMMUNICATION SYSTEMS, LLC (190 OLD MILFORD RD., BOX 1174, MILFORD, PA 18337, PHONE: 1-877-748-0244) PART NO. H6010-9VWHB7 OR APPROVED EQUAL.



"DANGER - HIGH VOLTAGE KEEP OUT" SIGN

PROVIDE WARNING SIGN ON VAULT EXTERIOR DOORS LABELED "DANGER - HIGH VOLTAGE - KEEP OUT" PER THE REQUIREMENTS OF NEC 110.34 (c). PROVIDE MINIMUM OF 2 SIGNS (ONE ON EACH DOOR TO THE VAULT).



"DANGER - HIGH VOLTAGE" SIGN

FURNISH AND INSTALL "DANGER - HIGH VOLTAGE" LABELS/SIGNS FOR EACH CUTOUT ENCLOSURE, EACH CONSTANT CURRENT REGULATOR, AND THE HIGH VOLTAGE WIREWAY, TO COMPLY WITH FAA AC 150/5340-26B "MAINTENANCE OF AIRPORT VISUAL AID FACILITIES".

NOTES

1. PROVIDE PHENOLIC ENGRAVED LEGEND PLATES FOR EACH CONSTANT CURRENT REGULATOR (EXISTING & NEW) NOTING THE RUNWAY AND/OR TAXIWAY SERVED.
2. EACH PLUG CUTOUT CABINET SHALL BE FURNISHED WITH A PHENOLIC ENGRAVED LEGEND PLATE THAT IDENTIFIES THE RESPECTIVE RUNWAY OR TAXIWAY CIRCUIT OR REGULATOR. INCLUDE AN ADDITIONAL LEGEND PLATE LABELED "CAUTION OPERATE CUTOUTS WITH CCR SHUT OFF".
3. PROVIDE PHENOLIC ENGRAVED LEGEND PLATES FOR THE CUTOUTS TO IDENTIFY THE RESPECTIVE REGULATOR OUTPUT CONNECTION AND THE RESPECTIVE CIRCUIT LOAD CONNECTION.

REVISION		DATE	
MARSHALL COUNTY AIRPORT LACON, ILLINOIS			
Hanson Proj. No. 10A0051		E-607.DWG	
Scale NONE		Date 12/14/12	
LAYOUT	KNL	08/26/10	09/01/10
DRAWN	MLH	09/01/10	03/30/11
REVIEWED	KNL/CAH	03/30/11	
<p>© Copyright Hanson Professional Services Inc. 2013  <b>Hanson Professional Services Inc.</b>          1525 South Sixth Street          Springfield, Illinois 62703-2886          Ph: (217) 788-2450 Fax: (217) 788-2503          www.hanson-inc.com          Offices Nationwide</p>			
PAVE, LIGHT AND MARK 805' EXTENSION		LEGEND PLATE SCHEDULE	
<p><b>35</b></p> <p>35 of 75 sheets</p>			