11/15/2005

FAI ROUTE	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
57	*	CHAMPAIGN	18	15
F.A.I.N.&B.	S.B.I.&D.	PROJECT		

*(10-30HB-2) & (10-31HB)P

CONTRACT NO. 70482

STATE OF ILLINOIS
DEPARTMENT OF PUBLIC WORKS & BUILDINGS
DIVISION OF HIGHWAYS

F.A.I. 57	10-30HB-2 & 10-31HB-1	CHAMPAIGN	20	5

SHEET NO. / SHEETS

GENERAL NOTES

Class X Concrete shall be used throughout.

Coarse aggregate which is to be used in end posts must be absolutely free of chert, flint, taconite, lignite and soft sandstone.

The Concrete floor slab shall be poured in one continous operation between joints and shall be finished in accordance with Article 1019 of the Standard Specifications.

All rivets shall be 7/8" unless noted.

All holes for splices shall be sub-punched 3/4" and reamed to proper size: 7/8" for 7/8" rivets, 1" for 1" rivets.

All rockers, bolsters, bearing plates, lead plates, pedestals and anchor bolts shall be fabricated and set in accordance with Article 512.15 of the Standard Specifications and are included as quantity of structural steel. Est. Wt.: 4,335 lbs.

Anchor bolts shall be set before grading equipment over supports.

All Structural Steel and Metal Handrail shall be inspected by the Illinois Division of Highways before painting.

Welding shall comply with Article 505.5(a) of the Standard Specifications.

The slopewall is to be reinforced with 12 gauge welded wire fabric 6"x6" mesh and weighing not less than 58 lbs. per 100 sq. ft.

Metal Handrail & Structural Steel except the anchor bolts shall receive one shop coat of red lead paint and two field coats of aluminum paint. See Article 506.14 & 16.4 inclusive of the Standard Specifications.

All paint shall be furnished and applied at the Contractor's.

Piles at Abutments shall be proved in accordance with Article 512.9(c) of the Standard Specifications.

Use pipe culvert, Type 2A construction to conform with Articles 542.4, 542.5 and 542.7 of the Standard Specifications.

Headwalls for pipe culvert under West Intersection are to conform with Standard 2051.

All Structural Steel shall conform to the A.S.T.M. Specification A-36.

The Contractor shall drive three test piles, one concrete pile at East Abut. and one concrete pile at West Abut. both in permanent location, and one timber pile near P.2 as directed by the Engineer before ordering the remainder of piles.