

STORM SEWER SCHEDULE							
PIPE NO.	FROM	TO	LENGTH (FT)	DIA. (IN)	TYPE	SLOPE (%)	TRENCH BACKFILL (CU YD)
20R	20-19	20-20	2	15	STORM SEW CL A 2 15	5.00	0.48
20S	20-21	20-1	90	12	STORM SEW CL A 2 12	1.00	11.22
20T	20-22	20-23	10	12	STORM SEW CL A 2 12	1.00	0.75
20U	20-23	20-2	133	24	STORM SEW CL A 2 24	0.25	62.10
20V	20-24	20-25	81	12	STORM SEW CL A 2 12	0.51	7.22
20W	20-25	20-11	68	12	STORM SEW CL A 2 12	0.50	7.70
20X	20-26	20-4	17	12	STORM SEW CL A 2 12	1.00	2.21
20Y	20-27	20-12	120	12	STORM SEW CL A 1 12	1.00	0.00
20Z	20-28	20-12	57	12	STORM SEW CL A 2 12	1.00	13.54
20AA	20-29	20-28	65	12	STORM SEW CL A 1 12	1.02	0.00
20BB	20-30	20-16	146	12	STORM SEW CL A 1 12	1.00	0.00
20CC	EXIST	20-29	4	12	STORM SEW CL A 1 12	5.00	0.00
20DD	20-20	21-11	53	18	STORM SEW CL A 2 18	0.72	34.12
21A	21-11	21-6	96	18	STORM SEW CL A 2 18	0.71	15.01
21B	21-1	21-2	51	12	STORM SEW WM REQ 12	1.00	8.34
21C	21-2	21-3	30	12	STORM SEW CL A 2 12	1.00	6.56
21D	21-3	21-4	8	15	STORM SEW CL A 2 15	1.13	1.83
21E	21-4	21-5	85	18	STORM SEW CL A 2 18	0.71	23.62
21F	21-6	21-4	89	18	STORM SEW CL A 2 18	0.78	20.89
21G	21-5	21-9	35	18	STORM SEW CL A 2 18	0.69	9.16
21H	21-7	21-8	32	12	STORM SEW CL A 1 12	1.06	0.00
21I	21-9	21-10	12	18	STORM SEW CL A 2 18	1.92	0.00
23A	23-1	23-2	64	12	STORM SEW WM REQ 12	0.50	9.70
23B	23-2	23-3	58	12	STORM SEW CL A 2 12	0.55	6.92
23C	23-3	14-10	62	15	STORM SEW CL A 2 15	0.50	11.98
24A	24-1	EXIST	8	12	STORM SEW CL A 2 12	6.50	0.00

NOTE: 1. CLASS A STORM SEWERS SHALL CONSIST OF THE FOLLOWING MATERIALS: REINFORCED CONCRETE CULVERT, STORM DRAIN, AND SEWER PIPE

2. PIPES DESIGNATED "WM REQ" SHALL SATISFY WATERMAIN REQUIREMENTS (SEE SPECIAL PROVISIONS).