



Notes:

- All beams shall be AASHTO M270 Grade 50.
- See sheet 17 of 26 for Field Splice Details, Diaphragm details and Table of Moments and Shears.
- All diaphragms shall be installed as steel is erected and secured with erection pins and bolts except as otherwise noted. Individual diaphragms at supports may be temporarily disconnected to install bearing anchor rods.
- Load carrying components designated "NTR" shall conform to the Supplemental Requirements for Notch Toughness, Zone 2.

