

**STORMSEWER SCHEDULE:**

Structure	Station	Offset	Type	Diameter	Rim El.	Invert El.	Pay Length	Size	Slope %	
A7	23+71.12	56.30	RT	FES	12	N/A	SW 870.00	38.5	12.0	0.59
A8	24+21.81	57.00	RT	FES	12	N/A	NE 869.70			
A9	23+07.54	122.89	LT	Modified Inlet	12	N/A	SW 864.00	144.0	12.0	0.50
A10	24+57.01	122.89	LT	FES	12	N/A	NE 863.25			
A11	28+85.84	120.55	LT	FES	12	N/A	W 857.64	135.6	12.0	0.30
SI	30+33.75	60.00	LT	Manhole	48	865.94	SW 857.22 E 857.22	117.0	18.0	0.30
S2	30+33.75	60.00	RT	Manhole	48	866.64	W 856.86 E 856.86	52.4	18.0	0.30
A12	30+33.75	120.04	RT	FES	18	N/A	E 856.69			
A13	31+63.99	197.38	LT	FES	12	N/A	S 860.33	34.0	12.0	0.34
A14	32+10.77	197.38	LT	Modified Inlet	12	N/A	N 860.46			
A15	33+00.00	57.16	RT	FES	15	N/A	E 863.95	8.0	15.0	0.30
S4	33+00.00	37.60	RT	Manhole	48	866.50	E 863.90 W 863.90	94.6	18.0	0.30
S3	33+00.00	60.00	LT	Manhole	48	865.18	E 863.62 W 863.62	16.0	18.0	0.30
A16	33+00.00	83.60	LT	FES	18	N/A	W 863.54			
A17	39+47.97	62.34	LT	FES	15	N/A	NW 877.54	30.0	15.0	2.60
A18	39+05.87	62.34	LT	FES	15	N/A	SE 876.37			
T1	21+47.07	61.56	LT	CMP		N/A	S 871.33 Temp	39.6	24.0	0.83
T2	21+75.63	88.91	LT	CMP		N/A	N 871.00 Temp			
T3	21+86.98	53.26	RT	CMP		N/A	S 871.33 Temp	13.0	24.0	0.85
T4	21+99.88	53.12	RT	CMP		N/A	N 871.22 Temp			
T7	51+36.80	44.73	LT	CMP		N/A	N 882.78 Temp	114.0	24.0	2.29
T8	51+45.20	68.22	RT	CMP		N/A	S 880.17 Temp			

**FRAME AND LID DATA:**

Structure	Structure Type	Diameter "D" (in.)	Frame Height "X" (in)	Hole Opening "L" (in)	Frame & Cover Type (Neenah)
A9	Inlet	24	4	24	R-1690
SI	Manhole	48	4	24	R-1690
S2	Manhole	48	4	24	R-1690
A14	Inlet	24	4	24	R-1690
S3	Manhole	48	4	24	R-1690
S4	Manhole	48	4	24	R-1690

**NOTES:**

- EXISTING PIPES SHALL BE CLEANED, ADJUSTED, OR REPAIRED AS NEEDED. THIS WILL BE INCIDENTAL TO THE CONTRACT.
- SEE DETAILS FOR ADDITIONAL MANHOLE AND FLARED END SECTION INFORMATION.
- ALL MANHOLES TO HAVE FLAT SLAB TOP, SEE DETAIL.
- STATIONING AND OFFSETS BASED ON ALIGNMENTS SHOWN. ENGINEER WILL PROVIDE BENCHMARKS WITH STATION, OFFSET, AND ELEVATION FOR THE CONTRACTORS USE.
- ALL MANHOLE STRUCTURES TO BE PRECAST.
- MANHOLES ARE LOCATED TO THE CENTERLINE OF THE FRAME AND GRATE. THE CONTRACTOR IS RESPONSIBLE FOR FABRICATING AND OFFSETTING THE STRUCTURES AS NEEDED TO ALLOW FOR PROPER PLACEMENT OF THE FRAME AND GRATE.
- FRAME AND GRATE ARE INCIDENTAL TO THE MANHOLE OR INLET STRUCTURE.

Hanson Professional Services Inc.  
Suite 200, 815 Commerce Drive  
Oak Brook, Illinois 60523  
© Copyright Hanson Professional Services Inc. 2008

