F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS.	SHEET NO.
8419	99-00048-01-PV	FAYETTE	142	75
STA.	TO STA.			
FED. ROAD DIST. NO.	ILLINOIS	FED. AID PROJECT		
CONTRACT NO. 95500				

N

SCALE IN FEET
0 20 40

600 L.F. PROPOSED 8" AWWA C900 DR18 PVC WATER MAIN

EXACT LOCATION OF OFFSET UNKNOWN

R.R. BATTERY BOX

SIXTH ST.

METER TO BE LOCATED UNDER PAVERS

PROPOSED MANHOLE

EXISTING SEWER TO BE LINED

EXISTING SEWER TO BE ABANDONED

3" CAP AND BLOCK

COMMON LINE SERVING CONNECTED BUILDINGS

SERVICE TO 3 METERS

TAP

SEWER TO BE LINED

GALLATIN ST.

℄ GALLATIN STREET

EXISTING MANHOLE TO BE REPLACED

PROPOSED SEWER

PROPOSED MANHOLE

MATCH LINE STA 4+00

MATCH LINE STA 10+00

FIRE HYDRANT TO BE REMOVED, 1 EACH

8" WATER MAIN EXISTING

PROPOSED 8" GATE VALVE & BOX WITH 8" CROSS

PROPOSED 6" 3-WAY HYDRANT W/GATE VALVE & BOX

STAIRWELL

REVISED (4-13-07)

LEGEND

- WATER MAIN, EXISTING
- WATER MAIN, REPLACEMENT
- FIRE HYDRANT
- FLUSHING HYDRANT
- EXISTING SERVICE RECONNECT INSIDE BUILDING
- REESTABLISH SERVICE FROM MAIN TO INSIDE BUILDING
- EXISTING SERVICE RECONNECT AT NEW MAIN ONLY

600 LF SELECT GRANULAR BACKFILL & CONCRETE PAVEMENT PATCHING (15')

PROPOSED ℄ PROFILE

EXISTING PROFILE ALONG ℄

PROPOSED 28 LF OF 16" STEEL CASING

PROPOSED 8" GATE VALVE & BOX WITH 8" CROSS

600 L.F. PROPOSED 8" AWWA C900 DR18 PVC WATER MAIN

PROPOSED WATER MAIN QUALITY STORM SEWER

EXISTING STORM SEWER (SIZE & LOCATION UNKNOWN)

PROPOSED STORM SEWER

EXISTING COMBINATION SEWER

EXISTING SANITARY SEWER TO BE ABANDONED

COMBINATION SEWER TO BE ABANDONED

30 SERVICE CONNECTIONS

525 520 515 510 505 500 495 490 485

4+00 4+50 5+00 5+50 6+00 6+50 7+00 7+50 8+00 8+50 9+00 9+50 10+00

H.M. & G. NO. 4812

CADD FILE: 14812-W_Gallatin_02.dgn
PLOTTED: 4/16/2007

HENRY, MEISENHEIMER & GENDE, INC. 1075 LAKE ROAD CARLYLE, ILLINOIS 62231 (618) 594-3711 WWW.HMGENGINEERS.COM

WATER - STA. 4+00 TO STA. 10+00 - GALLATIN STREET

Revised 4-17-07