

STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

GENERAL NOTES

1. Reinforcement bars shall conform to the requirements of ASTM A 706 Gr 60. See Special Provisions.
2. Reinforcement bars designated (E) shall be epoxy coated.
3. Prior to pouring the new concrete deck, all heavy or loose rust, loose mill scale, and other loose or potentially detrimental foreign material shall be removed from the surfaces in contact with concrete. Tightly adhered paint may remain unless otherwise noted. Removal shall be accomplished by methods that will not damage the steel and the cost will be included in the pay item covering removal of the existing concrete.

As directed by the Engineer, existing construction accessories welded to the top flange of beams and girders shall be removed. The weld areas shall be ground flush and inspected for cracks using magnetic particle testing (MT) or dye penetrant testing (PT) by qualified personnel approved by the Engineer. Any cracks that cannot be removed by grinding 1/4 inch deep shall be identified and reported to the Bureau of Bridges and Structures for further disposition. The cost of removing welded accessories, grinding and inspecting weld areas and grinding cracks will be paid for according to Article 109.04 of the Standard Specifications.
4. Plan dimensions and details relative to existing plans are subject to nominal construction variations. The Contractor shall field verify existing dimensions and details affecting new construction and make necessary approved adjustments prior to construction or ordering of materials. Such variations shall not be cause for additional compensation for a change in scope of the work, however, the Contractor will be paid for the quantity actually furnished at the unit price bid for the work.
5. Concrete Sealer shall be applied to abutment seats and backwalls. All surfaces to be sealed shall be cleaned thoroughly prior to sealer application. Cost included with Concrete Sealer.
6. The existing structural steel coating contains lead. The Contractor shall take appropriate precautions to deal with the presence of lead on this project.
7. Stage construction shall be utilized to maintain traffic during construction.
8. The Contractor shall exercise care during removal of existing joints to ensure that the slab, beams and diaphragms' integrity will not be detrimentally impacted. The Contractor shall repair any damage(s) to the slab, beams and diaphragms caused by his operation as directed by the Engineer at no additional cost to the Department.
9. Protective Coat shall be applied to the new Latex Concrete Overlay on the deck and approach slabs. Protective Coat shall also be applied to the top and inside faces of the parapets and sidewalk.
10. Joint openings shall be adjusted according to Article 520.04 of the Std. Specs. when the deck is poured at an ambient temperature other than 50°F.
11. In the event that Structural Repair of Concrete takes place at a light pole foundation, the Contractor may be required to temporarily shore or remove and reinstall the light pole if deemed necessary by the Engineer. If necessary, this work shall be performed according to Article 109.04 of the Standard Specifications.
12. The final grades and cross-slopes for the latex concrete overlay and expansion joint reconstruction shall conform to the existing grades plus the net increase in deck thickness specified in the plans. Any preliminary survey required for the Contractor to conform to these grades and to fabricate the preformed joint strip seal expansion joints shall not be paid for separately but shall be included in the cost of the major items of work involved.

INDEX OF SHEETS

- | | |
|-------|---|
| 1 | General Plan and Elevation |
| 2 | General Notes, Bill of Material and Index of Sheets |
| 3 | Stage Construction Details |
| 4 | Bridge Deck, Parapet and Approach Slab Repairs |
| 5 | Parapet Retrofit Details |
| 6 | Expansion Joint Repairs |
| 7 | Expansion Joint Details |
| 8 | Preformed Joint Strip Seal |
| 9 | Substructure Repairs - Abutments |
| 10 | Bar Splicer Assembly and Mechanical Splicer Details |
| 11-14 | Existing Plan Information |

TOTAL BILL OF MATERIAL

ITEM	UNIT	SUPER	SUB	TOTAL
Stone Riprap, Class A4	Sq Yd		30	30
Filter Fabric	Sq Yd		30	30
Concrete Removal	Cu Yd	13.0		13.0
Protective Shield	Sq Yd	1,435		1,435
Concrete Superstructure	Cu Yd	14.3		14.3
Bridge Deck Grooving	Sq Yd	1,609		1,609
Protective Coat	Sq Yd	2,343		2,343
Reinforcement Bars, Epoxy Coated	Pound	1,190		1,190
Bar Splicers	Each	22		22
Preformed Joint Strip Seal	Foot	66.0		66.0
Concrete Sealer	Sq Ft		315	315
Bridge Deck Latex Concrete Overlay, 2 1/4"	Sq Yd	1,714		1,714
Structural Repair of Concrete (Depth Equal to or Less Than 5 Inches)	Sq Ft	159	105	264
Cleaning and Painting Exposed Rebar (Special)	Sq Ft	297		297
Approach Slab Repair (Full Depth)	Sq Yd	10.0		10.0
Bridge Deck Hydro-Scarification, 1/2"	Sq Yd	1,714		1,714
Deck Slab Repair (Full Depth, Type I)	Sq Yd	9.8		9.8
Deck Slab Repair (Full Depth, Type II)	Sq Yd	12.5		12.5
Retrofit Concrete Parapet	Foot	525		525
Temporary Shoring and Cribbing	Each		2	2

DESIGNED -	JLS
CHECKED -	KWS
DRAWN -	RMG
CHECKED -	KWS

benesch

alfred benesch & company
Engineers • Surveyors • Planners
205 North Michigan Avenue, Suite 2400
Chicago, Illinois 60601
312-565-0450 Job No. 10032.13

SHEET NO. 2 14 SHEETS	F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
	3531	1515.1-I	COOK	35	13
			CONTRACT NO. 60J58		
FED. ROAD DIST. NO.		ILLINOIS	FED. AID PROJECT		

**GENERAL NOTES, BILL OF MATERIAL
AND INDEX OF SHEETS
STRUCTURE NO. 016-2519**