











THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ON THE PLANS IS NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.

CALL J.U.L.I.E. FOR UTILITY INFORMATION AT 1-800-892-0123.

**NOTE**

ABANDONMENT AND/OR REMOVAL OF EXISTING RUNWAY OR TAXIWAY LIGHTING CABLES SHALL BE INCIDENTAL TO ITEM AR108158 1/C NO. 8, 5KV, U.G. CABLE IN U.D.

- LEGEND**
-  EXISTING PAVEMENT
  -  EXISTING ELECTRICAL CABLES
  -  EXISTING ELECTRICAL DUCT
  -  PROPOSED 1/C NO. 8, 5KV, U.G. CABLE IN U.D.
  -  EXISTING STAKE MOUNTED TAXIWAY LIGHT
  -  EXISTING BASE MOUNTED TAXIWAY LIGHT
  -  EXISTING STAKE MOUNTED RUNWAY THRESHOLD LIGHT
  -  EXISTING STAKE MOUNTED RUNWAY LIGHT
  -  EXISTING BASE MOUNTED RUNWAY LIGHT
  -  EXISTING TAXI GUIDANCE SIGN

APR 01, 2008 11:50 AM VOORH00805  
 I:\AIRPORTS\KEWANEE\810-06VLT\ELECTRICAL\SHEET\R-142ELE.DWG

CONNECT NEW HOMERUN CABLE AT EXISTING THRESHOLD LIGHT


RUNWAY 1-19

CONNECT NEW HOMERUN CABLE AT EXISTING BASE MOUNTED RUNWAY LIGHT.

EXISTING HOMERUN CABLES FOR RUNWAY 1-19 SHALL BE DISCONNECTED FROM THE RESPECTIVE RUNWAY LIGHTS & ABANDONED IN-PLACE OR REMOVED AT CONTRACTORS OPTION.


PROPOSED 1/C NO. 8, 5KV, FAA L-824, TYPE C U.G. CABLE IN U.D. (NEW HOMERUN CABLES FOR RUNWAY 1-19) (AR108158)

MATCHLINE STA. 252+00



APR 01, 2008 11:50 AM VOORH00805 I:\AIRPORTS\KEWANEE\810-06VLT\ELECTRICAL\SHEET\R-142ELE.DWG - TAXIWAY A

BY		REVISION		DATE	
<p><b>KEWANEE MUNICIPAL AIRPORT</b>                  KEWANEE, HENRY COUNTY, ILLINOIS</p> <p style="font-size: small;">IL. PROJ.: E21-3586 A.I.P. PROJ.: J-17-0058-B12</p>					
H.E. Project No.	810-06VLT	Title	R-142ELE.DWG	Date	04/01/08
Scale	1"=30'	LAYOUT	R.A.W.	DRAWN	B.A.K.
Date	04/01/08	REVIEWED	C.A.H.	Date	04/27/06
Date	08/02/05	Date	08/02/05	Date	08/02/05



Hanson Professional Services Inc.  
 5125 Danby Trail, Suite 100  
 Indianapolis, IN 46214  
 Offices Nationwide

**CONSTRUCT VAULT**

PROPOSED ELECTRICAL PLAN TAXIWAY "A"

8

8 of 27 sheets