


LIGHTING CONTROLLER "B"  
 240/120V, 1PH, 3W  
 STA. 3943+78  
 88.5' RT  
 NOTE 9

**NOTES**

1. FOR SYMBOL LIST AND ABBREVIATIONS, SEE SHEET LT-01.
2. COMBINATION TRAFFIC SIGNAL - LIGHTING POLES SHALL BE INSTALLED UNDER TRAFFIC SIGNAL CONTROL WORK, SEE TRAFFIC SIGNAL PLANS. LUMINAIRE SHALL BE PAID FOR UNDER ELECTRICAL WORK.
3. UNIT DUCT, 600V, 4-1C NO.8, 1/C NO.8 GROUND, (XLP-TYPE USE), 1" DIA. POLYETHYLENE.
4. UNIT DUCT, 600V, 2-1C NO.8, 1/C NO.8 GROUND, (XLP-TYPE USE), 3/4" DIA. POLYETHYLENE.
5. UNIT DUCT, 600V, 4-1C NO.4, 1/C NO.6 GROUND, (XLP-TYPE USE), 1 1/4" DIA. POLYETHYLENE.
6. UNIT DUCT, 600V, 3-1C NO.4, 1/C NO.6 GROUND, (XLP-TYPE USE), 1 1/2" DIA. POLYETHYLENE.
7. POLE SET-BACK SHALL BE MEASURED FROM THE BACK OF THE CURB TO THE CENTER OF THE POLE/BASE.
8. COMBINATION LIGHTING CONTROLLER SHALL BE ATTACHED TO TRAFFIC SIGNAL CONTROL CABINET. SEE EXACT LOCATION ON TRAFFIC SIGNAL PLANS. CONTROLLER OWNED AND MAINTAINED BY I.D.O.T..
9. CONTROLLER OWNED AND MAINTAINED BY CITY OF NAPERVILLE. POWER SHALL BE SUPPLIED BY NAPERVILLE ELECTRIC DEPARTMENT (NED) AND NED REQUIREMENTS FOR INSTALLATION SHALL BE MET.
10. PROVIDE A LOCKING-TYPE RECEPTACLE ON THE FIXTURE. INSTALL LOCKING-TYPE PHOTOELECTRIC CONTROL ON TOP OF LUMINAIRE AND WIRE IT TO THE LIGHTING CONTROLLER FOLLOWING THE CITY OF NAPERVILLE STANDARDS. PARTS AND WORK SHALL BE INCLUDED IN THE "PHOTOCELL" PAY ITEM.
11. UNIT DUCT, 600V, 4-1C NO.4, 3-1C NO.10, 1/C NO.6 GROUND, (XLP-TYPE USE), 1 1/2" DIA. POLYETHYLENE.
12. SEE DISTRICT 1 DETAIL BE-230 FOR COMBINATION LIGHTING AND TRAFFIC SIGNAL ELECTRIC SERVICE DISCONNECT.



DESIGNED <i>MCP</i>	REVISED - ADDENDUM A 02/20/2013	<b>STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION</b>	<b>LIGHTING PLAN - ILLINOIS ROUTE 59</b>		F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
DRAWN <i>MLB</i>	REVISED -		338	(112 & 113) WRS-7	DUPAGE	1156	785		
CHECKED <i>MCP</i>	REVISED -		<b>LT-15</b>		CONTRACT NO. 60R30		ILLINOIS FED. AID PROJECT		
DATE 12/14/2012	REVISED -		SCALE: AS SHOWN	SHEET NO. 4 OF 15 SHEETS	STA. TO STA.				