



STAINLESS STEEL STANDARD GRADE WIRE CLOTH, 6X6 (1/4") MESH OR LESS WITH #16 GAUGE (0.062") DIAMETER OR HEAVIER WIRE. ATTACH WITH 1/2" STAINLESS STEEL BANDING OR TIE BACK ON ITSELF WITH STAINLESS STEEL WIRE TIES. FINISHED INSTALLATION MUST PREVENT RODENT ENTRY.

WIRING DETAIL

(NO SCALE)

GENERAL NOTES

ALL TAPED SPLICES SHALL USE 2 LAYERS OF ELECTRICAL TAPE OVER 3 LAYERS OF RUBBER TAPE AS REQUIRED BY THE STANDARD SPECIFICATIONS. COAT THE FINISHED TAPED SPLICE WITH BONDING COMPOUND.

ALL CABLE SPLICES SHALL BE TAPED UNLESS ANOTHER METHOD HAS BEEN SPECIFICALLY APPROVED BY THE ENGINEER.

FOR EXAMPLE PURPOSES, THE POLE IS SHOWN ON AN ANCHOR BASE. IF THE POLE IS REQUIRED TO BE SET ON A BREAKWAY BASE, CONSULT THE STANDARD SPECIFICATIONS.

ALL DIMENSIONS ARE IN MILLIMETERS (INCHES) UNLESS OTHERWISE SHOWN.

FILE NAME =	USER NAME = sparkgw	DESIGNED -	REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
cr:\pw\work\pvidot\sparkgw\0332350\067	PC04-sh1-detail.dgn	DRAWN -	REVISED -		67	(S) L-1	SANGAMON	9	9
	PLOT SCALE = 32.0000 * / in.	CHECKED -	REVISED -		SCALE: SHEET OF SHEETS STA. TO STA.		CONTRACT NO. 72G04		
	PLOT DATE = Mar-13-2013 09:43:26AM	DATE -	REVISED -		ILLINOIS FED. AID PROJECT				