SHEET SA- 2 OF 14 SHEETS

Contract #63074

## INDEX OF DRAWINGS

SA - 14 of 14 Soil Boring Logs

SA - 1 of 14	General Pian and Elevation
SA - 2 of 14	General Notes, Index of Sheets and Total Bill of Material
SA - 3 of 14	Foundation Plan and Reinforcement
SA - 4 of 14	Top Slab Reinforcement
SA - 5 of 14	Plan and Elevation West Wall
SA - 6 of 14	Plan and Elevation East Wall
SA - 7 of 14	Wall Reinforcement
SA - 8 of 14	Wingwall Details Stage 1
SA - 9 of 14	Wingwall Details Stage 2
SA - 10 of 14	Drainage Details
SA - 11 of 14	Bar Splicer Details
SA - 12 of 14	Rail Details
SA - 13 of 14	Architectural Treatment

TOTAL BI	ILL C	OF MA	TERIAL
----------	-------	-------	--------

PAY ITEM	UNIT ( STAGE 1 STAGE 2 TOTAL
Porous Granular Embankment	Cu. Yd. 546 686 1,232
Structure Excavation	Cu. Yd.( 890 991 1,881 )
Concrete Structures	Cu. Yd.\ 360.7 453.7 814.4 <
Form Liner Textured Surface (Special)	Sq. Ft 1,489 1,766 3,255
Reinforcement Bars, Epoxy Coated	Pound (64,830 83,470 148,300 )
Bar Splicers	Each 191 191
Name Plates	Each 1 1
Geocomposite Wall Drain	Sq. Yd. 215 270 485
Pipe Underdrains for Structures 4"	Foot. 174 196 370
Graffiti Removal (Special)	Sq. Yd. 162 234 396
Anti-Graffiti Coating	Sq. Ft 1,668 1,946 3,614
Steel Railing (Special)	Foot 89 73 162
Architectural Lettering	L. Sum ( 0.25   0.25   0.5
* 0 0 140	

\* See Special Provisions

## GENERAL NOTES

- 1. Reinforcement bars shall conform to the requirements of ASTM A706 Gr. 60. See Special Provision.
- 2. Reinforcement bars designated (E) shall be epoxy coated.
- 3. All exposed concrete edges shall have a  $^3{}_4$ " x 45 deg. Chamfer, except where shown otherwise. Chamfer on vertical edges shall be continued a minimum of one foot below finished ground level.
- 4. Reinforcement bending details shall be in accordance with the latest Manual of Standard Practice for Detailing Reinforced Concrete Structures, ACI 315.
- 5. Reinforcement bar bending dimensions are out to out.
- 6. Cover from face of concrete to face of reinforcement bars shall be 3 inches for surfaces cast against earth and 2 inches for all other surfaces unless otherwise shown.
- 7. The cost of Water Seals and PJF is included in the cost of Concrete Structures unless noted otherwise.
- Backfill shall be placed simultaneously against both side walls of the structure.
  The maximum differential in fill height on either side shall be two feet.
- 9. Reinforcement bar lap splices shall be Class C. Top bars so placed that more than 12 inches of concrete is cast below the reinforcement shall be lapped for 1.4 x basic lap. Reinforcement bar splices shall be in accordance with the following table unless shown otherwise on the drawing.

Basic Lap	1.4 Basic Lap
1'-8"	2'-5"
2'-2"	3'-0"
2'-7"	3'-7"
3′-5"	4'-10"
4'-6"	6'-4"
5′-9″	8'-1"
7′-3″	10'-3"
9'-0"	12 '- 7"
	1'-8" 2'-2" 2'-7" 3'-5" 4'-6" 5'-9" 7'-3"

AAYDESIGNED AJKCHECKED VHDRAWN HMA/DMC CHECKED

benesch alfred benesch & company Engineers · Surveyors · Planners 205 North Michigan Avenue, Suite 2400 Chicago, Illinois 60601 312-565-0450 312-565-0450

GENERAL NOTES, INDEX OF SHEETS AND TOTAL BILL OF MATERIAL MULTI-USE PATH UNDER IL 25/STEARNS ROAD F.A.P. 360 - SEC. 06-00214-15-BR KANE COUNTY STATION 916+09.93 STRUCTURE NO. 045-3173