



REF: DMS-12012.dwg
 DATE: Thursday, February 26, 2009 2:05:15 PM
 FILE: K:\projects\0825702_Airfield_Storage_Phase 1_Anc 2\Sign-plan-electrical.dwg
 UPDATE BY: Jeremy Linke
 LAYOUT: LAYOUT1
 IMAGE FILES:


IL CONTRACT: **DU078**
 IL LETTING ITEM: **9A**
 IL PROJECT: **DPA-3836**
 A.I.P. PROJECT: **3-17-0017-B23**

SURVEY BOOK # BOOK #

REVISIONS		
NUMBER	BY	DATE




TYPICAL LANDSCAPING FOR AR12544X / AR80013X
NEW SIGN / NEW SIGN ON EXISTING PAD
 NOT TO SCALE




TYPICAL LANDSCAPING FOR AR125904 - REMOVE TAXI GUIDANCE SIGN
 NOT TO SCALE

NEW TOPSOIL (4" AVG.) SEED AND MULCH

LANDSCAPING MAX PAY LIMITS



TRENCH DETAIL
 NOT TO SCALE




CABLE IN UNIT DUCT - PLOWED
 NOT TO SCALE

CONTRACTOR SHALL HAVE THE OPTION TO TRENCH OR PLOW UNIT DUCT. NO ADDITIONAL PAYMENT SHALL BE MADE FOR TRENCHING.

- NOTES:**
- TRENCHES WITH MORE THAN 2 CABLES SHALL BE INCREASED 3" IN WIDTH FOR EACH ADDITIONAL CABLE. IF SPECIFIED ON PLANS, TWO PARALLEL TRENCHES MAY BE CONSTRUCTED.
 - DEPTH OF TRENCHES SHALL BE AS SHOWN UNLESS OTHERWISE SPECIFIED ON THE PLANS.
 - SAND BACKFILL SHALL BE USED IF THE EXISTING SOIL DOES NOT MEET THE BACKFILL REQUIREMENTS.
 - ALL DISTURBED SURFACES SHALL BE RESTORED TO THEIR ORIGINAL CONDITION. COST IS INCIDENTAL.

NOTE: AT CONTRACTOR'S OPTION, CABLE PLOWING MAY BE USED IN LIEU OF TRENCHING.



TYPICAL LANDSCAPING CABLE TRENCH DETAIL
 NOT TO SCALE

DUPAGE AIRPORT
WEST CHICAGO, ILLINOIS
AIRFIELD SIGNAGE UPDATES

ELECTRICAL DETAILS - SHEET 2
MISCELLANEOUS DETAILS

Copyright CMT, Inc.
CMT
 CRAWFORD, MURPHY & TILLY, INC.
 CONSULTING ENGINEERS
 License No. 184-000613

DDM
 DuPage Airport

DESIGN BY: AB / JRL
 DRAWN BY: JRO
 CHECKED BY: AB / JRL
 APPROVED BY: DLP
 DATE: 2/27/2009
 JOB No: 08257-02-00

FINAL

SHEET 18 OF 18 SHEETS