



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

May 29th, 2026

SUBJECT FAP Route 305 (US 14)
Project NHPP-9LNU(280)
Section 2025-2102-RS
McHenry County
Contract No. 80C45
Item No. 29, June 12, 2026, Letting
Addendum B

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

1. Revised the Schedule of Prices
2. Revised page 4 of the Special Provisions
3. Revised sheet 3 of the Plans

Prime contractors must utilize the enclosed material when preparing their bid and must include any changes to the Schedule of Prices in their bid.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Jack A. Elston'.

Jack A. Elston, P.E.
Bureau Chief, Design and Environment

MTS

UTILITIES TO BE WATCHED AND PROTECTED

The areas of concern noted below have been identified by following the suggested staging plan included for the contract. The information provided is not a comprehensive list of all remaining utilities, but those which during coordination were identified as ones which might require the Department's contractor to take into consideration when making the determination of the means and methods that would be required to construct the proposed improvement. In some instances, the contractor will be responsible to notify the owner in advance of the work to take place so necessary staffing on the owner's part can be secured.

Pre-Stage

STAGE / LOCATION	TYPE	DESCRIPTION	OWNER
STA 104+67.87 TO STA 150+07.41, STA 303+20 TO STA 321+12	Communication (equipment, manholes, splice boxes, etc.)	Existing facilities within the limits of construction to be protected from damage by the contractor.	AT&T
STA 104+67.87 TO STA 150+07.41, STA 303+20 TO STA 321+12	Gas Main	Existing facilities within the limits of construction to be protected from damage by the contractor. Please contact a Nicor representative (Hensley Gooden [hgooden@southernco.com, 630- 514-7737] or William Bell [wbell@southernco.com, 312-965- 5068]) when working within 25' of the gas main. For transmission mains, please contact Brian Schorr (bschorr@southernco.com) at 630- 918-1657. Contact Shannah Mustafa- Parker, scheduler, at 224-370-8640 if Nicor Gas valve boxes require adjustment or the test connection posts need to be relocated.	Nicor Gas
STA 133+00 TO STA 150+07.41, STA 303+20 TO STA 321+12	Fiber Optic	Existing facilities within the limits of construction to be protected from damage by the contractor.	MCI/Verizon
STA 133+00 TO STA 150+07.41, STA 303+20 TO STA 321+12	Manholes, Overhead Electrical Wires	Existing facilities within the limits of construction to be protected from damage by contractor. If excavation will be performed near poles or large equipment will be used near existing overhead lines, facility protection may be required. If facility protection is required, please call 1-800-334-7661 to create a ticket for line and/or pole protection as soon as possible.	ComEd

Revised 5-29-2026