



NOTES:

1. CONTROLLER SHALL HAVE 11 SPARE 20 AMP BREAKERS FOR FUTURE USE. THE CONTROLLER FOUNDATION SHALL HAVE TWO SPARE 5" WIRING WINDOWS FOR FUTURE USE.
2. CONDUIT SLEEVE UNDER RAMPS SHALL CONTAIN THE UNIT DUCT NOTED.
3. SEE TRAFFIC SIGNAL PLANS FOR COMBINATION LIGHT POLE AND FOUNDATION DETAILS.

STREET LIGHTING - BILL OF MATERIAL - THIS SHEET

PAY ITEM	UNIT	QTY
ELECTRIC SERVICE INSTALLATION	EACH	1
LIGHTING CONTROLLER, BASE MOUNTED, 240 VOLT, 200 AMP	EACH	1
UNDERGROUND CONDUIT, PVC, 1/2" DIA.	FOOT	720
UNDERGROUND CONDUIT, PVC, 3" DIA.	FOOT	235
LIGHT POLE FOUNDATION, 30" DIAMETER	FOOT	52
UNIT DUCT, 600V, 2-1C NO.8, 1/C NO.8 GROUND, (XLP-TYPE-USE), 3/4" DIA. POLYETHYLENE	FOOT	1132
LIGHT POLE, SPECIAL	EACH	8
LUMINAIRE (SPECIAL)	EACH	12
BREAKAWAY DEVICE, COUPLING WITH ALUMINUM SKIRT	EACH	32

benesch
engineers · scientists · planners

Alfred Benesch & Company
205 North Michigan Avenue, Suite 2400
Chicago, Illinois 60601
312-565-0450 Job No. 10064

FILE NAME = D2C0104-AB-sht-1.lghtE01.dgn	USER NAME =	DESIGNED - BENESCH	REVISED -
		DRAWN - NLH	REVISED -
		CHECKED - GHT	REVISED -
		DATE - 3/17/2014	REVISED -

**STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION**

**RIVER DRIVE
PROPOSED LIGHTING
PLAN**

SCALE: AS NOTED SHEET NO. 6 OF 10 SHEETS STA. 3014+00 TO STA. 3026+00

F.A.U. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
5756	(81-1)M	ROCK ISLAND	217	114
			CONTRACT NO. 64J68	
ILLINOIS FED. AID PROJECT				