

GENERAL NOTES

1. CONTRACTOR SHALL BE RESPONSIBLE TO COORDINATE ELECTRICAL WORK WITH OTHER TRADES.
2. LIGHT POLE FOUNDATIONS SHALL BE INSTALLED PLUMB AND FLUSH WITH THE PROPOSED GRADE AND SHALL MEET THE HEIGHT REQUIREMENTS OF ARTICLE 836.03 OF THE STANDARD SPECIFICATIONS. AFTER UNIT DUCT IS INSTALLED, FOUNDATIONS SHALL BE FILLED WITH FINE AGGREGATE ACCORDING TO ARTICLE 836.03. WASHERS USED TO INSTALL THE POLE SHALL BE LARGE ENOUGH TO FULLY COVER THE SLOTTED HOLES IN THE POLE BASE PLATE
3. THE CONTRACTOR IS RESPONSIBLE FOR UNCOVERING OR HAND DIGGING AROUND UTILITIES AS NECESSARY. THE COST OF THIS WORK IS TO BE INCLUDED WITH THE UNIT DUCT PAY ITEM.
4. ALL RELOCATED LIGHTING UNITS SHALL BE INSTALLED AT A MINIMUM OF FIVE FEET BEHIND GUARDRAIL. NO POLE IS TO BE INSTALLED IN THE FLOWLINE OF THE DITCH. POLE SETBACK TO BE INCREASED IF NECESSARY AS DIRECTED BY THE ENGINEER.
5. NO LIGHTING CIRCUIT OR PORTION THEREOF SHALL BE REMOVED FROM NIGHTTIME OPERATION WITHOUT THE APPROVAL OF THE ENGINEER.
6. THE CONTRACTOR SHALL TAKE INSULATION RESISTANCE MEASUREMENTS OF ALL EXISTING CIRCUITS BEFORE ANY MODIFICATIONS ARE MADE AND PROVIDE THE WRITTEN RESULTS TO THE ENGINEER. EXISTING CIRCUITS IN THE LIGHTING CONTROLLER LOCATED ON STEVENSON DRIVE NOT TESTED AND PROPERLY DOCUMENTED SHALL BE SUBJECT TO THE INSULATION RESISTANCE REQUIREMENTS OF ARTICLE 801.13 AT THE CONTRACTOR'S EXPENSE.
7. AFTER THE PROPOSED CIRCUIT IS FULLY INSTALLED THE CONTRACTOR SHALL TAKE INSULATION RESISTANCE MEASUREMENTS ACCORDING TO ARTICLE 801.13 AND PROVIDE THE WRITTEN RESULTS TO THE ENGINEER. IF THE TEST RESULTS DO NOT COMPLY WITH ARTICLE 801.13, THE CONTRACTOR SHALL THEN TEST ONLY THE PORTIONS OF THE CIRCUIT WHICH ARE NEW. ANY WORK NECESSARY TO BRING THE CIRCUIT IN TO COMPLIANCE SHALL BE AT THE CONTRACTOR'S OWN EXPENSE AND NO ADDITIONAL PAYMENT WILL BE ALLOWED.
8. THE CONTRACTOR SHALL PLACE A COPY OF REVISED AS-BUILT PLANS INSIDE THE EXISTING LIGHTING CONTROLLER ON STEVENSON DRIVE.
9. UNDERGROUND CONDUIT, COILABLE NONMETALLIC CONDUIT, 2 1/2" DIA. SHALL BE SCHEDULE 80 AS NOTED IN THE PLANS.
10. STAINLESS STEEL SCREEN INSTALLED AROUND BREAKAWAY COUPLINGS OR ANCHOR RODS AND NUTS SHALL BE ACCORDING TO ARTICLE 1070.04(a)(2)c. OF THE STANDARD SPECIFICATIONS EXCEPT THE MINIMUM WIRE DIAMETER SHALL BE AWG NO. 16 (1.6 MM).

| | | | | | | | | | | | | | |
|--|------------------------------------|------------|-----------|---|-----------------------|-------|----|--------|---------------------------|-----------|----------|-----------------|--------------|
| FILE NAME : c:\pwwork\parks\sparks\0326237\LightingDesign.dgn | USER NAME : sparks | DESIGNED - | REVISED - | STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION | LIGHTING NOTES | | | | F.A.I. RTE. | SECTION | COUNTY | TOTAL SHEETS | SHEET NO. |
| Default | PLOT SCALE = 100.0000' / in. | DRAWN - | REVISED - | | | | | | 55 | (84-3)1-4 | SANGAMON | 56 | 26 |
| | PLOT DATE = Oct-17-2013 09:57:26AM | CHECKED - | REVISED - | | CONTRACT NO. 72F90 | | | | ILLINOIS FED. AID PROJECT | | | | |
| | | DATE - | REVISED - | | SCALE: | SHEET | OF | SHEETS | STA. | TO | STA. | | |