



MAIN FLOW PUMP NO. 2 (MFP-2) SCHEMATICS

- NOTES:**
- N.O. CONTACTS CLOSE ON ALARM.
 - COORDINATE EXACT REQUIREMENTS FOR PUMP PROTECTION WITH PUMP MANUFACTURER.
 - ALL DEVICES MOUNTED IN MOTOR STARTER, UNLESS OTHERWISE NOTED.

- COMPONENT LOCATION:**
- LOCATED IN CONTROL PANEL PUMP ROOM INTERMEDIATE LEVEL EL: 692.75
 - ▲ LOCATED ON RESPECTIVE STARTER DOOR
 - LOCATED IN CONTROL PANEL
 - ◆ LOCATED IN SCADA PANEL
 - TERMINAL IN CONTROL PANEL
 - △ TERMINAL IN MOTOR STARTER
 - ◇ TERMINAL IN SCADA PANEL
 - TSI MOTOR TEMPERATURE SENSOR
 - MSI MOTOR MOISTURE SENSOR