



GATE NO. 3 ELECTRICAL ONE LINE

ELECTRICAL NOTES

1. ELECTRIC SLIDE GATE NO. 3 IS LOCATED AT THE EAST SIDE OF THE FBO HANGAR AND THE ACCESS ROAD TO THE T-HANGARS.
2. ALL ELECTRICAL EQUIPMENT SHALL BE INSTALLED IN CONFORMANCE WITH NFPA 70 – NATIONAL ELECTRICAL CODE (NEC) MOST CURRENT ISSUE IN FORCE, THE RESPECTIVE EQUIPMENT MANUFACTURER'S DIRECTIONS AND ALL OTHER APPLICABLE LOCAL CODES, LAWS, ORDINANCES, AND REQUIREMENTS IN FORCE. ANY INSTALLATIONS WHICH VOID THE U.L. LISTING, ETL LISTING (OR OTHER THIRD PARTY LISTING) AND/OR THE MANUFACTURER'S WARRANTY OF A DEVICE WILL **NOT** BE PERMITTED.
3. CONTRACTOR SHALL COORDINATE NEW WORK AND ANY POWER OUTAGES TO EXISTING EQUIPMENT WITH THE RESPECTIVE USER PERSONNEL & THE AIRPORT DIRECTOR.
4. ALL EQUIPMENT NOT LABELED AS EXISTING IS NEW.
5. PROVIDE A WEATHERPROOF ENGRAVED PHENOLIC OR PLASTIC LEGEND PLATE FOR THE SAFETY SWITCH AT THE RESPECTIVE GATE OPERATOR LABELED "GATE NO. 3, 120 VAC, FED FROM FBO MDP".
6. FURNISH AND INSTALL A #12 AWG EQUIPMENT GROUND WIRE FROM THE GATE OPERATOR TO THE CARD READER UNIT IN THE EXISTING CONTROL WIRING CONDUIT.
7. CONTRACTOR SHALL FIELD VERIFY EXISTING CONDITIONS.
8. WORK SHOWN ON THIS SHEET SHALL BE PAID FOR UNDER ITEM AT109200.

WORK SHOWN ON THIS SHEET IS FOR ADDITIVE ALTERNATE NO. 2

DATE	REVISION	BY

MT. VERNON AIRPORT
MT. VERNON, ILLINOIS

A.I.P. PROJ.: 3-17-0074-B18
IL PROJ.: MVN-3818

Hanson Project No.	08A0003D
Filename	E-604.DWG
Scale	NONE
Date	06/18/08
LAYOUT	KNL 12/02/05
DRAWN	MV 12/02/05
REVIEWED	LDP 12/16/05

HANSON

Hanson Professional Services Inc.
1625 South Sixth Street
Springfield, Illinois 62705-2886
Chicago Nationwide

REHABILITATE TAXIWAYS
"C" AND "D"
INSTALL ELECTRICAL
EQUIPMENT
GATE NO. 3
ELECTRICAL ONE LINE

JUN 30, 2008 2:54 PM WALLE00723 I:\AIRPORTS\MYERINON\08A0003\DESIGN\CAD\SHEETS\E-604.DWG - Work-FLR