

INDEX TO SHEETS

SHEET NO.	DESCRIPTION
1	COVER SHEET
2	SUMMARY OF QUANTITIES AND INDEX TO SHEETS
3	PROPOSED SCOPE OF WORK PLAN
4	PROPOSED SAFETY AND PHASING PLAN-WORK AREA 1
5	PROPOSED SAFETY AND PHASING PLAN-WORK AREA 2
6	PROPOSED SAFETY AND PHASING PLAN-WORK AREA 3
7	CONSTRUCTION SAFETY AND PHASING DETAILS AND NOTES
8	EXISTING ELECTRICAL PLAN - STA. 96+50 TO STA.107+50
9	EXISTING ELECTRICAL PLAN - STA. 107+50 TO STA. 118+50
10	EXISTING ELECTRICAL PLAN - STA. 118+50 TO STA. 129+50
11	EXISTING ELECTRICAL PLAN - STA. 129+50 TO STA. 140+50
12	EXISTING ELECTRICAL PLAN - STA. 140+50 TO STA. 151+50
13	EXISTING ELECTRICAL PLAN - HOMERUNS AND VAULT
14	PROPOSED ELECTRICAL PLAN - STA. 96+50 TO STA.107+50
15	PROPOSED ELECTRICAL PLAN - STA. 107+50 TO STA. 118+50
16	PROPOSED ELECTRICAL PLAN - STA. 118+50 TO STA. 129+50
17	PROPOSED ELECTRICAL PLAN - STA. 129+50 TO STA. 140+50
18	PROPOSED ELECTRICAL PLAN - STA. 140+50 TO STA. 151+50
19	PROPOSED ELECTRICAL PLAN - HOMERUNS AND VAULT
20	SIDEWALK JOINTING PLAN AND DETAILS
21	RADIUS DETAILS
22	RUNWAY 9-27 THRESHOLD DETAILS
23	AIRFIELD LIGHTING NOTES AND SCHEDULES
24	LIGHT LOCATIONS TABLE
25	ELECTRICAL DETAILS SHEET 1
26	ELECTRICAL DETAILS SHEET 2
27	ELECTRICAL DETAILS SHEET 3
28	ELECTRICAL DETAILS SHEET 4
29	4' X 4' X 4' ELECTRICAL MANHOLE
30	UNLIGHTED SIGN DETAILS
31	L-807 WIND CONE ELEVATION DETAIL
32	LIGHTNING PROTECTION DETAILS FOR BEACON
33	REIL DETAILS AND NOTES
34	ELECTRICAL NOTES SHEET 1
35	ELECTRICAL NOTES SHEET 2
36	ELECTRICAL LEGEND AND ABBREVIATIONS
37	EXISTING ELECTRICAL ONE-LINE DIAGRAM FOR VAULT AND AIRFIELD
38	EXISTING ELECTRICAL ONE-LINE DIAGRAM FOR APRON LIGHTING & AWOS
39	PROPOSED VAULT ELECTRICAL EQUIPMENT PLAN
40	PROPOSED VAULT LIGHTING AND RECEPTACLE PLAN
41	PROPOSED AIRPORT VAULT WALL ELEVATIONS (SHEET 1)
42	PROPOSED AIRPORT VAULT WALL ELEVATIONS (SHEET 2)
43	PROPOSED ELECTRICAL ONE-LINE DIAGRAM FOR VAULT & AIRFIELD SHEET 1
44	PROPOSED ELECTRICAL ONE-LINE DIAGRAM FOR VAULT & AIRFIELD SHEET 2
45	VAULT PANELBOARD SCHEDULE
46	AIRFIELD LIGHTING CONTROL WIRING SCHEMATIC
47	LIGHTING CONTRACTOR PANEL SCHEMATIC
48	LIGHTING CONTRACTOR PANEL DETAIL
49	HIGH VOLTAGE WIRING SCHEMATIC FOR RUNWAY 9-27 & TAXIWAY
50	LEGEND PLATE SCHEDULES
51	CCR GROUND BUS RISER
52	GROUNDING DETAILS
53	GROUNDING NOTES

UTILITY NOTE

THE LOCATION, SIZE, AND TYPE OF MATERIAL OF EXISTING UNDERGROUND AND/OR ABOVEGROUND UTILITIES INDICATED ON THE PLANS ARE NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. NEITHER THE OWNER NOR THE ENGINEER ASSUMES ANY RESPONSIBILITY WHATSOEVER IN RESPECT TO THE ACCURACY, COMPLETENESS, OR SUFFICIENCY OF THE INFORMATION. THERE IS NO GUARANTEE, EITHER EXPRESSED OR IMPLIED, THAT THE LOCATIONS, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ARE REPRESENTATIVE OF THOSE TO BE ENCOUNTERED IN THE CONSTRUCTION. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE OWNER'S REPRESENTATIVE AND/OR THE RESIDENT ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY DAMAGE TO SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT. ALL UTILITY CABLES AND LINES SHALL BE LOCATED BY THE RESPECTIVE UTILITY. **CONTACT JULIE (JOINT UTILITY LOCATION INFORMATION FOR EXCAVATORS) FOR UTILITY INFORMATION, PHONE: 1-800-892-0123.** CONTACT THE FAA (FEDERAL AVIATION ADMINISTRATION) FOR ASSISTANCE IN LOCATING FAA CABLES AND UTILITIES. LOCATION OF FAA POWER, CONTROL, AND COMMUNICATION CABLES SHALL BE COORDINATED WITH AND/OR LOCATED BY THE FAA. ALSO CONTACT AIRPORT DIRECTOR/MANAGER AND AIRPORT PERSONNEL FOR ASSISTANCE IN LOCATING UNDERGROUND AIRPORT CABLES AND/OR UTILITIES. ALSO COORDINATE WORK WITH ALL ABOVEGROUND UTILITIES.

J.U.L.I.E. INFORMATION

COUNTY.....McDONOUGH
 CITY.....MACOMB
 TOWNSHIP.....MACOMB T-6-N, R-2-W
 SECTION NO.....7 & 8
 ADDRESS.....MACOMB MUNICIPAL AIRPORT
 RR #1
 MACOMB, ILLINOIS 61455



**Know what's below.
 Call before you dig.**

SUMMARY OF QUANTITIES - BASE BID

ITEM NO.	DESCRIPTION	UNIT	TOTAL QUANTITIES	AS BUILT QUANTITIES
AR107812	L-807 WC-12' INTERNALLY LIT	EA	1	
AR107901	REMOVE WIND TEE	LS	1	
AR108158	1/C #8 5 KV UG CABLE IN UD	LF	25,600	
AR108258	2/C #8 5 KV UG CABLE IN UD	LF	1,800	
AR109110	ERECT PREFABRICATED VAULT	LS	1	
AR109200	INSTALL ELECTRICAL EQUIPMENT	LS	1	
AR109901	REMOVE ELECTRICAL VAULT	LS	1	
AR110013	3" DIRECTIONAL BORE	LF	660	
AR110014	4" DIRECTIONAL BORE	LF	410	
AR110503	3-WAY CONCRETE ENCASED DUCT	LF	200	
AR110610	ELECTRICAL HANDHOLE	EA	10	
AR110710	ELECTRICAL MANHOLE	EA	4	
AR125410	MITL - STAKE MOUNTED	EA	147	
AR125415	MITL - BASE MOUNTED	EA	15	
AR125442	TAXI GUIDANCE SIGN, 2 CHARACTER	EA	1	
AR125445	TAXI GUIDANCE SIGN, 5 CHARACTER	EA	7	
AR125505	MIRL, STAKE MOUNTED	EA	42	
AR125510	MIRL, BASE MOUNTED	EA	12	
AR125540	MI THRESHOLD LIGHT STAKE MTD	EA	16	
AR125610	REILS	PAIR	2	
AR125901	REMOVE STAKE MOUNTED LIGHT	EA	147	
AR125902	REMOVE BASE MOUNTED LIGHT	EA	29	
AR125904	REMOVE TAXI GUIDANCE SIGN	EA	13	
AR125906	REMOVE SPLICE CAN	EA	3	
AR125907	REMOVE REILS	PAIR	1	
AR150510	ENGINEER'S FIELD OFFICE	LS	1	
AR150520	MOBILIZATION	LS	1	
AR150540	HAUL ROUTE	LS	1	
AR800415	TAXI SIGN, 4 CHARACTER, UNLIGHTED	EA	2	
AR800591	UPGRADE AIRPORT ROTATING BEACON	LS	1	

SUMMARY OF QUANTITIES - ADDITIVE ALTERNATE NO. 1

ITEM NO.	DESCRIPTION	UNIT	TOTAL QUANTITIES	AS BUILT QUANTITIES
AS800411	2 CHARACTER SIGN LED UPGRADE	EA	1	
AS800413	MIRL LED UPGRADE	EA	54	
AS800414	MI THRESHOLD LIGHT LED UPGRADE	EA	16	
AS800592	MITL LED UPGRADE	EA	162	
AS800593	5 CHARACTER SIGN LED UPGRADE	EA	7	

NOTES:

QUANTITIES

PAYMENT WILL BE MADE UNDER THE ITEM NUMBERS, DESCRIPTIONS AND UNITS NOTED IN THE ABOVE TABLES IN ACCORDANCE WITH THE BASIS OF PAYMENT FOR EACH RESPECTIVE WORK ITEM COMPLETED AND ACCEPTED BY THE ENGINEER.

CERTIFIED PAYROLLS

THE RESIDENT ENGINEER CANNOT FORWARD CONSTRUCTION REPORTS TO THE ILLINOIS DIVISION OF AERONAUTICS FOR PROCESSING UNTIL ALL CERTIFIED PAYROLLS FOR THE PERIOD HAVE BEEN RECEIVED.

MATERIAL CERTIFICATIONS

COMPLETED WORK CANNOT BE PLACED ON A CONSTRUCTION REPORT UNTIL ALL MATERIAL CERTIFICATIONS FOR THAT PAY ITEM HAVE BEEN RECEIVED, REVIEWED AND ACCEPTED BY THE RESIDENT ENGINEER.

REVISION	DATE	QTY. CHANGED TO
AR125410	02/19/13	147
REVISED AR107901	05/19/13	
REMOVED PAPER FROM PROJECT	06/12/13	

MACOMB MUNICIPAL AIRPORT
 MACOMB, ILLINOIS

IL PROJ.: MGB-4206 BLOCK GRANT PROJ.: 3-17-0064-B21

Hanson Proj. No. 12A0053	02/01/13
Filename G-002-QTY.dwg	MLH
Scale NONE	02/01/13
Date 06/17/13	REVIEWED
	KNL/CAH
	02/04/13



© Copyright Hanson Professional Services Inc. 2013
 Hanson Professional Services Inc.
 1425 South Main Street
 Springfield, Illinois 62703-2886

REPLACE VAULT, AIRFIELD LIGHTING AND GUIDANCE SIGNS

SUMMARY OF QUANTITIES AND INDEX TO SHEETS

JUN 17, 2013 12:11 PM HARR01115
 pw:\sgr-svr306\hanson\dom\hanson\Projects\Documents\12a0053\12a0053.dwg\Airport\Sheet\G-002-QTY