

VERIFIED UTILITY INFORMATION

Table with 8 columns: TEST HOLE #, SIZE & TYPE, NORTHING, EASTING, TOP OF UTILITY, EXISTING CUT, REFERENCE GROUND ELEVATION, COMMENTS. Rows 110-140.

VERIFIED UTILITY INFORMATION

Table with 8 columns: TEST HOLE #, SIZE & TYPE, NORTHING, EASTING, TOP OF UTILITY, EXISTING CUT, REFERENCE GROUND ELEVATION, COMMENTS. Rows 141-164.

TBE Project Information

TH#112 Utility not exposed, clearance depth of 6.79'.
TH#113 Utility not exposed, clearance depth of 8.03'.
TH#130 Utility not exposed, clearance depth of 10.98'.
TH#131 Utility not exposed, clearance depth of 11.56'.
TH#136 Unable to expose utility due to hard clay, probed and felt top and side of utility.
TH#145 & 146 Unable to expose utility due to water table at 3' +/-, but were able to feel the sides and top.
TH#160 & 162 Unable to expose utility due to hard clay, clearance of 7' given.
TH#161 Unable to expose utility due to water, but did feel the pipe.
TH#163 & 164 Unable to expose utility due to water, but did feel top and sides of 30" pipe.

ALL INFORMATION SHOWN WAS OBTAINED FROM A LOCATION SURVEY.

Illinois Department of Transportation

I-90 /94 (NB & SB of Dan Ryan Expressway)
Chicago-Cook County
Sec No: (2122-921 PT1) R, (2021-922 PT1,2)
Contract No. 62586, 62589, 62693, 62694, 62695
TBE Project No.: IL09500164, 167, 168, 170, 171, 179, 180, 182, 204, 205, 206, 211, 212, 219, 221, 225, 226, 227, 228, 230, 232

REVISIONS table with columns: DATE, BY, DESCRIPTION. Row 1: 6-15-05, KLC, REMOVE QL "A" FROM TH#116, 146, 161, 163 & 164 REMOVED TOP OF UTILITY FROM TH#160 & 162.



VERIFIED UTILITY LOCATIONS

Handwritten signature and date: J. Adams E-9802