



HANSON PROFESSIONAL SERVICES INC.

815 Commerce Drive Suite 200  
Oak Brook, Illinois 60523  
Telephone: 630.990.3800  
Fax: 630.990.3801



CITY OF DIXON, ILLINOIS

Post Office Box 386  
Dixon, Illinois 61021  
Telephone: 815.288.1485

DIXON MUNICIPAL AIRPORT  
CHARLES R. WALGREEN FIELD

CONSTRUCT REPLACEMENT  
AIRFIELD ELECTRICAL VAULT

AIP PROJECT NO. 3-17-0036-B8  
IDA PROJECT NO. C73-3548

### SUMMARY OF QUANTITIES

Number	Description	Unit	Quantity	
			As Bid	Record Paid
AR108258	2/C #8 5kV UG Cable in UD	Linear Foot	1,070.0	
AR108656	3/C #6 600V UG Cable in UD	Linear Foot	1,500.0	
AR109100	Construct Electrical Vault	Lump Sum	1.0	
AR109200	Install Electrical Equipment	Lump Sum	1.0	
AR109901	Remove Electrical Vault	Lump Sum	1.0	
AR109924	Replace Electric Services	Lump Sum	1.0	
AR110014	4" Directional Bore	Linear Foot	430.0	
AR110502	2-Way Concrete Encased Duct	Linear Foot	32.0	
AR110600	Concrete Utility Pad	Each	1.0	
AR110610	Electrical Handhole	Each	3.0	
AR150510	Engineer's Field Office	Lump Sum	1.0	
AR152410	Unclassified Excavation	Cubic Yard	46.0	
AR208606	6" Aggregate Base Course	Square Yard	103.0	
AR501604	4" PCC Sidewalk	Square Foot	907.0	
AR501690	PCC Sidewalk Removal	Square Foot	180.0	
AR800591	Upgrade Airport Rotating Beacon	Lump Sum	1.0	
AR800990	Power Cables In Duct	Linear Foot	153.0	
AR904510	Sodding	Square Yard	206.0	
AR905510	Topsoiling (From On Site)	Cubic Yard	16.0	
AR905520	Topsoiling (From Off Site)	Cubic Yard	8.0	

No.	Drawing Issue Description	Date	By

Date  
JUNE 23, 2006  
Sheet Title

### SUMMARY OF QUANTITIES

843-05C8010  
Project Number  
KNL 06/10/06  
Layout By Date  
KNL 06/10/06  
Designed By Date  
RMH 06/23/06  
Reviewed By Date  
Drawn By

G2