

THE LOCATION, SIZE AND TYPE OF MATERIAL OF EXISTING UNDERGROUND UTILITIES INDICATED ON THE PLANS IS NOT REPRESENTED AS BEING ACCURATE, SUFFICIENT OR COMPLETE. IT SHALL BE THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE THE ACTUAL LOCATION OF ALL SUCH FACILITIES, INCLUDING SERVICE CONNECTIONS TO UNDERGROUND UTILITIES. PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL NOTIFY THE UTILITY COMPANIES OF HIS OPERATIONAL PLANS AND SHALL OBTAIN FROM THE RESPECTIVE UTILITY COMPANIES DETAILED INFORMATION AND ASSISTANCE RELATIVE TO THE LOCATION OF THEIR FACILITIES AND THE WORKING SCHEDULE OF THE COMPANIES FOR REMOVAL OR ADJUSTMENT WHERE REQUIRED. IN THE EVENT AN UNEXPECTED UTILITY INTERFERENCE IS ENCOUNTERED DURING CONSTRUCTION, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE UTILITY COMPANY OF JURISDICTION. THE ENGINEER SHALL ALSO BE IMMEDIATELY NOTIFIED. ANY SUCH MAINS AND SERVICES SHALL BE RESTORED TO SERVICE AT ONCE AND PAID FOR BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CONTRACT.


CALL J.U.L.I.E. FOR UTILITY INFORMATION AT 1-800-892-0123. CONTACT AIRPORT PERSONNEL FOR ASSISTANCE IN LOCATING AIRPORT CABLES. CONTACT FAA FOR ASSISTANCE IN LOCATING FAA CABLES

SUMMARY OF PROPOSED QUANTITIES (THIS SHEET)

ITEM NUMBER	DESCRIPTION	UNIT	QUANTITY
AR107408	L-806 WIND CONE 8' LIGHTED	EA	2
AR108656	3/C #6 600V UG CABLE IN UD	L.F.	6,160
AR110014	4" DIRECTIONAL BORE	L.F.	335
AR800581	ELECTRICAL POWER FOR RWY 6 AND RWY 36 WIND CONES	L.S.	1

WIND CONE NOTES
THE PROPOSED WIND CONES SHALL BE INSTALLED AS SHOWN ON THIS SHEET & THE "WIND CONE ELEVATION DETAIL" SHEET, AND IN ACCORDANCE WITH THE SPECIAL PROVISIONS.

- LEGEND**
- EXISTING PAVEMENT
 - PROPOSED DUCT
 - PROPOSED 3/C #6 XLP-USE 600V UG CABLE IN UD - AR108656
 - PROPOSED SUPPLEMENTAL WIND CONE
 - EXISTING ELECTRICAL CABLES
 - EXISTING WIND CONE



DATE	REVISION	BY

HANSON
DECATUR AIRPORT
DECATUR, ILLINOIS

IL PROJ: DEC-3414
A.I.P. PROJ: 3-17-0033-28

ISS. Project No. 802-04TXD	DATE 04/22/05
Filename E-102.DWG	DATE 04/25/05
Scale AS SHOWN	DATE 06/07/06
Date xx/xx/xx	DATE
LAYOUT KNL	DATE
DRAWN MW	DATE
REVIEWED CAH	DATE

HANSON
Engineers, Architects, Scientists
1525 South Sixth Street
Springfield, Illinois 62703-2888
Offices Nationwide

TAXIWAY G WIDENING
PHASE II
ELECTRICAL SITE PLAN
RUNWAY 6 & RUNWAY 36
WIND CONES