


DATE	REVISION	BY



  
**DECATUR, ILLINOIS**
  
 I.L. PROJ.: DEC-3414      A.I.P. PROJ.: 3-17-0033-28

HEL. Project No. 802-041XXD	File Name E-104.DWG	Date 04/22/05
Scale 1/4" = 1'-0"	Date xx/xx/xx	04/25/05
LAYOUT	KHL	06/06/06
DRAWN	MW	
REVIEWED	CAH	


  
**HANSON**
  
 Engineers, Architects, Scientists
   
 1525 South State Street
   
 Springfield, Illinois 62703-2888
   
 Offices Nationwide

**TAXIWAY G WIDENING**
  
**PHASE II**
  
**ELECTRICAL VAULT PLAN**
  
**RUNWAY 6 & RUNWAY 36**
  
**WIND CONE WORK**

- NOTES**
- ALL VAULT WORK AND/OR POWER OUTAGES SHALL BE COORDINATED WITH THE AIRPORT DIRECTOR AND THE RESIDENT ENGINEER.
  - SEE "ELECTRICAL ONE LINE DIAGRAM FOR RUNWAY 6 & RUNWAY 36 WIND CONES" SHEET FOR INFO ON WIRING REQUIREMENTS.
  - HIGH VOLTAGE AND LOW VOLTAGE CIRCUITS SHALL NOT BE INSTALLED IN THE SAME RACEWAY.
  - ELECTRICAL POWER & WIND CONE CONTROL WORK FOR RUNWAY 6 & RUNWAY 36 WIND CONES SHALL BE PAID FOR UNDER AR800581. ELECTRIC POWER FOR RUNWAY 6 & RUNWAY 36 WIND CONES PER LUMP SUM. ALL POWER & CONTROL CABLE AT THE VAULT AND INTO THE LOW VOLTAGE HANDHOLE ADJACENT TO THE VAULT SHALL BE PAID FOR UNDER AR800581.
  - ALL EQUIPMENT NOT LABELED AS EXISTING IS NEW.



**ELECTRICAL VAULT PLAN FOR**  
**RWY 6 & RWY 36 WIND CONES**

SCALE 1/4" = 1'-0"  
 2 0 4 8 FEET

JUN 10, 2005 12:53 PM CCC  
 I:\AIRPORTS\DECATUR\802-041XXD\AIRPORT\SHETS\CONTRACT-1\E-104.DWG - Work-FLR