



- NOTES:**
- REFER TO DRAWINGS E-04 AND E-05 FOR ELECTRICAL SYMBOLS.
 - REFER TO DRAWING E-06 FOR ELECTRICAL ABBREVIATIONS.
 - REFER TO DWGS. E-02 AND E-03 FOR GENERAL ELECTRICAL NOTES.
 - ELECTRICAL EQUIPMENT SHOWN SOLID IS PLATFORM MOUNTED OR WALL MOUNTED AT ELEV. 6'-0".
 - ELECTRICAL CONDUITS SHOWN ARE SUSPENDED FROM EXISTING STRUCTURAL STEEL ABOVE DOCK ELEV. 6'-0" AND BELOW THE MEZZANINE ELEV. 20.073'.
 - ALL ELECTRICAL EQUIPMENT ENCLOSURES, PULL BOXES, JUNCTION BOXES AND TERMINAL CABINETS SHALL BE STAINLESS STEEL, TYPE 316 AND SHALL BE RATED NEMA 4X IN THE DOCK AREA.
 - ALL CONDUIT AND FITTINGS SHALL BE HOT-DIP GALVANIZED RIGID STEEL AND PVC COATED, AND POLYURETHANE COATED, UON IN THE DOCK AREA.
 - THE CONTRACTOR SHALL FURNISH AND INSTALL ALL PULL BOXES REQUIRED TO FACILITATE THE ROUTING AND PULLING OF CONDUITS AND WIRES.
 - WHEREVER THE NUMBER OF CONDUIT BENDS EXCEED 180° AND NO SPLICE IS INVOLVED, CONTRACTOR SHALL USE MOGUL TYPE FITTINGS.
 - REFER TO DRAWINGS E-68 AND E-69 FOR CONDUIT AND WIRE SCHEDULES.
 - CONTRACTOR SHALL SUBMIT SHOP DRAWINGS OF SUBMARINE CABLE TERMINAL BOX DETAILS.

POWER PLAN
1/8"=1'-0"

PB Americas, Inc. 230 WEST MONROE STREET, SUITE 900 CHICAGO, IL. 60606	USER NAME = sharma FILE NAME = D:\6061\sh-t-elo-43.dgn PLOT SCALE = NONE PLOT DATE = 5/7/2009	DESIGNED - A. CENTENO DRAWN - S. SHARMA CHECKED - M. INTATANO DATE - MAY 8, 2009	REVISED - REVISED - REVISED - REVISED -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	POWER PLAN WEST SIDE DOCK LEVEL		F.A.P. RTE. 389 SECTION 2424-2B-R COUNTY COOK TOTAL SHEETS 398 SHEET NO. 314 CONTRACT NO. 60D61 FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT
	SCALE: AS SHOWN SHEET NO. E-43 OF E-125 SHEETS STA. 379+06.09 TO STA. 382+45.28						