



- NOTES:**
- FOR UNDERPASS LIGHTING, SEE UNDERPASS LIGHTING PLAN SHEET.
 - JUNCTION BOX, STAINLESS STEEL, ATTACHED TO PARAPET WALL, 12"x12"x6" AND JUNCTION BOX, STAINLESS STEEL, ATTACHED TO WING WALL, 18"x12"x6" AND CONDUIT ATTACHED TO STRUCTURE, 2 1/2" DIA. PVCC, RGC, - 10'.
 - ROW FENCE REMOVAL AND REPAIR AT THE PROPOSED AND EXISTING LIGHTING CONTROLLER SHALL BE INCLUDED IN THE COST OF THE LIGHTING CONTROLLER WORK.

FILE NAME =	DESIGNED - GRR	REVISED -
...\\D160J16-sht-IL171-prlight-SB-08.dgn	DRAWN - JLW	REVISED -
USER NAME = jworthington	CHECKED - GHT	REVISED -
PLOT DATE = 6/23/2014	DATE - 6/23/2014	REVISED -



STATE OF ILLINOIS
DEPARTMENT OF TRANSPORTATION

PROPOSED LIGHTING PLAN
IL 171

SCALE: SHEET 21 OF 49 SHEETS STA. 96+00.00 TO STA. 110+00.00

F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
372/373	2013-038B-R	COOK	821	220
CONTRACT NO. 60J16			ILLINOIS FED. AID PROJECT	