

MUNICIPALITY	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
QUINCY	06-00300-00-LS	ADAMS	69	19

CIRCUIT VI - 240 VOLT	PVC CONDUIT 2" IN TRENCH	PVC CONDUIT 2" IN AUGERED	USE EXISTING CONDUIT	EL CABLE 4 WIRES #8 - 1C	ORNAMENTAL LIGHT POLE	150 WATT HPS LUMINAIRE	EL CABLE 5 WIRES #12 - 1C	CONCRETE FOUNDATION	JUNCTION BOX	TRENCH & BACKFILL
	FOOT	FOOT		FOOT	EACH	EACH	FOOT	FOOT	EACH	FOOT
SOUTH SIDE OF MAINE STREET - 6TH TO 7TH										
SERVICE BOX E IN PEDESTRIAN WALKWAY										
SOUTH SIDE OF MAINE - 6TH TO 7TH										
TO HH 27				28						
HH27				26						
HH 27 TO HH 16				744						
HH 16				26						
SPLICE IN HH 16 TO JB 37	8			24						8
JB 37				6					1	
JB 37 TO LIGHT 37	5			20						5
LIGHT 37				12	1	1	85	3		
JB 37 TO JB 38	67			268						67
JB 38				6					1	
JB 38 TO LIGHT 38	5			20						5
LIGHT 38				12	1	1	85	3		
JB 38 TO JB 39	75			300						75
JB 39				6					1	
JB 39 TO LIGHT 39	5			20						5
LIGHT 39				12	1	1	85	3		
JB 39 TO JB 40	73			292						73
JB 40				6					1	
JB 40 TO LIGHT 40	5			20						5
LIGHT 40				12	1	1	85	3		
JB 40 TO HH 15	35			140						35
HH 15				26						
HH 15 TO JB 41	23			92						23
JB 41				6					1	
JB 41 TO LIGHT 41	5			20						5
LIGHT 41				12	1	1	85	3		
SPLICE AT HH 16 TO JB 36	67			268						67
JB 36				6					1	
JB 36 TO LIGHT 36	5			20						5
LIGHT 36				12	1	1	85	3		
JB 36 TO JB 35	69			276						69
JB 35				6					1	
JB 35 TO LIGHT 35	5			20						5
LIGHT 35				12	1	1	85	3		
JB 35 TO JB 34	67			268						67
JB 34				6					1	
JB 34 TO LIGHT 34	5			20						5
LIGHT 34				12	1	1	85	3		
JB 34 TO HH 17	63			252						63
HH 17				26						
HH 17 TO JB 33	5			20						5
JB 33				6					1	
JB 33 TO LIGHT 33	5			20						5
LIGHT 33				12	1	1	85	3		
TOTALS	597			3418	9	9	765	27	9	597

PLOT DATE = 8/6/2007
 USER = j...
 PLOT SCALE = 20.0000 / IN
 USER NAME = default