


DATE: _____
 BY: _____
 CHECKED: _____
 DATE: _____
 NO. _____

DATE: _____
 BY: _____
 CHECKED: _____
 DATE: _____
 NO. _____



Boring No./Sample No. : EB-07/6

Depth:	11.0' - 13.0'
Soil Classification:	SAND & GRAVEL A-1-p
Group Index:	0
% Gravel (AASHTO T-311):	31.9
% Sand (AASHTO T-311):	52.2
% Silt/Clay (AASHTO T-311):	15.9
Cu:	
Cc:	
Plasticity Index:	NP

Boring No./Sample No. : EB-08/10

Depth:	21.0' - 23.0'
Soil Classification:	SILTY CLAY A-7
Group Index:	55
% Gravel (AASHTO T-88):	0.0
% Sand (AASHTO T-88):	2.4
% Silt (AASHTO T-88):	50.0
% Clay (AASHTO T-88):	47.6
Liquid Limit:	66
Plastic Limit:	19
Plasticity Index:	51

Boring No./Sample No. : EB-09/25

Depth:	56.5' - 60.0'
Soil Classification:	SAND A-3
Group Index:	1
% Gravel (AASHTO T-311):	0.0
% Sand (AASHTO T-311):	89.9
% Silt/Clay (AASHTO T-311):	10.1
Cu:	2.9
Cc:	1.02
Plasticity Index:	NP