


ENGINEERS
ARCHITECTS
SURVEYORS
SCIENTISTS

Farnsworth GROUP

155 E WASHINGTON STREET
PONTIAC, ILLINOIS 61764
(815) 844-5571 / (815) 844-5147 Fax
www.fw.com



ISSUE

| # | Date | Description |
|---|----------|----------------------------------|
| 1 | 11/21/01 | REVISED SIZE OF WATER MAIN |
| 2 | 05/26/02 | REVISED FOR SUBMITTAL |
| 3 | 02/24/03 | REVISED FOR SOFT CONDITIONS |
| 4 | 02/26/03 | REVISED FOR SOFT SOILS AND LEAKS |

CITY OF PONTIAC

MUNICIPAL AIRPORT WATERMAIN IMPROVEMENTS

LIVINGSTON COUNTY, ILLINOIS

| | |
|---------------|----------|
| Date: | 10-22-04 |
| Design/Drawn: | DAS/GLE |
| Approved: | BDI |
| Book No.: | 2471/41 |
| Project No.: | 104771 |

**WATERMAIN PLAN
STA. 260+00 TO
EXISTING WATERMAIN**

SHEET NO. **9**
OF 10
FILE NO. 24-7371

- NOTES:**
1. THE WATER METER IS TO BE PLACED INSIDE THE AIRPORT BUILDING. ITS EXACT LOCATION AND INSTALLATION IS TO BE COORDINATED WITH THE AIRPORT MANAGER.
 2. TESTING OF ALL PROPOSED WATERMAIN SHALL BE COMPLETE BEFORE THE FINAL CONNECTION TO THE EXISTING 2" WATER MAIN.
 3. THE SEQUENCE TO CONNECT TO THE EXISTING 2" WATER MAIN SHALL BE:
 - A) COORDINATE SHUT OFF OF AIRPORT WATER WITH THE AIRPORT MANAGER.
 - B) DISCONNECT POWER TO THE EXISTING WELLS.
 - C) DISCONNECT THE EXISTING 2" WATER MAIN FROM THE WELL, KEEPING WATER MAIN CLEAN AND FREE OF DEBRIS, PLUS END OF 2" WATER MAIN.
 - D) CONNECT NEW WATER MAIN TO EXISTING 2" WATER MAIN.