

GENERAL NOTES

See cross sections for special ditches and backslopes.

The removal of Bituminous Surfacing not on a rigid type base removed in conjunction with the base shall be removed as EARTH EXCAVATION. The removal of Bituminous Surfacing on a rigid type base removed in conjunction with the base shall be included in the contract unit price for PAVEMENT REMOVAL of the type specified.

The final top 100 mm (four inches) of soil in any right-of-way area disturbed by the Contractor must be capable of supporting vegetation. The soil must be from the A horizon (zero to 2' deep) of soil profiles of local soils.

All Borrow/Waste/Use sites must be approved by the Department prior to removing any material from the project or initiating any earthmoving activities, including temporary stockpiling outside the limits of construction.

The Contractor shall seed all disturbed areas within the project limits. Seeding Class 4 or 2A shall be used, except in front of properties where the grass will be mowed, then use Seeding, Class 1. Class 2A shall be used on front slopes and ditch bottoms. Class 4 shall be used behind Type A gutter, on all backslopes and areas behind the backslope, and beyond the toe of front slope on fill sections without ditches.

Fertilizer Nutrients shall be applied at the rate specified in Sections 250 and 252 of the Standard Specifications. This shall be included in the cost of the SEEDING or SODDING.

Mulch on temporary seeding Class 7 shall be MULCH METHOD 2.

Previously pugmilled stockpiles of "Type A" older than 1 month will not be approved for use until a moisture check is run to verify moisture content. Material shipped to projects without being tested will not be accepted.

Except for the top 75 mm (3"), all aggregate bases and subbases 300 mm (12") in thickness shall be constructed of aggregate gradation CA-2. If the specified thickness exceeds 300 mm (12"), the bases or subbases shall be constructed of topsize 150 mm (6") breaker-run crushed stone with 70% to 90% by weight, passing the 4" sieve and 15% to 40% by weight, passing the 50 mm (2") size sieve, except for the top 75 mm (3"). The breaker-run crushed stone shall be reasonably uniformly graded from coarse to fine and be taken from a quarry ledge capable of producing Class "D" quality aggregate. The top 75 mm (3") shall be gradation CA-6 or CA-10 regardless of thickness. The water necessary to achieve compaction in all but the top 75 mm (3") layer may be added after the subbase or base course is placed on the grade.

The following Mixture Requirements are applicable for this project:

Spring Creek

| Mixture Uses(s): | Surface | Level Binder | Top Shoulder | Bottom Shoulder |
|---|----------------|--------------|----------------|-----------------|
| PG: | SBS PG 70-22 | SBS PG 70-22 | PG 58-22 | PG 58-22 |
| Design Air Voids | 4.0 @ N70 | 4.0 @ N70 | 3 @ N50 | 2 @ N50 |
| Mixture Composition (Gradation Mixture) | IL 9.5 or 12.5 | IL 9.5 | IL 9.5 or 12.5 | BAM |
| Friction Aggregate | E | N/A | C | N/A |
| 20 Year ESAL | 5.7 | 5.7 | N/A | N/A |
| Mix Unit Weight | 119 lbs/sy/in | | 112 lbs/sy/in | |

Forest Hills Road

| Mixture Uses(s): | Surface | Level Binder | Top Shoulder | Bottom Shoulder |
|---|----------------|--------------|----------------|-----------------|
| PG: | PG 64-22 | PG 64-22 | PG 58-22 | PG 58-22 |
| Design Air Voids | 4.0 @ N70 | 4.0 @ N70 | 3 @ N50 | 2 @ N50 |
| Mixture Composition (Gradation Mixture) | IL 9.5 or 12.5 | IL 9.5 | IL 9.5 or 12.5 | BAM |
| Friction Aggregate | D | N/A | C | N/A |
| 20 Year ESAL | 0.8 | 0.8 | N/A | N/A |
| Mix Unit Weight | 112 lbs/sy/in | | 112 lbs/sy/in | |

The Contractor will be required to furnish 140 mm (5 1/2") high brass stencils as approved by the Engineer and install stationing at 250' intervals. Stationing shall be placed on both lanes of 2-lane highways and on the outside lanes in both directions on 4-lane highways. The stations shall be placed 150 mm (6") inside the pavement marking edge so they can be read from the shoulder. This work will be included in the cost of the final pavement surface.

The area to be primed shall be limited to that which can be covered with HMA the same day, unless otherwise permitted by the Engineer.

Bituminous and Aggregate prime coat shall be placed in accordance with Section 406 of the Standard Specifications. The cost of the prime coats shall be included in the contract unit price per metric ton (ton) for LEVELING BINDER (MACHINE METHOD) of the type specified.

The new number for this structure will be 101-0190 for IL 251 over Spring Creek.

This structure will retain the same number 101-0122 for Forest Hills Road over IL 251.

At bridge expansion joints, if temporary expansion joint bulkheads are attached to adjacent deck slabs or abutments for support, the Contractor shall cut the attachments as soon as the concrete has set to prevent joint damage due to horizontal contraction or expansion.

The Contractor shall sandblast the top of the beams upon removal of the bridge deck. This work will be included in the cost of removing the bridge deck.

Reflector Markers Type B shall be installed on the top of bridge parapet walls. The markers shall be according to Standard 635011 and the color and spacing according to Standard 635006, except the minimum is 2 per side.

The Contractor shall install 450 mm (18") diameter formed openings in the Concrete Median Surface, spaced at intervals no greater than 75 m (250 feet), and/or as directed by the Engineer. All existing pavement surfaces or other existing obstructions beneath these openings shall be removed by the Contractor. After the median is in place, core each opening down 1.2 m (4') and fill with dirt. All costs incurred shall be included in the contract unit price per Square Meter (Square Foot) for P.C. CONCRETE MEDIAN SURFACE, 100 mm (4 INCH).

Embankment quantities for the construction of the Traffic Barrier Terminals as shown in the plans are included in quantities for Earth Excavation.

The Contractor shall supply the Resident Engineer with the manufacturer's installation requirements for the type of Steel Plate Beam Guardrail Terminal Type 1 Special (Tangent).

One 16d galvanized nail shall be used to toe nail the wood block out to the wood post on all Traffic Barrier Terminal Type I Specials.

Delineators shall be installed as shown in Standard 635001, except that the post shall be rotated 180° and only metal-backed delineators shall be permitted.

Delineators shall be placed at the ends of approach guardrail terminal sections, and at each headwall or end section of AR Culverts. This work will be paid for at the contract unit price each for DELINEATORS.

Pavement Marking shall be done according to Standard 780001, except as follows:

- All words, such as ONLY, shall be 2.4 m (8 feet) high.
- All non-freeway arrows shall be the large size.
- The distance between yellow no-passing lines shall be 200 mm (8"), not 180 mm (7") as shown in the detail of Typical Lane and Edge Lines.

PERMANENT SURVEY MARKERS, TYPE II, shall be set at intervals of 1.6 Km (1 mile) or as directed by the Engineer. Bridge or culvert projects shall have one survey marker placed near the structure. Estimated: 4 Each.

| | | | | | | | | | | | |
|---------------------------|--------------------------------|--------------------------------|-----------|---|---------------|-----------------------------|-----------------|-----------|--------------------|-----------|--|
| FILE NAME = 64879.GN.DOCX | USER NAME = | DESIGNED - Engineering Systems | REVISED - | STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION | GENERAL NOTES | ROUTE | SECTION | COUNTY | TOTAL SHEETS | SHEET NO. | |
| | PLOT SCALE = | DRAWN - | REVISED - | | | FAP 303 (IL 251) & | 1-HBR & 1-2HB-D | Winnebago | 216 | 3 | |
| | PLOT DATE = 8/31/2010 11:18 AM | CHECKED - | REVISED - | | | FAU 5146 (Forest Hills Rd.) | | | CONTRACT NO. 64879 | | |
| | DATE = 7/28/2010 1:07 PM | DATE - | REVISED - | | | | | ILLINOIS | FED. AID PROJECT | | |
| | | | | SCALE: | SHEET NO. | OF | SHEETS | STA. | TO STA. | | |