

WATER MAIN GENERAL NOTES:

- LOCATION OF UTILITIES AND PROPERTY LINES ARE FROM THE BEST INFORMATION AVAILABLE. EXACT LOCATION AND COMPLETENESS ARE NOT GUARANTEED.
- THE CONTRACTOR MUST VERIFY THE LOCATION OF UNDERGROUND UTILITIES WITH THE UTILITY OWNERS PRIOR TO DOING ANY WORK IN THE VICINITY. THE CONTRACTOR MUST COMPLY WITH REQUIREMENTS OF UTILITY OWNERS REGARDING NOTICE OF WORK AND PROTECTION OF UTILITIES. THE CONTRACTOR MUST COMPLY WITH THE CITY OF CHICAGO, DEPARTMENT OF TRANSPORTATION DAMAGE PREVENTION PROTOCOL CITY INFRASTRUCTURE DEPARTMENTS. ALL UTILITIES MUST BE NOTIFIED AT LEAST 48 HOURS BEFORE CONSTRUCTION. (CALL DIGGER 312-744-7000)
- IF ANY PUBLIC OR PRIVATE UTILITIES CROSS THE WATER MAIN TRENCH AND MUST REMAIN IN PLACE, THE CONTRACTOR MUST PROTECT SAID UTILITY IN CONFORMANCE WITH THE SPECIFICATIONS OR AS DIRECTED BY THE CHICAGO DEPARTMENT OF WATER MANAGEMENT BUREAU OF ENGINEERING SERVICES.
- TEST PITS MUST BE EXCAVATED IN ADVANCE OF PIPELINE CONSTRUCTION IN ORDER TO CONFIRM DEPTH AND LOCATION OF EXISTING UTILITIES AND WHEN DIRECTED BY THE ENGINEER. NO ADDITIONAL PAYMENT WILL BE MADE FOR TEST PIT EXCAVATION.
- WORK INDICATED ON THE PLANS AND NOT REFERENCED TO A BID ITEM IS CONSIDERED INCIDENTAL TO THE WORK TO WHICH IT APPLIES AND NO ADDITIONAL COMPENSATION WILL BE ALLOWED.
- WATER MAIN AND FITTINGS LOCATIONS SHOWN ON THE DRAWINGS FOR THE NEW WATER MAINS AND APPURTENANCES MAY BE CHANGED BY THE ENGINEER DUE TO FIELD CONDITIONS. NO ADDITIONAL COMPENSATION WILL BE ALLOWED FOR SUCH CHANGES, UNLESS PREVIOUSLY APPROVED BY THE ENGINEER.
- THE OPERATION OF ALL VALVES REQUIRED FOR SHUTDOWN MUST BE PERFORMED BY CDWM FORCES PURSUANT TO A 72 HOUR ADVANCE NOTIFICATION TO THE DEPARTMENT. ANY VALVE FOUND NOT OPERABLE WILL BE REPAIRED OR REPLACED BY CDWM.
- REMOVE AND PROPERLY DISPOSE OF ALL WATER ENTERING ANY EXCAVATION INCLUDING LEAKAGE FROM EXISTING WATER MAINS. ALL EXCAVATIONS ASSOCIATED WITH THE WATER MAIN WORK MUST BE KEPT DRY.
- ALL OPENINGS IN EXISTING WATER MAINS MUST BE PLUGGED OR CAPPED WITH DUCTILE IRON FITTINGS UNTIL THE MAIN IS ABANDONED.
- ALL VALVE BASINS MUST BE CONSTRUCTED OF PRE-CAST REINFORCED CONCRETE UNLESS DIRECTED OTHERWISE BY THE ENGINEER.
- NOTES INDICATING S.N.L., E.W.L., ETC. MEAN SOUTH OF THE NORTH PROPERTY LINE, EAST OF THE WEST PROPERTY LINE, ETC. AND ARE MEASURED FROM THE NEAREST STREET.
- IF A STANDARD MECHANICAL JOINT SLEEVE DOES NOT FIT TO MAKE CONNECTION OF THE NEW PIPE TO THE EXISTING PIPE, A TRANSITION SLEEVE MUST BE USED. NO GRINDING OF THE EXISTING PIPE IS PERMITTED.
- THE CONTRACTOR SHALL CONSULT AND FOLLOW RESTRAINED JOINT PIPE MANUFACTURER'S GUIDELINES AS TO EXTENSION OF THE JOINT AFTER ASSEMBLY IN ORDER TO LIMIT THE JOINT TAKE-UP UNDER PRESSURE TEST OR SERVICE CONDITIONS.
- USE FILLER PIECES OF PIPE TO FILL THE AREA BETWEEN PIPE ENDS WHEN INSTALLING SLEEVE FITTINGS.
- ON CONNECTIONS TO EXISTING CAST IRON PIPES, USE CAUTION WHEN INSTALLING MJ SLEEVES. SET SCREW TYPE RESTRAINT GLANDS (E.G. RETAINER GLANDS) ARE NOT ACCEPTABLE. CONSULT THE SPECIFICATIONS FOR JOINT RESTRAINT REQUIREMENTS.
- ABANDON EXISTING WATER MAINS IN ACCORDANCE WITH THE SPECIFICATIONS.
- SWAB ALL PIPE AND FITTINGS WITH CHLORINE SOLUTION DURING INSTALLATION AND USE EXTRA PRECAUTION TO PREVENT SOIL AND DEBRIS FROM ENTERING THE PIPE. COMPLY WITH ALL STANDARDS AND REQUIREMENTS OF THE CDWM BUREAU OF WATER QUALITY, (312) 744-8190
- DE-CHLORINATION OF HEAVILY CHLORINATED WATER IS REQUIRED. THE CONTRACTOR OR SUBCONTRACTED CHLORINATOR SHALL DE-CHLORINATE AS LISTED FOR "INFORMATIONAL PURPOSES ONLY" IN APPENDIX C OF THE ANSI/AWWA STANDARD C-651-05, JUNE 1, 2005. THE CHLORINE LEVEL MUST BE BROUGHT TO POTABLE WATER LEVELS.
- ELEVATIONS ARE SHOWN IN THE CITY OF CHICAGO DATUM AND NAVD 88. THE CONVERSION FACTOR FROM CCD TO NAVD88 IS: NAVD 88 ELEVATION = CCD + 579.19.
- CONTRACTOR SHALL CONSTRUCT THE IMPROVEMENTS ONLY WITHIN THE RIGHT-OF-WAY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY AND ALL DAMAGE TO PRIVATE PROPERTY AND SHALL REPAIR SAID DAMAGE AT OWN EXPENSE TO THE SATISFACTION OF THE ENGINEER.
- ALL CASING PIPES MUST BE SMOOTH WELDED STEEL PIPE MEETING THE REQUIREMENTS OF ASTM A139, GRADE B. THE EXTERIOR OF THE CASING PIPE MUST HAVE COAL-TAR ENAMEL IN ACCORDANCE WITH AWWA C203 AND HAVE A THICKNESS OF 1.000 INCHES AND AN OUTSIDE DIAMETER OF 72 INCHES.
- SPACERS FOR CARRIER PIPES MUST BE EITHER THE TWO-PIECE METAL BAND TYPE WITH 2-INCH WIDE NON-METALLIC RUNNERS OR UNITS MANUFACTURED ENTIRELY OUT OF HIGH-DENSITY POLYETHYLENE. ON TWO-PIECE METAL BAND TYPE SPACERS, BANDS AND FASTENERS MUST BE OF CORROSION RESISTANT MATERIAL. ALL SPACERS MUST BE RATED FOR HEAVY DUTY SERVICE, MANUFACTURED BY (PSI) PIPELINE SEAL AND INSULATOR, INCORPORATED; CASCADE WATERWORKS MANUFACTURING COMPANY OR RACI SPACERS NORTH AMERICA.
- PRIOR TO INSERTION IN THE CASING, EACH LENGTH OF PIPE MUST BE SUPPORTED ON CASING SPACERS IN SUCH A MANNER THAT AT NO TIME WILL THE WEIGHT OF THE PIPE BEAR ON THE BELL OR ANY PART OF THE PIPE TOUCH THE CASING.
- ALL PIPES MUST BE JOINTED PRIOR TO BEING PUSHED OR PULLED THROUGH THE CASING PIPE. AFTER PLACEMENT OF THE CARRIER PIPE THROUGH THE CASING, THE ENDS OF THE CASING ARE TO BE SEALED WITH BRICK AND MORTAR OR RUBBER END SEAL OR OTHER APPROVED METHOD AND MUST BE COMPLETELY LEAK-TIGHT.

BILL OF MATERIALS:

NOTE: ALL PIPE AND FITTINGS INCLUDED BELOW WILL BE SUPPLIED TO THE CONTRACTOR AND WILL BE AVAILABLE AS IDENTIFIED IN THE SPECIAL PROVISIONS. ALL OTHER ITEMS REQUIRED TO PERFORM WORK AS SHOWN ARE THE RESPONSIBILITY OF THE CONTRACTOR.

- 420' OF 48" DI RESTRAINED JOINT PIPE
- 140' OF 24" DI RESTRAINED JOINT PIPE
- 50' OF 72" STEEL CASING PIPE
- 3-48"x24" 3BRJ TEE
- 1-48"x12" 3BRJ TEE
- 2-48" 2BRJ 1/4 BENDS
- 1-48" MJ SLEEVE
- 1-48" MJ TRANSITION SLEEVE
- 1-24" MJ TRANSITION SLEEVE
- 5-48" 2BRJ 1/8TH BEND
- 2-48" 2BRJ 1/16TH BEND
- 1-54" R&S SPIGOT X MJ SPIGOT TRANSITION COUPLING
- 1-54"x48" 2BRJ REDUCER
- 2-24"x16" 2BRJ REDUCER
- 7-24" 2BRJ 1/8TH BEND
- 48" RESTRAINED JOINT PLUG
- 48" RESTRAINED JOINT CAP
- 2-48" BUTTERFLY VALVE
- 1-16" MECHANICAL JOINT GATE VALVE



FILE PATH : p:\A\388235\exm\l\escomonline\loc\2146\CDWM\Documents\21\Americas\Transportation\62255938_CirclePhase_11\222_06\01\25_Roads\Sheet\60W26_Constr.dwg



DIGW26-ent-WM-01.dgn
 USER NAME = CooperM2
 PLOT SCALE = 28.2228' / 1" =
 PLOT DATE = 10/15/2013

DESIGNED - HHC	REVISION 10/15/2013
DRAWN - HHC	REVISION -
CHECKED - RBB	REVISION -
DATE - 9/15/13	REVISION -

STATE OF ILLINOIS
 DEPARTMENT OF TRANSPORTATION

WATER MAIN GENERAL NOTES			
SCALE:	SHEET	OF SHEETS	STA. TO STA.

F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
90/94/290	2013-008R	COOK	559	140
CONTRACT NO. 60W26				
ILLINOIS FED. AID PROJECT				