



GENERAL NOTES

1. The collar shall be constructed entirely of CLASS SI CONCRETE and in accordance with the applicable portions of section 503 of the Standard Specifications. REINFORCEMENT BARS shall conform to section 508.
2. Expansion bolts shall consist of approved expansions anchors, and M20 (3/4'') hook bolts which conform to Section 1006.09. These bolts shall extend at least 200(8'') into the new concrete.

* Dimensions for ASTM C789.

DIMENSIONS

EXISTING BOX		A	B	T *	EACH COLLAR				
W mm (ft)	H mm (ft)				CL SI m ³ (CU YD)	REINFORCEMENT BARS		EXPANSION BOLTS	
					X	Y	kg (POUNDS)	NO.	
600(2)	600(2)	1.22m (4'-0'')	1.22m (4'-0'')	100(4'')	0.21(0.27)	1.02m (3'-4'')	660(26'')	16(21)	8
900(3)	600(2)	1.52m (5'-0'')	1.22m (4'-0'')	100(4'')	0.24(0.32)	1.32m (4'-4'')	660(26'')	18(23)	8
900(3)	750(2.5)	1.52m (5'-0'')	1.37m (4'-6'')	100(4'')	0.26(0.34)	1.32m (4'-4'')	737(29'')	19(25)	8
900(3)	900(3)	1.52m (5'-0'')	1.52m (5'-0'')	100(4'')	0.28(0.36)	1.32m (4'-4'')	813(32'')	20(26)	8
900(3)	1200(4)	1.57m (5'-2'')	1.88m (6'-2'')	125(5'')	0.31(0.41)	1.37m (4'-6'')	991(39'')	22(29)	10
1200(4)	900(3)	1.88m (6'-2'')	1.57m (5'-2'')	125(5'')	0.31(0.41)	1.68m (5'-6'')	838(33'')	22(29)	10
1200(4)	1200(4)	1.88m (6'-2'')	1.88m (6'-2'')	125(5'')	0.34(0.45)	1.68m (5'-6'')	991(39'')	25(32)	12
1200(4)	1500(5)	1.93m (6'-4'')	2.24m (7'-4'')	150(6'')	0.39(0.51)	1.73m (5'-8'')	1.17m (3'-10'')	28(36)	14
1500(5)	1200(4)	2.24m (7'-4'')	1.93m (6'-4'')	150(6'')	0.39(0.51)	2.03m (6'-8'')	1.02m (3'-4'')	28(36)	14
1500(5)	1500(5)	2.24m (7'-4'')	2.24m (7'-4'')	150(6'')	0.42(0.55)	2.03m (6'-8'')	1.17m (3'-10'')	29(38)	16
1500(5)	1800(6)	2.29m (7'-6'')	2.59m (8'-6'')	175(7'')	0.46(0.60)	2.08m (6'-10'')	1.35m (4'-5'')	32(42)	16
1800(6)	1200(4)	2.59m (8'-6'')	1.98m (6'-6'')	175(7'')	0.43(0.56)	2.39m (7'-10'')	1.04m (3'-5'')	30(39)	14
1800(6)	1500(5)	2.59m (8'-6'')	2.29m (7'-6'')	175(7'')	0.46(0.60)	2.39m (7'-10'')	1.19m (3'-11'')	32(42)	16
1800(6)	1800(6)	2.59m (8'-6'')	2.59m (8'-6'')	175(7'')	0.49(0.64)	2.39m (7'-10'')	1.35m (4'-5'')	35(45)	16
1800(6)	2400(8)	2.64m (8'-8'')	3.25m (10'-8'')	200(8'')	0.57(0.74)	2.44m (8'-0'')	1.68m (5'-6'')	39(51)	18
2400(8)	2400(8)	3.25m (10'-8'')	3.25m (10'-8'')	200(8'')	0.63(0.82)	3.05m (10'-0'')	1.68m (5'-6'')	43(56)	20

All dimensions are in millimeters (Inches) unless otherwise noted.

QUANTITIES

CALC. BY: _____ DATE: _____
 CHECKED BY: _____ DATE: _____
 QUANTITY CALCULATIONS ARE ON FILE AT THE DISTRICT 4 OFFICE; BUREAU OF PROJECT IMPLEMENTATION; DOCUMENTATION SECTION

DATE	REVISIONS	BY
1-1-97	RENUM. J-12-01, METRICS, NEW REVISION BOX, REVISED TITLE BOX, ADDED QUANTITY CALCULATION BOX.	T.P.

ILLINOIS DEPARTMENT OF TRANSPORTATION
 DISTRICT CADD STANDARD
 COLLAR FOR BOX CULVERT EXTENSIONS
 CADD STANDARD 540001-D4
 SCALE: NOT DRAWN TO SCALE
 DATE 7/18/2006
 DRAWN BY CADD
 CHECKED BY _____