

NOTES

Reinforcement bars shall conform to the requirements of ASTM A 706 Gr 60. See Special Provisions.

Reinforcement bars designated (E) shall be epoxy coated.

Plan dimensions and details relative to existing plans are subject to nominal construction variations. The Contractor shall field verify existing dimensions and details affecting new construction and make necessary approved adjustments prior to construction or ordering of materials. Such variations shall not be cause for additional compensation for a change in scope of the work, however, the Contractor will be paid for the quantity actually furnished at the unit price bid for the work.

Existing reinforcement bars extending into the removal area shall be cleaned, straightened and incorporated into the new construction. Any reinforcement bars that are damaged during concrete removal shall be replaced with an approved bar splicer or anchorage system. Cost included with Concrete Removal.

The Contractor shall use extreme care during concrete removal so as not to damage the PPC I-Beam.

The Contractor shall locate and verify the exact location of the boundaries of the existing PCC plank being removed prior to saw cutting and removal.

BILL OF MATERIAL

Bar	No.	Size	Length	Shape
a ₂ (E)	5	#5	9'-1"	$\overline{}$
a3(E)	- 8	#5	7'-11''	
04(E)	5	#5	9'-4"	$\overline{}$
a5(E)	8	#5	8'-2"	
b(E)	15	#5	3′-8′′	

SECTION EXAMINED DATE -OCTOBER 7, 2011 SINGLE PLANK REMOVAL AND REPLACEMENT CHECKED VHV STATE OF ILLINOIS 326 (5CS, 13C, 108, 109)R KENDALL 931 659A SN 047-0048 REVISED **DEPARTMENT OF TRANSPORTATION** DRAWN baliva PASSED CONTRACT NO. 66671 SHEET NO. 2A OF 7 SHEETS CHECKED IJL VHV