


TOTAL BILL OF MATERIAL

| ITEM | UNIT | SUPER | SUB | TOTAL |
|--|---------|--------|-------|--------|
| Porous Granular Embankment (Special) | Cu. Yd. | | 153 | 153 |
| Stone Riprap, Class A4 | Sq. Yd. | | 1090 | 1090 |
| Filter Fabric | Sq. Yd. | | 1,090 | 1,090 |
| Removal of Existing Structures | Each | | 7 | 7 |
| Structure Excavation | Cu. Yd. | | 374 | 374 |
| Floor Drains | Each | 36 | | 36 |
| Concrete Structures | Cu. Yd. | | 162.0 | 162.0 |
| Concrete Superstructure | Cu. Yd. | 543.3 | | 543.3 |
| Bridge Deck Grooving | Sq. Yd. | 1401 | | 1401 |
| Concrete Encasement | Cu. Yd. | | 19.8 | 19.8 |
| Protective Coat | Sq. Yd. | 1773 | | 1773 |
| ** Furnishing and Erecting Structural Steel | L. Sum | | | 1 |
| Stud Shear Connectors | Each | 8406 | | 8406 |
| Reinforcement Bars, Epoxy Coated | Pound | 132450 | 14940 | 147390 |
| Bar Splicers | Each | 1188 | 180 | 1368 |
| Furnishing Steel Piles HP14x73 | Foot | | 2699 | 2699 |
| Driving Piles | Foot | | 2699 | 2699 |
| Test Pile Steel HP14x73 | Each | | 4 | 4 |
| Temporary Sheet Piling | Sq. Ft. | | 932 | 932 |
| Name Plates | Each | 1 | | 1 |
| Anchor Bolt 1" φ | Each | | 48 | 48 |
| Geocomposite Wall Drain | Sq. Yd. | | 81 | 81 |
| Pipe Underdrains for Structures, 4" | Foot | | 150 | 150 |
| Diamond Grinding (Bridge Section) | Sq. Yd. | 1318 | | 1318 |
| Asbestos Bearing Pad Removal | Each | | 140 | 140 |
| Underwater Structure Excavation Protection, Location 1 | Each | | | 1 |
| Underwater Structure Excavation Protection, Location 2 | Each | | | 1 |

** See Special Provision for Structural Steel for Bridges.

INDEX OF SHEETS

- 1 General Plan & Elevation
- 2 General Data
- 3 Stage Construction & Temporary Sheet Piling Details
- 4 Modified Temporary Concrete Barrier Details
- 5-8 Top of Slab Elevations
- 9 Top of West Approach Slab Elevations
- 10 Top of East Approach Slab Elevations
- 11 Superstructure
- 12 Superstructure Details
- 13 Integral Abutment Diaphragm Details
- 14-15 Bridge Approach Slab Details
- 16 Structural Steel
- 17 Structural Steel Details
- 18 Bearing Details
- 19 West Abutment
- 20 East Abutment
- 21 Pier 1
- 22 Pier 2
- 23 Bar Splicer Assembly Details
- 24 Steel H Pile Details
- 25-30 Soil Boring Logs



SECTION THRU INTEGRAL ABUTMENT

Notes: All drainage system components shall extend to 2'-0" from the end of each wingwall except an outlet pipe shall extend until intersecting with the side slopes. The pipes shall drain into concrete headwalls. (See Article 601.05 of the Standard Specifications and Highway Standard 601101).

GENERAL NOTES

Fasteners shall be AASHTO M164 Type 3. Bolts 7/8" φ, holes 15/16" φ, unless otherwise noted.
 Calculated weight of Structural Steel = 453,110 lbs.
 All structural steel shall be Grade 50W. All structural steel shall be cleaned as specified in the Special Provision for "Surface Preparation and Painting Requirements for Weathering Steel".
 Layout of slope protection system may be varied to suit ground conditions in the field as directed by the Engineer.
 No field welding is permitted except as specified in the contract documents.
 Reinforcement bars designated (E) shall be epoxy coated.
 Bearing seat surfaces shall be constructed or adjusted to the designated elevations within a tolerance of 1/8 inch (0.01 ft.). Adjustment shall be made either by grinding the surface or by shimming the bearings.
 Structural steel shall only be painted for a distance equal to the depth of embedment into the concrete cap plus 3 inches. Painted areas shall be primed in the shop with a Department approved zinc rich primer. Field painting will not be required.
 Reinforcement bars shall conform to the requirements of AASHTO A 706, Grade 60.
 Up to 1/4" shall be ground off the bridge slab and the bridge approach slab. The profile grade shown on sheet 1 of 30 is the final elevation after grinding.
 All test piles shall be driven utilizing dynamic pile monitoring procedures. See Special Provisions.
 Slipforming of the parapets is not allowed.


WATERWAY INFORMATION

| Flood | Freq. Yr. | Q C.F.S. | Opening Sq. Ft. | | Nat. H.W.E. | Head - Ft. | | Headwater El. | | |
|----------------|-----------|---|-----------------|-------|-------------|------------|-------|---------------|-------|--|
| | | | Exist. | Prop. | | Exist. | Prop. | Exist. | Prop. | |
| | | Existing Low Grade Elev. 683.30 @ Sta. 420+00 | | | | | | | | |
| | | Proposed Low Grade Elev. 683.75 @ Sta. 417+00 | | | | | | | | |
| Design | 10 | 6410 | 1799 | 2050 | 680.4 | 1.0 | 1.0 | 681.4 | 681.4 | |
| Base | 50 | 10200 | 2159 | 2436 | 681.7 | 1.7 | 1.6 | 683.4 | 683.3 | |
| Overtop Exist. | 100 | 11800 | 2270 | 2556 | 682.1 | 2.1 | 2.0 | 684.2 | 684.1 | |
| Overtop Prop. | 250 | 14100 | 2388 | | 682.7 | 1.0 | | 683.7 | | |
| Max. Calc. | 450 | 15600 | 2672 | 2672 | 683.0 | | 0.8 | 683.8 | 683.8 | |
| | 500 | 15800 | 2388 | 2672 | 683.1 | 1.1 | 0.8 | 684.2 | 683.9 | |


10 year velocity through existing bridge = 3.2 ft/s
 10 year velocity through proposed bridge = 2.8 ft/s

DESIGN SCOUR ELEVATION TABLE

| Design scour elevation (ft.) | W. Abut. | Pier 1 | Pier 2 | E. Abut. |
|------------------------------|----------|--------|--------|----------|
| | 678.6 | 647.8 | 647.8 | 678.7 |



SECTION A-A



SECTION B-B

REVISION 11/8/11

| | | | | | | | | | |
|-------------------------------|-------------------------------|------------------------|---|--|--------------------------|---------------------------|--------------------|--------------------|----------------|
| DESIGNED - Michael D. Rolape | EXAMINED - Thomas J. Domagala | DATE - OCTOBER 5, 2011 | STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION | GENERAL DATA STRUCTURE NO. 057-0244 | F.A.P. RTE. - 315 | SECTION - 121 BR-2 | COUNTY - MCLEAN | TOTAL SHEETS - 144 | SHEET NO. - 50 |
| CHECKED - Nicholas R. Barnett | PASSED - [Signature] | | | | SHEET NO. 2 OF 30 SHEETS | ILLINOIS FED. AID PROJECT | CONTRACT NO. 70552 | | |