



LOAD TABLE LIGHTING CONTROLLER "M"					
CIRCUIT	RED PHASE		BLACK PHASE		CIRCUIT
	AMPS	WATTS	AMPS	WATTS	
A	20.0	4,800	B	17.6	4,224
C	18.6	4,464	D	18.6	4,464
E	16.2	3,888	F	18.2	4,368
G	16.2	3,888	H	18.2	4,368
I	20.4	4,896	J	20.4	4,896
K	16.0	3,840	L	16.0	3,840
M	32.0	7,680	N	30.4	7,296
O			P		
TOTAL	139.4	33,456	TOTAL	139.4	33,456

**SINGLE LINE DIAGRAM  
LIGHTING CONTROLLER "M"**

NOTES:  
1. SEE DRAWING ME-12 FOR WIRING DIAGRAM DETAILS.

**LEGEND**

- HIGH MAST LIGHT TOWER.
- 400 W. HPS LUMINAIRE (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- HIGH MAST TOWER DESIGNATION.
- LIGHTED SIGN STRUCTURE WITH 170 W. FLUORESCENT LUMINAIRES, QUANTITY OF LUMINAIRES AS REQUIRED. (BLACK PHASE-SOLID SYMBOL, RED PHASE, OPEN SYMBOL)
- 3 POLE SAFETY SWITCH
- UNDERPASS LIGHTING UNIT, 70W HPS LUMINAIRE. (BLACK PHASE- SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- LIGHTING CONTROLLER
- GROUND FIELD
- ELECTRIC UTILITY SERVICE
- ECA
- ELECTRIC CABLE ASSEMBLY
- CONVENTIONAL LIGHTING UNIT, 310 WATT HPS LUMINAIRE. (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
- EXISTING UNDERPASS LIGHTING UNIT, 55W LPS LUMINAIRE (BLACK PHASE SOLID SYMBOL, RED PHASE OPEN SYMBOL)

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION  
F.A.I. 90/94 (DAN RYAN EXPRESSWAY)  
31st STREET TO I-57

**SINGLE LINE DIAGRAM  
LIGHTING CONTROLLER "M"  
FINAL CONDITION**

SCALE: NOT TO SCALE  
DATE: OCTOBER 29, 2004  
DRAWN BY: YJ  
CHECKED BY: TM

**SINGH** 300 W. ADAMS ST.  
CHICAGO, IL 60606  
SINGH & ASSOCIATES, INC.  
CONSULTING ENGINEERS  
TEL: (312) 629-0240  
FAX: (312) 629-8449

11/23/2004 4:04:22 PM