



**SINGLE LINE DIAGRAM  
LIGHTING CONTROLLER "P"**

NOTES:  
1. SEE DRAWING ME-12 FOR WIRING DIAGRAM DETAILS.

CIRCUIT	RED PHASE		BLACK PHASE		
	AMPS	WATTS	AMPS	WATTS	
A	22.0	5,280	B	20.0	4,800
C	16.2	3,888	D	13.4	3,216
E	29.0	6,960	F	27.4	6,576
G	13.6	3,264	H	11.6	2,784
I	20.7	4,968	J	19.8	4,752
K	25.8	6,192	L	25.8	6,192
M			N		
O	34.3	8,232	P	33.9	8,136
TOTAL	167.7	40,248	TOTAL	157.2	37,728

- LEGEND**
- HIGH MAST LIGHT TOWER.
  - 400 W. HPS LUMINAIRE (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
  - HIGH MAST TOWER DESIGNATION.
  - LIGHTED SIGN STRUCTURE WITH 170 W. FLUORESCENT LUMINAIRES, QUANTITY OF LUMINAIRES AS REQUIRED. (BLACK PHASE-SOLID SYMBOL, RED PHASE, OPEN SYMBOL)
  - UNDERPASS LIGHTING UNIT, 70W HPS LUMINAIRE. (BLACK PHASE-SOLID SYMBOL, RED PHASE-OPEN SYMBOL)
  - LIGHTING CONTROLLER
  - GROUND FIELD
  - ELECTRIC UTILITY SERVICE

**SINGH**  
SINGH & ASSOCIATES, INC.  
CONSULTING ENGINEERS  
300 W. ADAMS ST.  
CHICAGO, IL 60606  
TEL: (312) 629-0240  
FAX: (312) 629-8449

REVISIONS	
NAME	DATE

ILLINOIS DEPARTMENT OF TRANSPORTATION  
F.A.I. 90/94 (DAN RYAN EXPRESSWAY)  
31st STREET TO I-57

**SINGLE LINE DIAGRAM  
LIGHTING CONTROLLER "P"  
FINAL CONDITION**

SCALE: NOT TO SCALE  
DATE: OCTOBER 29, 2004

DRAWN BY: YJ  
CHECKED BY: TM

J:\5\9094\10217535\5108-04.dwg 8:52:46 PM 10/21/2004