



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

January 18, 2011

SUBJECT: FAU 1578 (Lily Cache Lane)
Project CMM-M-TE-9003(632)
Section 06-00046-01-PV (Bolingbrook)
Will County
Contract No. 63503
Item 128
January 21, 2011 Letting
Addendum (B)

TO PROSPECTIVE BIDDERS:

Due to clarify information necessary to revise the following:

Proposal – Page 68 of the special provisions.

Prime contractors must utilize the enclosed material when preparing their bid and must include any Schedule of Prices changes in their bidding proposal.

Bidders using computer-generated bids are cautioned to reflect any and all Schedule of Prices changes, if involved, into their computer programs.

Very truly yours,

Scott Stitt
Acting Engineer of Design and Environment

A handwritten signature in cursive script, appearing to read 'Ted B. Walschleger', followed by the letters 'DE'.

By: Ted B. Walschleger
Engineer of Project Development
and Implementation

ELECTRIC UTILITY SERVICE CONNECTION

Description: This item shall consist of payment for work to be performed by ComEd in making the connection of electric cables to their transformer for 240V/480V 60 Hz, single-phase, three-wire system, and any other work deemed necessary by ComEd in fulfilling the requirements of this contract as shown on the plans and specified in the special provisions. THIS MAY INVOLVE WORK AT MORE THAN ONE ELECTRIC SERVICE. See section 804 of "Standard Specifications for Road and Bridge Construction".

Please contact ComEd, New Business Center Call Center, at 866 NEW ELECTRIC (1-866-639-3532) to begin the service connection process. The Call Center Representatives will create a work order for the service connection. The representative will ask the requestor for information specific to the request. The representative will assign the request based upon the location of project.

The Contractor should make particular note of the need for the earliest attention to arrangements with ComEd for service. In the event of delay by ComEd, no extension of time will be considered applicable for the delay unless the Contractor can produce written evidence of a request for electric service within 30 days of execution.

Requirements: This work will be performed in accordance with the applicable provisions of Section 804 of the Standard Specifications.

Method of Payment: The contractor will be reimbursed by this contract to the exact amount of money as billed by ComEd for their services. Work provided by the Contractor for electric service will be paid separately as described under ELECTRIC SERVICE INSTALLATION. No extra compensation shall be paid to the contractor for any incidental materials and labor required to fulfill the requirements as shown on the plans and specified herein.

For bidding purposes, this item shall be estimated at \$1,800.00.

Basis of Payment: This work will be paid for at the contract lump sum price for ELECTRIC UTILITY SERVICE CONNECTION, which shall be reimbursement in full for electric utility service charges.

LIGHTING CONTROLLER, SPECIAL

Description: This work shall consist of installing new controllers at locations shown on the plans.

Requirements: This work shall be completed in accordance with the applicable portions of section 825 of the Standard Specifications. The control cabinet and all controls are to be provided and constructed per detail. All service equipment shall be rated for a minimum available fault current as follows: 22,000 RMS for main circuit breaker, 10,000 RMS for branch circuit breakers and 5,000 RMS for Auxiliary circuit breakers. The contractor shall submit shop drawing for approval.

Basis of Payment: This work will be paid for at the contract unit price per each for LIGHTING CONTROLLER, SPECIAL, of the enclosure and control type specified.