


- NOTES:**
- PROPOSED UTILITY POLE SHALL BE INSTALLED BY COMED. CONTRACTOR SHALL INSTALL CONDUIT, GROUNDING, DISCONNECT ANY SECONDARY CONDUCTORS TO THE UTILITY POLES. COORDINATE ALL WORK WITH COMMONWEALTH EDISON. REFER TO LIGHTING CONTROLLER DETAIL.
 - PROPOSED ROUTING OF CONDUIT AS SHOWN FOR INFORMATION ONLY. CONTRACTOR SHALL VERIFY EXACT ROUTING IN THE FIELD.
 - ALL SPLICES SHALL BE HEAT SHRINK AND WATERPROOF, INSTALLED INSIDE POLE BASE OR HANDHOLES. NO DIRECT BURIED SPLICES SHALL BE ALLOWED.
 - REFER TO IDOT STANDARD 814001-02 FOR HANDHOLE DETAILS.
 - REFER TO JUNCTION BOX AND PARAPET WALL CONDUIT TRANSITION DETAILS.

- LEGEND**
- PROPOSED ROADWAY LIGHTPOLE AND LUMINAIRE
 - TYPE A: 400W MH LUMINAIRE, 40 FT POLE, 6 FT MAST ARM
 - TYPE B: 250W MH LUMINAIRE, 30 FT POLE, 6 FOOT MAST ARM
 - TYPE C: 400W MH LUMINAIRE, 40 FT POLE, 6 FOOT MAST ARM, PARAPET WALL MOUNTED
 - EXISTING ROADWAY LIGHTPOLE AND LUMINAIRE
 - ◆ PROPOSED UTILITY POLE (BY OTHERS)
 - PROPOSED LIGHTING CONTROLLER, 100 AMP, 480V
 - PROPOSED ROADWAY LIGHTING HANDHOLE
 - PROPOSED JUNCTION BOX
 - CONDUIT INSTALLED, 1 1/2" PVC
 - L- PROPOSED 1 1/2" PVC, SCH. 40, CONDUIT, IN TRENCH WITH 2 #6 XLP-USE, 1 #8 GND. OR AS INDICATED
 - E- PROPOSED 2" PVC, SCH. 40, CONDUIT, EMBEDDED IN PARAPET WALL WITH 2 #6 XLP-USE, 1 #8 GND. OR AS INDICATED
 - FO- PROPOSED 1-1/2" PVC, SCH. 40, CONDUIT, IN TRENCH, EMPTY (FOR FUTURE BUILD)



USER NAME = Steve Frange	DESIGNED - SJP / MNB	REVISED -
PLOT SCALE = 48,0000' / IN.	DRAWN - ERD	REVISED -
PLOT DATE = 02/04/11	CHECKED - SJP	REVISED -
	DATE - 02/04/2011	REVISED -

**CITY OF ROCKFORD
MORGAN STREET BRIDGE**

**ROADWAY LIGHTING PLAN
MORGAN STREET / COLLEGE AVENUE**

F.A. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
5077	99-00493-00-BR	WINNEBAGO	253	115
FED. ROAD DIST. NO. 2 ILLINOIS FED. AID PROJECT BRM-5099165				

SCALE: 1"=20' SHEET NO. 1 OF 4 SHEETS STA. 34+00 TO STA. 46+00 CONTRACT NO. 85529