F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
94	*	COOK	907	397
STA.		TO STA.		
FED. ROAD DIST. NO.	ILLINOIS	FED. AID PROJECT		

* (1516.1, 1717 & 1818) R-9

62695



HEXAGON NUT

AMER. NAT'L. STD. HEAVY HEX. FLAT NUT (ANSI B 18.2.2 - 1972)



FLAT WASHER

AMER. NAT'L. STD. TYPE "B" SERIES "W" (ANSI B 18.22.1-1965, R1975)



LOCK WASHER

AMER. NAT'L. STD. HELICAL SPRING LOCK WASHER (ANSI B 18.21.1 - 1972)





U.S. STANDARD 1½"-6 N.C. ROLLED THREAD

A ZINC COATING, 0.0021 INCH IN THICKNESS SHALL BE APPLIED OVER THIS LENGTH AND COVERED WITH HEAVY NO-OX-ID, OR EQUAL, RUST INHIBITING COMPOUND

MATERIAL:

A.S.T.M. A-36 MODIFIED STEEL, 55 000 LBS. MINIMUM YIELD.

HARDWARE TO BE FURNISHED & ATTACHED IN PLACE ON ROD FOR SHIPPING:
2 HEX. NUTS, HEAVY, GALV., 1½".
2 WASHERS, STEEL, ROUND, GALV., TYPE "B", SERIES "W", 1½".
1 WASHER, LOCK, STEEL, GALV., HELICAL SPRING, REGULAR, 1½".

BOLT & NUTS SHALL HAVE AN AMERICAN STANDARD CLASS 2 OR 3 FIT. (NUT IS TAPPED OVERSIZE BY 1/32")

1½" x 60" STEEL ANCHOR ROD

COMMODITY CODE 37-8180-0240

REVISED		REDRAWN
A	JULY 29, 1982	
B		
C		
D		
E		
F		
G		

CITY OF CHICAGO
DEPT. OF STREETS AND SANITATION
BUREAU OF ELECTRICITY
DIVISION OF ELECTRICAL ENGINEERING

DRAWN: EUGENE GERULIS | CHECKED: A. NIELSEN | ENGINEER: H. SHINE

ELEC. DESIGN ENGINEER:

ENGINEER OF ELECTRICITY:

DEPUTY COMMISSIONER:

DRG. NO. 806

SIZE 17" x 28" SCALE: | DATE AUG. 3, 1982

KNIGHT
Engineers & Architects

REVISIONS	
NAME	DATE
REVISED	04/15/05

ILLINOIS DEPARTMENT OF TRANSPORTATION

F.A.I. 94 (DAN RYAN EXPRESSWAY)

CITY OF CHICAGO

BUREAU OF ELECTRICITY STANDARDS

SCALE: | DRAWN BY: REW

DATE: MARCH 25, 2005 | CHECKED BY: WHI

FILE: L:\1658.021\Cadd\Sheets\Revised 1781.04-15-05\1658208 Sht#1014 Rev04505.dgn