



Illinois Department of Transportation

2300 South Dirksen Parkway / Springfield, Illinois / 62764

November 1, 2023

SUBJECT: FAU 2712 (Balmoral Avenue)
Section 17-00084-00-PV (Westchester)
Cook County
Contract No. 61J83
Item 015
November 17, 2023 Letting
Addendum (A)

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

- 1. Revised Special Provision Index**
- 2. Added pages 79A, 79B & 79C to the Special Provisions**

Prime contractors must utilize the enclosed material when preparing their bid and must include any changes to the Schedule of Prices in their bid.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Jack A. Elston'.

Jack A. Elston, P.E.
Bureau Chief, Design and Environment

TABLE OF CONTENTS

LOCATION OF IMPROVEMENT	1
DESCRIPTION OF IMPROVEMENT	1
MAINTENANCE OF ROADWAYS (D1).....	2
STATUS OF UTILITIES (D-1)	3
PUBLIC CONVENIENCE AND SAFETY (D1).....	9
AGGREGATE SURFACE COURSE FOR TEMPORARY ACCESS	10
HOT-MIX ASPHALT BINDER AND SURFACE COURSE (D-1).....	12
HOT-MIX ASPHALT – MIXTURE DESIGN VERIFICATION AND PRODUCTION (D1)	18
ADJUSTMENTS AND RECONSTRUCTIONS	20
DRAINAGE AND INLET PROTECTION UNDER TRAFFIC (D1).....	21
TRAFFIC CONTROL AND PROTECTION (ARTERIALS) (D1)	23
TRAFFIC CONTROL PLAN (D1).....	24
FRICTION AGGREGATE (D-1).....	25
KEEPING ARTERIAL ROADWAYS OPEN TO TRAFFIC (LANE CLOSURES ONLY)	28
TEMPORARY INFORMATION SIGNING.....	29
AVAILABLE REPORTS (D1 LR)	31
DETECTABLE WARNINGS	32
FRAMES AND LIDS TO BE ADJUSTED (SPECIAL).....	33
STORM SEWER REMOVAL	34
DUCTILE IRON WATER MAIN	35
WATER VALVES.....	37
FIRE HYDRANTS TO BE REMOVED.....	38
FIRE HYDRANT WITH AUXILIARY VALVE AND VALVE BOX.....	39
PIPE UNDERDRAINS, TYPE 2, 4"	41
VALVE VAULTS, TYPE A, 5'-DIAMETER, TYPE 1 FRAME, CLOSED LID	42
FILLING VALVE VAULTS	43
CHANGEABLE MESSAGE SIGN.....	44
ADJUSTING SANITARY SEWER SERVICE LINE	45
WASHOUT BASIN	46
TRENCH BACKFILL, SPECIAL	47
WATER MAIN LINE STOP.....	48
WATER SERVICE CONNECTION.....	49
CUT AND CAP EXISTING WATER MAIN.....	51
VALVE BOX	52
FRAMES AND LIDS (SPECIAL).....	53
CONNECTION TO EXISTING WATER MAIN (NON-PRESSURE) – 6"	54
LOCATING UNDERGROUND UTILITY	55
STORM STRUCTURE INTERNAL REPAIR (SPECIAL).....	56
INSTALL SIGN	57
WATER MAIN 8" (SPECIAL).....	58
HOT-MIX ASPHALT DRIVEWAY PAVEMENT, 3".....	61
STORM SEWER, (WATER MAIN QUALITY PIPE).....	62
TEMPORARY TRAFFIC SIGNAL TIMING	65
IDOT TRAINING PROGRAM GRADUATE ON-THE-JOB TRAINING SPECIAL PROVISION	66
LR 107-4	68
LR 1030-2.....	69
SWPPP.....	71
IEPA LPC 663.....	78
IEPA PERMIT	79A

ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 North Grand Avenue, East; Post Office Box 19276; Springfield, IL 62794-9276

Division of Public Water Supplies

Telephone 217/782-1724

PUBLIC WATER SUPPLY CONSTRUCTION PERMIT

SUBJECT: WESTCHESTER (IL0313150)

Permit Issued to:

Village of Westchester
10300 W. Roosevelt Rd
Westchester, IL 60154

PERMIT NUMBER: 0165-FY2024

DATE ISSUED: October 6, 2023

PERMIT TYPE: Water Main Extension

The issuance of this permit is based on plans and specifications prepared by the engineers/architects indicated, and are identified as follows. This permit is issued for the construction and/or installation of the public water supply improvements described in this document, in accordance with the provisions of the Environmental Protection Act, Title IV, Sections 14 through 17, and Title X, Sections 39 and 40, and is subject to the conditions printed on the last page of this permit and the ADDITIONAL CONDITIONS listed below.

FIRM: Christopher B. Burke Engineering, Ltd.

NUMBER OF PLAN SHEETS: 85

TITLE OF PLANS: "Balmoral Avenue Reconstruction"

APPLICATION RECEIVED DATE: August 11, 2023

PROPOSED IMPROVEMENTS:

*** The installation of approximately 20 feet of 4-inch diameter watermain, 175 feet of 6-inch diameter watermain, 2,827 feet of 8-inch diameter watermain along Balmoral Avenue in Westchester, IL.*****


ADDITIONAL CONDITIONS:

1. All water mains shall be satisfactorily disinfected prior to use pursuant to Ill. Adm. Code, Title 35, Subtitle F, Section 602.310. Two consecutive sets of samples collected at least 24 hours apart must show the absence of coliform bacteria. The samples must be collected from every 1,200 feet of new water main along each branch and from the end of the line. An operating permit must be obtained before the project is placed in service.
2. When the owner or operator of a community water supply replaces a water main, the community water supply shall identify all lead service lines connected to the water main and shall comply with the requirements of Section 17.12 of the Act, 415 ILCS 5/17.12 for lead service line replacement. Galvanized service line must also be replaced if the galvanized service line is or was connected downstream to the lead piping. A statement must be submitted with the Application for Operating Permit indicating either that no full or partial lead service lines were identified or that Section 17.12 of the Act was complied with for this project.

3. When replacing water mains with lead service lines or partial lead service lines connected to them, the owner or operator of the community water supply shall provide the owner or operator of each potentially affected building that is serviced by the affected lead service lines or partial lead service lines, as well as the occupants of those buildings, with an individual written notice. The lead informational notice shall be provided at least 14 days prior to permitted water main work. The notification provided by the community water supply must satisfy the requirements of Section 17.12(jj) of the Act, 415 ILCS 5/17.12(jj). A copy of the notice used must be submitted to the Agency with the Application for Operating Permit.
4. The permit approval is for the Schedule A and 85 plan sheets received on August 11, 2023, Application received on September 13, 2023, Schedule B received on September 14, 2023, and additional information received on September 5-6, 2023, September 11, 2023, and September 18, 2023.

JML:LKW

cc: Christopher B. Burke Engineering, Ltd.
Elgin Regional Office
IDPH/DEH Plumbing & Water Quality Program
Cook County Health Department



Jenny Larsen, P.E.
Working Supervisor, Permit Section – Unit B
Division of Public Water Supplies

STANDARD CONDITIONS FOR CONSTRUCTION/DEVELOPMENT PERMITS
ISSUED BY THE ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

The Illinois Environmental Protection Agency Act (415 ILCS 5/39) grants the Environmental Protection Agency authority to impose conditions on permits which it issues.

These standard conditions shall apply to all permits which the Agency issues for construction or development projects which require permits under the Division of Water Pollution Control, Air Pollution Control, Public Water Supplies and Land Pollution Control. Special conditions may also be imposed by the separate divisions in addition to these standard conditions.

1. Unless this permit has been extended or it has been voided by a newly issued permit, this permit will expire one year after this date of issuance unless construction or development on this project has started on or prior to that date.
2. The construction or development of facilities covered by this permit shall be done in compliance with applicable provisions of Federal laws and regulations, the Illinois Environmental Protection Act, and Rules and Regulations adopted by the Illinois Pollution Control Board.
3. There shall be no deviations from the approved plans and specifications unless a written request for modification of the project, along with plans and specifications as required, shall have been submitted to the Agency and a supplemental written permit issued.
4. The permittee shall allow any agent duly authorized by the Agency upon the presentation of credentials:
 - a. to enter at reasonable times the permittee's premises where actual or potential effluent, emission or noise sources are located or where any activity is to be conducted pursuant to this permit.
 - b. to have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit.
 - c. to inspect at reasonable times, including during any hours of operation of equipment constructed or operated under this permit, such equipment or monitoring methodology or equipment required to be kept, used, operated, calibrated and maintained under this permit.
 - d. to obtain and remove at reasonable times samples of any discharge or emission of pollutants.
 - e. to enter at reasonable times and utilize any photographic, recording, testing, monitoring or other equipment for the purpose of preserving, testing, monitoring, or recording any activity, discharge, or emission authorized by this permit.
5. The issuance of this permit:
 - a. shall not be considered as in any manner affecting the title of the permits upon which the permitted facilities are to be located;
 - b. does not release the permittee from any liability for damage to person or property caused by or resulting from the construction, maintenance, or operation of the proposed facilities;
 - c. does not release the permittee from compliance with the other applicable statutes and regulations of the United States, of the State of Illinois, or with applicable local laws, ordinances and regulations;
 - d. does not take into consideration or attest to the structural stability of any units or parts of the project;
 - e. in no manner implies or suggests that the Agency (or its officers, agents or employees) assumes any liability directly or indirectly for any loss due to damage, installation, maintenance, or operation of the proposed equipment or facility.
6. These standard conditions shall prevail unless modified by special conditions.
7. The Agency may file a complaint with Board of modification, suspension or revocation of a permit:
 - a. upon discovery that the permit application misrepresentation or false statements or that all relevant facts were not disclosed; or
 - b. upon finding that any standard or special conditions have been violated; or
 - c. upon any violation of the Environmental Protection Act or any Rules or Regulation effective thereunder as a result of the construction or development authorized by this permit.